

National/_____Regional Load Despatch Centre

Notice Number: (NLDC/RLDC)/yyyy/mm/... Date: ^{2016/09/04} ^{13/09/2016} dd/mm/yy

Time of Issue: hh:mm

To [✓] NLDC, WRLDCE.

20:44 hrs.

WARNING NOTICE

The actual transfer of electricity on following corridors has crossed the ATC.

Corridor/Control Area	ATC (MW)	Actual Flow (MW)
NR-NR	5900	6400

The following regional entities, which are downstream of the congested corridor, are advised to reduce their draw/increase their generation to decongest the system:

1. NR Constituents.
- ...
- n.

The following regional entities, which are upstream of the congested corridor are advised to / increase their draw/reduce their generation to decongest the system:

1. WR Constituents.
- ...
- n.

[Signature]
Shift Charge Manager 13/09/16

This is a warning notice before levying of congestion charges and issued in accordance with the Central Electricity Regulatory Commission (Measures to relieve congestion in real time operation) Regulations, 2009

NLDC would send this notice to RLDC and RLDC would send this notice to regional entities

Note: Format may be changed as per requirement with prior approval of the Commission.