

✓ National/ Regional Load Despatch Centre

Notice Number: (NLDC/RLDC)/yyyy/mm/... Date: 2016/04/02 24/04/16

Time of Issue: hh:mm

To 10:46

WARNING NOTICE

The actual transfer of electricity on following corridors has crossed the ATC

Corridor/Control Area	ATC (MW)	Actual Flow (MW)
SR Impact	5250	5910

The following regional entities, which are downstream of the congested corridor are advised to reduce their draw/increase their generation to decongest the system:

1. All Regional entities in SR.

The following regional entities, which are upstream of the congested corridor are advised to increase their draw/reduce their generation to decongest the system:

- 1.

*Gupta*  
Shift Charge Manager

This is a warning notice before levying of congestion charges and issued in accordance with the Central Electricity Regulatory Commission (Measurement and congestion in real time operation) Regulations, 2009

NLDC would send this notice to RLDC and RLDC would send this notice to the entities

Note: Power can be changed as per requirement with prior intimation to the concerned entities.