

National/Regional Load Despatch Centre

NUDC/09/2016/09 26/09/16  
Notice Number: (NLDC/RLDC)/yyyy/mm/... Date: dd/mm/yy  
Time of Issue: hh:mm 6:39

WARNING NOTICE

The actual transfer of electricity on following corridors has crossed the ATC.

Corridor/Control Area	ATC (MW)	Actual Flow (MW)
WR - SR	3250	3857

The following regional entities, which are downstream of the congested corridor, are advised to reduce their draw/increase their generation to decongest the system:

All SR constituents / Regional Entities

The following regional entities, which are upstream of the congested corridor are advised to increase their draw/reduce their generation to decongest the system:

All WR constituents / Regional Entities

*[Signature]*  
For (Shift Charge Controller)

This is a warning notice before levying of congestion charges and issued in accordance with the Central Electricity Regulatory Commission (Measures to reduce congestion in real time operation) Regulations, 2009

NLDC would send this notice to RLDC and RLDC would send this notice to regional entities.

Note: Format may be changed as per requirement with prior approval of the Commission.