

National Load Despatch Centre
Import of West Bengal Transfer Capability for June 2021

Issue Date: 26th May 2021

Issue Time: 1600 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st June 2021 to 30th June 2021	00-24	5283	400	4883	2641	2242		
Limiting Constraints		Tripping of 400 kV Sagardighi-Subhasgram causing Thermal loading violation of 220 kV Jeerat-Barasat D/C						