

National Load Despatch Centre
Import of West Bengal Transfer Capability for March 2021

Issue Date: 27th February 2021

Issue Time: 1700 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Mar 2021 to 31st Mar 2021	00-24	5140	400	4740	2640.52	2099		
Limiting Constraints		Tripping of 400 kV Sagardighi-Subhasgram causing Thermal loading violation of 220 kV New Town-Rajarhat D/C						

National Load Despatch Centre			
Import of West Bengal Transfer Capability for Feb 2021			
Revision No	Date of	Period of	Reason for Revision