

**National Load Despatch Centre**  
**Import of Chhattisgarh Transfer Capability for Apr 2022**

Issue Date: 26th Dec 2021

Issue Time: 1500 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Apr 2022 to 30th Apr 2022	00-24	2590	50	2540	3437.61	-898		
<b>Limiting Constraints</b>		N-1 contingency of (a) 2X 315 MVA, 400/220kV NSPCL ICTs, (b) 2X 315 MVA, 400/220kV Bhatapara ICTs, (c) 2X 315 MVA, 400/220kV Raigarh-PG ICTs						

**National Load Despatch Centre**  
**Import of Chhattisgarh Transfer Capability for Apr 2022**

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>

**National Load Despatch Centre**  
**Import of Daman & Diu Transfer Capability for Apr 2022**

Issue Date: 26th Dec 2021

Issue Time: 1500 hrs

Revision No. 0

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC)</b>	<b>Reliability Margin</b>	<b>Available Transfer Capability (ATC)</b>	<b>Long Term Access (LTA)/ Medium Term Open Access (MTOA) #</b>	<b>Margin Available for Short Term Open Access (STOA)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
1st Apr 2022 to 30th Apr 2022	00-24	620	10	610	340	270		
<b>Limiting Constraints</b>		N-1 contingency of 220 kV Magarwada(PG)-Magarwada(DD) D/C						

**National Load Despatch Centre**  
**Import of Daman & Diu Transfer Capability for Apr 2022**

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>

**National Load Despatch Centre**  
**Import of DNH Transfer Capability for Apr 2022**

Issue Date: 26th Dec 2021

Issue Time: 1500 hrs

Revision No. 0

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC)</b>	<b>Reliability Margin</b>	<b>Available Transfer Capability (ATC)</b>	<b>Long Term Access (LTA)/ Medium Term Open Access (MTOA) #</b>	<b>Margin Available for Short Term Open Access (STOA)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
1st Apr 2022 to 30th Apr 2022	00-24	840	15	825	1201	-376		Allocated LTA is more than ATC
<b>Limiting Constraints</b>		N-1 contingency of 220 kV Kala-Khadoli D/C						

**National Load Despatch Centre**  
**Import of DNH Transfer Capability for Apr 2022**

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>

**National Load Despatch Centre**  
**Import of Goa Transfer Capability for Apr 2022**

Issue Date: 26th Dec 2021

Issue Time: 1500 hrs

Revision No. 0

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC)</b>	<b>Reliability Margin</b>	<b>Available Transfer Capability (ATC)</b>	<b>Long Term Access (LTA)/ Medium Term Open Access (MTOA) #</b>	<b>Margin Available for Short Term Open Access (STOA)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
1st Apr 2022 to 30th Apr 2022	00-24	710	15	695	588	107		
<b>Limiting Constraints</b>		N-1 contingency of 220 kV Mapusa-Ponda-S/C						

**National Load Despatch Centre**  
**Import of Goa Transfer Capability for Apr 2022**

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>



**National Load Despatch Centre**  
**Import of Gujarat Transfer Capability for Apr 2022**

Issue Date: 26th Dec 2021

Issue Time: 1500 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
<b>With SSP Generation</b>								
1st Apr 2022 to 30th Apr 2022	00-09	10230	330	9900	8863.516	1036.484		https://www.sldcguj.com/Operation/TTC-ATC-Gujarat_State_Revised_9500-9900_Web.pdf
1st Apr 2022 to 30th Apr 2022	09-17	9830	330	9500	8863.516	636.484		
1st Apr 2022 to 30th Apr 2022	17-24	10230	330	9900	8863.516	1036.484		
<b>Without SSP Generation</b>								
1st Apr 2022 to 30th Apr 2022	00-09	10030	330	9700	8863.516	836.484		https://www.sldcguj.com/Operation/TTC-ATC-Gujarat_State_Revised_9500-9900_Web.pdf
1st Apr 2022 to 30th Apr 2022	09-17	9630	330	9300	8863.516	436.484		
1st Apr 2022 to 30th Apr 2022	17-24	10030	330	9700	8863.516	836.484		
<b>Limiting Constraints</b>		1) N-1 contingency of 400 kV D/C Banaskantha – Veloda line. 2) N-1 contingency of 765/400 kV Vadodara ICTs 3) N-1 contingency of 400 kV D/C Kala – Kudus line						

**National Load Despatch Centre**  
**Import of Gujarat Transfer Capability for Apr 2022**

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>

**National Load Despatch Centre**  
**Import of Madhya Pradesh Transfer Capability for Apr 2022**

Issue Date: 26th Dec 2021

Issue Time: 1500 hrs

Revision No. 0

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC)</b>	<b>Reliability Margin</b>	<b>Available Transfer Capability (ATC)</b>	<b>Long Term Access (LTA)/ Medium Term Open Access (MTOA) #</b>	<b>Margin Available for Short Term Open Access (STOA)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
*1st Apr 2022 to 30th Apr 2022	00-24	11091	340	10751	10021	730		Link:- <a href="https://www.sldcmpindia.com/page.php?id=20">https://www.sldcmpindia.com/page.php?id=20</a>
<b>Limiting Constraints</b>								

\* TTC/ATC as declared by SLDC MP in website (Not available for Apr 2022. Hence, Dec'21 TTC/ATC only considered for Apr'22 month also)

**National Load Despatch Centre**  
**Import of Madhya Pradesh Transfer Capability for Apr 2022**

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>

**National Load Despatch Centre**  
**Import of Maharashtra Transfer Capability for Apr 2022**

Issue Date: 26th Dec 2021

Issue Time: 1500 hrs

Revision No. 0

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC)</b>	<b>Reliability Margin</b>	<b>Available Transfer Capability (ATC)</b>	<b>Long Term Access (LTA)/ Medium Term Open Access (MTOA) #</b>	<b>Margin Available for Short Term Open Access (STOA)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
1st Apr2022 to 30th Apr 2022	00-24	10060	300	9760	9395.62	364		
<b>Limiting Constraints</b>		N-1 of 400 kV Parli-PG-Parli-MH-DC						

**National Load Despatch Centre**  
**Import of Maharashtra Transfer Capability for Apr 2022**

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>