

National Load Despatch Centre
Import of Maharashtra Transfer Capability for July 2022

Issue Date: 26th Mar 2022

Issue Time: 1500 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st July 2022 to 31st July 2022	00-24	10060	300	9760	9830.22	0		
Limiting Constraints		N-1 of 400 kV Parli-PG-Parli-MH-DC						

National Load Despatch Centre
Import of Maharashtra Transfer Capability for July 2022

Revision No	Date of Revision	Period of Revision	Reason for Revision

National Load Despatch Centre
Import of Gujarat Transfer Capability for July 2022

Issue Date: 26th Mar 2022

Issue Time: 1500 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
With SSP Generation								
1st July 2022 to 31st July 2022	00-09	10230	330	9900	10279.026	0		https://www.sldcguj.com/Operation/TTC-ATC-Gujarat_State_Revised_9500-9900_Web.pdf
1st July 2022 to 31st July 2022	09-17	9830	330	9500	10279.026	0		
1st July 2022 to 31st July 2022	17-24	10230	330	9900	10279.026	0		
Without SSP Generation								
1st July 2022 to 31st July 2022	00-09	10030	330	9700	10279.026	0		https://www.sldcguj.com/Operation/TTC-ATC-Gujarat_State_Revised_9500-9900_Web.pdf
1st July 2022 to 31st July 2022	09-17	9630	330	9300	10279.026	0		
1st July 2022 to 31st July 2022	17-24	10030	330	9700	10279.026	0		
Limiting Constraints		1) N-1 contingency of 400 kV D/C Banaskantha – Veloda line. 2) N-1 contingency of 765/400 kV Vadodara ICTs 3) N-1 contingency of 400 kV D/C Kala – Kudus line						

National Load Despatch Centre
Import of Gujarat Transfer Capability for June 2022

Revision No	Date of Revision	Period of Revision	Reason for Revision

National Load Despatch Centre
Import of Madhya Pradesh Transfer Capability for July 2022

Issue Date: 26th Mar 2022

Issue Time: 1700 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
*1st July 2022 to 31st July 2022	00-24	10801	300	10501.00	10115.20	386		Link:- https://www.sldcmpindia.com/page.php?id=20
Limiting Constraints								

* TTC/ATC as declared by SLDC MP in website (Not available for July 2022. Hence, Apr'22 TTC/ATC only considered for July'22 month also)

National Load Despatch Centre
Import of Madhya Pradesh Transfer Capability for July 2022

Revision No	Date of Revision	Period of Revision	Reason for Revision

National Load Despatch Centre
Import of Chhattisgarh Transfer Capability for July 2022

Issue Date: 26th Mar 2022

Issue Time: 1700 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st July 2022 to 31st July 2022	00-24	2590	50	2540	3437.61	0		
Limiting Constraints		N-1 contingency of (a) 2X 315 MVA, 400/220kV NSPCL ICTs, (b) 2X 315 MVA, 400/220kV Bhatapara ICTs, (c) 2X 315 MVA, 400/220kV Raigarh-PG ICTs						

National Load Despatch Centre
Import of Chhattisgarh Transfer Capability for July 2022

Revision No	Date of Revision	Period of Revision	Reason for Revision

National Load Despatch Centre
Import of Goa Transfer Capability for July 2022

Issue Date: 26th Mar 2022

Issue Time: 1700 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st July 2022 to 31st July 2022	00-24	710	15	695	588	107		
Limiting Constraints		N-1 contingency of 220 kV Mapusa-Ponda-S/C						

National Load Despatch Centre
Import of Goa Transfer Capability for July 2022

Revision No	Date of Revision	Period of Revision	Reason for Revision

National Load Despatch Centre
Import of Daman & Diu Transfer Capability for July 2022

Issue Date: 26th Mar 2022

Issue Time: 1700 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st July 2022 to 31st July 2022	00-24	620	10	610	340	270		
Limiting Constraints		N-1 contingency of 220 kV Magarwada(PG)-Magarwada(DD) D/C						

National Load Despatch Centre
Import of Daman & Diu Transfer Capability for July 2022

Revision No	Date of Revision	Period of Revision	Reason for Revision

National Load Despatch Centre
Import of DNH Transfer Capability for July 2022

Issue Date: 26th Mar 2022

Issue Time: 1700 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st July 2022 to 31st July 2022	00-24	840	15	825	1201	0		Allocated LTA is more than ATC
Limiting Constraints		N-1 contingency of 220 kV Kala-Khadoli D/C						

National Load Despatch Centre
Import of DNH Transfer Capability for July 2022

Revision No	Date of Revision	Period of Revision	Reason for Revision