

National Load Despatch Centre
Import of Chhattisgarh Transfer Capability for Sept 2022

Issue Date: 26th May 2022

Issue Time: 1700 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Sept 2022 to 30th Sept 2022	00-24	2590	50	2540	3448.91	-909		
Limiting Constraints		N-1 contingency of (a) 2X 315 MVA, 400/220kV NSPCL ICTs, (b) 2X 315 MVA, 400/220kV Bhatapara ICTs, (c) 2X 315 MVA, 400/220kV Raigarh-PG ICTs						

National Load Despatch Centre
Import of Chhattisgarh Transfer Capability for Sept 2022

Revision No	Date of Revision	Period of Revision	Reason for Revision

National Load Despatch Centre
Import of Daman & Diu Transfer Capability for Sept 2022

Issue Date: 26th May 2022

Issue Time: 1700 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Sept 2022 to 30th Sept 2022	00-24	620	10	610	340	270		
Limiting Constraints		N-1 contingency of 220 kV Magarwada(PG)-Magarwada(DD) D/C						

National Load Despatch Centre
Import of Daman & Diu Transfer Capability for Sept 2022

Revision No	Date of Revision	Period of Revision	Reason for Revision

National Load Despatch Centre
Import of DNH Transfer Capability for Sept 2022

Issue Date: 26th May 2022

Issue Time: 1700 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Sept 2022 to 30th Sept 2022	00-24	840	15	825	1201	-376		Allocated LTA is more than ATC
Limiting Constraints		N-1 contingency of 220 kV Kala-Khadoli D/C						

National Load Despatch Centre
Import of DNH Transfer Capability for Sept 2022

Revision No	Date of Revision	Period of Revision	Reason for Revision

National Load Despatch Centre
Import of Goa Transfer Capability for Sept 2022

Issue Date: 26th May 2022

Issue Time: 1700 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Sept 2022 to 30th Sept 2022	00-24	710	15	695	588	107		
Limiting Constraints		N-1 contingency of 220 kV Mapusa-Ponda-S/C						

National Load Despatch Centre
Import of Goa Transfer Capability for Sept 2022

Revision No	Date of Revision	Period of Revision	Reason for Revision

National Load Despatch Centre
Import of Gujarat Transfer Capability for Sept 2022

Issue Date: 26th May 2022

Issue Time: 1700 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
With SSP Generation								
1st Sept 2022 to 30th Sept 2022	00-09	10230	330	9900	10189.03	-289.03		https://www.sldcguj.com/Operation/TTC-ATC-Gujarat_State_Revised_9500-9900_Web.pdf
1st Sept 2022 to 30th Sept 2022	09-17	9830	330	9500	10189.03	-689.03		
1st Sept 2022 to 30th Sept 2022	17-24	10230	330	9900	10189.03	-289.03		
Without SSP Generation								
1st Sept 2022 to 30th Sept 2022	00-09	10030	330	9700	10189.03	-489.03		https://www.sldcguj.com/Operation/TTC-ATC-Gujarat_State_Revised_9500-9900_Web.pdf
1st Sept 2022 to 30th Sept 2022	09-17	9630	330	9300	10189.03	-889.03		
1st Sept 2022 to 30th Sept 2022	17-24	10030	330	9700	10189.03	-489.03		
Limiting Constraints		1) N-1 contingency of 400 kV D/C Banaskantha – Veloda line. 2) N-1 contingency of 400 kV D/C Kala – Kudus line						

National Load Despatch Centre
Import of Gujarat Transfer Capability for Sept 2022

Revision No	Date of Revision	Period of Revision	Reason for Revision

National Load Despatch Centre
Import of Madhya Pradesh Transfer Capability for Sept 2022

Issue Date: 26th May 2022

Issue Time: 1700 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
*1st Sept 2022 to 30th Sept 2022	00-24	10801	300	10501.00	10897.70	-397		Link:- https://www.sldcmpindia.com/page.php?id=20
Limiting Constraints								

* TTC/ATC as declared by SLDC MP in website (Not available for Sept 2022. Hence, Apr'22 TTC/ATC only considered for Sept'22 month also)

National Load Despatch Centre
Import of Madhya Pradesh Transfer Capability for Sept 2022

Revision No	Date of Revision	Period of Revision	Reason for Revision

National Load Despatch Centre
Import of Maharashtra Transfer Capability for Sept 2022

Issue Date: 26th May 2022

Issue Time: 1700 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Sept 2022 to 30th Sept 2022	00-24	10060	300	9760	9889.82	-130		
Limiting Constraints		N-1 of 400 kV Parli-PG-Parli-MH-DC						

National Load Despatch Centre
Import of Maharashtra Transfer Capability for Sept 2022

Revision No	Date of Revision	Period of Revision	Reason for Revision