

Rev-1									10.04.2023
State	Date	Time Period (hrs)	TTC (MW)	TRM (MW)	ATC (MW)	Share allocation/ LTA/MTOA (MW)	Margin (ATC-share allocation/L TA/MTOA) (MW)	Limiting Constraint	Remarks
Maharashtra	01 st Apr-10 th Apr' 23	00-24	10060	300	9760	9896	0	1. N-1 contingency of 400 kV Parli-PG-Parli-MH-DC 2. N-1 contingency of 400 kV Pune(GIS)-Pune(PG)-Q/c	
	11 th Apr-30 th Apr' 23	00-24	10060	300	9760	10047	0	3. N-1 contingency of 765/400 kV Ektuni ICTs	
#Gujarat	01 st Apr-10 th Apr' 23	00-09	12820	370	12450	10704	1746	1 Contingency of 400 kV Kankroli-Zerda-S/c and subsequent high loading on 400 kV Bhinmal-Zerda-S/c 2. N-1 contingency of 400 kV Kudus-Kala-DC	If SSP Generation : 450 MW
		09-17	12420	370	12050	10704	1346		If SSP Generation : 50 MW
		17-24	12820	370	12450	10704	1746		
	01 st Apr-10 th Apr' 23	00-09	12620	370	12250	10704	1546		
		09-17	12220	370	11850	10704	1146		
		17-24	12620	370	12250	10704	1546		
	11 th Apr-	00-09	12820	370	12450	11321	1129		

	30 th Apr' 23	09-17	12420	370	12050	11321	729		If SSP Generation : 450 MW
		17-24	12820	370	12450	11321	1129		
		00-09	12620	370	12250	11321	929		If SSP Generation : 50 MW
		09-17	12220	370	11850	11321	529		
		17-24	12620	370	12250	11321	929		
*Madhya Pradesh	01 st Apr- 10 th Apr' 23	00-24	10369	300	10069	10595.23	0		
	11 th Apr- 30 th Apr' 23	00-24	10015	300	9715	10595.23	0		
Chhattisgarh	01 st Apr- 10 th Apr' 23	00-24	2590	50	2540	3918.07	0	N-1 contingency of (a)400/220 kV Bhatapara ICTs, (b) 400/220 kV NSPCL ICTs, (c) 400/220kV Raigarh-PG ICTs	
	11 th Apr- 30 th Apr' 23	00-24	2590	50	2540	3918.07	0		
Goa	01 st Apr- 10 th	00-24	710	15	695	625	70	N-1 contingency of 220 kV Mapusa-Ponda-S/C & subsequent 220 kV & 110 kV voltages in Goa	

	Apr' 23							system are at the verge of 0.9 pu.	
	11 th Apr-30 th Apr' 23	00-24	710	15	695	625	70	N-1 contingency of 220 kV Mapusa-Ponda-S/C & subsequent 220 kV & 110 kV voltages in Goa system are at the verge of 0.9 pu.	
DNHDDPDC L	01 st Apr-10 th Apr' 23	00-24	1310	25	1285	1464	0	a) N-1 contingency of 220 kV Magarwada (PG)-Magarwada (DD) D/C b) N-1 contingency of 220 kV Kala-Khadoli D/C	
	11 th Apr-30 th Apr' 23	00-24	1310	25	1285	1464	0		
^DD	01 st Apr-10 th Apr' 23	00-24	470	10	460	323	137	N-1 contingency of 220 kV Magarwada (PG)-Magarwada (DD) D/C	
	11 th Apr-30 th Apr' 23	00-24	470	10	460	323	137		
^DNH	01 st Apr-10 th Apr' 23	00-24	840	15	825	1142	0	N-1 contingency of 220 kV Kala-Khadoli D/C	
	11 th Apr-30 th	00-24	840	15	825	1142	0		

	Apr' 23								
# https://www.sldcguj.com/Operation/TTC-ATC-Gujarat_State_Revised_9500-9900_Web.pdf									
* https://www.sldcmpindia.com/page.php?id=20 (Updated as per SLDC MP declaration)									
^ For monitoring of DNH and DD ATC in real time system operation									