

National Load Despatch Centre
Import of Chhattisgarh Transfer Capability for Nov 2022

Issue Date: 26th July 2022

Issue Time: 1700 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Nov 2022 to 30th Nov 2022	00-24	2590	50	2540	3448.91	0		
Limiting Constraints		N-1 contingency of (a) 2X 315 MVA, 400/220kV NSPCL ICTs, (b) 2X 315 MVA, 400/220kV Bhatapara ICTs, (c) 2X 315 MVA, 400/220kV Raigarh-PG ICTs						

National Load Despatch Centre
Import of Chhattisgarh Transfer Capability for Nov 2022

Revision No	Date of Revision	Period of Revision	Reason for Revision

National Load Despatch Centre
Import of Goa Transfer Capability for Nov 2022

Issue Date: 26th July 2022

Issue Time: 1700 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Nov 2022 to 30th Nov 2022	00-24	710	15	695	588	107		
Limiting Constraints		N-1 contingency of 220 kV Mapusa-Ponda-S/C & subsequent 220 kV & 110 kV voltages in Goa system are at the verge of 0.9 pu						

National Load Despatch Centre
Import of Goa Transfer Capability for Nov 2022

Revision No	Date of Revision	Period of Revision	Reason for Revision

National Load Despatch Centre
Import of Gujarat Transfer Capability for Nov 2022

Issue Date: 26th July 2022

Issue Time: 1700 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
With SSP Generation								
1st Nov 2022 to 30th Nov 2022	00-09	12820	370	12450	10178	2272		https://www.slcdguj.com/Operation/TTC-ATC-Gujarat_State_Revised_9500-9900_Web.pdf
1st Nov 2022 to 30th Nov 2022	09-17	12420	370	12050	10178	1872		
1st Nov 2022 to 30th Nov 2022	17-24	12820	370	12450	10178	2272		
Without SSP Generation								
1st Nov 2022 to 30th Nov 2022	00-09	12620	370	12250	10178	2072		https://www.slcdguj.com/Operation/TTC-ATC-Gujarat_State_Revised_9500-9900_Web.pdf
1st Nov 2022 to 30th Nov 2022	09-17	12220	370	11850	10178	1672		
1st Nov 2022 to 30th Nov 2022	17-24	12620	370	12250	10178	2072		
Limiting Constraints		1) Contingency of 400 kV Kankroli-Zerda-S/c and subsequent high loading on 400 kV Bhinmal-Zerda-S/c 2) N-1 contingency of 400 kV D/C Kala – Kudus line						

National Load Despatch Centre
Import of Gujarat Transfer Capability for Nov 2022

Revision No	Date of Revision	Period of Revision	Reason for Revision

National Load Despatch Centre
Import of Madhya Pradesh Transfer Capability for Nov 2022

Issue Date: 26th July 2022

Issue Time: 1700 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
*1st Nov 2022 to 30th Nov 2022	00-24	10978.00	300	10678.00	10897.70	0		Link:- https://www.sldcmpindia.com/page.php?id=20
Limiting Constraints								

* TTC/ATC as declared by SLDC MP in website (Not available for Nov 2022. Hence, June'22 TTC/ATC only considered for Nov'22 month also)

National Load Despatch Centre
Import of Madhya Pradesh Transfer Capability for Nov 2022

Revision No	Date of Revision	Period of Revision	Reason for Revision

National Load Despatch Centre
Import of Maharashtra Transfer Capability for Nov 2022

Issue Date: 26th July 2022

Issue Time: 1700 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Nov 2022 to 30th Nov 2022	00-24	10060	300	9760	9889.82	0		
Limiting Constraints		N-1 of 400 kV Parli-PG-Parli-MH-DC						

National Load Despatch Centre
Import of Maharashtra Transfer Capability for Nov 2022

Revision No	Date of Revision	Period of Revision	Reason for Revision