

GRID CONTROLLER OF INDIA LIMITED
National Load Despatch Centre



From: The Shift Charge Manager, NLDC

To: The Shift Charge Manager, ERLDC/NERLDC

Date: 18/07/2023

Time: 13:48:53

Sl.No	Corridor	Current TTC(MW)	Current ATC(MW)	Revised TTC(MW)	Revised ATC(MW)	Change in ATC (MW)	Date for which Revision is done(dd-mm-yyyy)	Time Block for Revision(From TB)	Time Block for Revision(To TB)	Reason for Revision/Event for which TTC/ATC Revision is being done
1	ER-NER	1760	1700	1930	1870	170	2023-07-18	57	76	Due to unavailed Outage of 400kV Bongaigaon - Brynihat.
2	ER-NER	1500	1440	1680	1620	180	2023-07-18	77	92	Due to unavailed Outage of 400kV Bongaigaon - Brynihat.
3	ER-NER	1760	1700	1930	1870	170	2023-07-18	93	96	Due to unavailed Outage of 400kV Bongaigaon - Brynihat.
4	NER_IMPORT	1260	1200	1430	1370	170	2023-07-18	57	76	Due to unavailed Outage of 400kV Bongaigaon - Brynihat.
5	NER_IMPORT	1000	940	1180	1120	180	2023-07-18	77	92	Due to unavailed Outage of 400kV Bongaigaon - Brynihat.
6	NER_IMPORT	1260	1200	1430	1370	170	2023-07-18	93	96	Due to unavailed Outage of 400kV Bongaigaon - Brynihat.

SCE-NLDC