

GRID CONTROLLER OF INDIA LIMITED  
National Load Despatch Centre



From: The Shift Charge Manager, NLDC

To: The Shift Charge Manager, WRLDC/ERLDC/SRLDC

Date: 25/08/2023

Time: 18:04:35

Sl.No	Corridor	Current TTC(MW)	Current ATC(MW)	Revised TTC(MW)	Revised ATC(MW)	Change in ATC (MW)	Date for which Revision is done(dd-mm-yyyy)	Time Block for Revision(From TB)	Time Block for Revision(To TB)	Reason for Revision/Event for which TTC/ATC Revision is being done
1	WR-SR	9800	9150	11600	10950	1800	2023-08-25	77	96	Due to HVDC Bypass mock drill at HVDC Bhadrawati and outage of HVDC 500KV BHADRAVTAHI POLE 1 & 2
2	ER-SR	5400	5050	5700	5350	300	2023-08-25	77	96	Due to HVDC Bypass mock drill at HVDC Bhadrawati and outage of HVDC 500KV BHADRAVTAHI POLE 1 & 2
3	SR_IMPORT	15200	14200	17300	16300	2100	2023-08-25	77	96	Due to HVDC Bypass mock drill at HVDC Bhadrawati and outage of HVDC 500KV BHADRAVTAHI POLE 1 & 2

SCE-NLDC