

GRID CONTROLLER OF INDIA LIMITED  
National Load Despatch Centre



From: The Shift Charge Manager, NLDC

To: The Shift Charge Manager, WRLDC/SRLDC

Date: 9/1/2023  
Time: 4:21:13 PM

| Sl.No | Corridor  | Current TTC(MW) | Current ATC(MW) | Revised TTC(MW) | Revised ATC(MW) | Change in ATC (MW) | Date for which Revision is done(dd-mm-yyyy) | Time Block for Revision(From TB) | Time Block for Revision(To TB) | Reason for Revision/Event for which TTC/ATC Revision is being done |
|-------|-----------|-----------------|-----------------|-----------------|-----------------|--------------------|---|----------------------------------|--------------------------------|--|
| 1     | WR-SR     | 10700           | 10050           | 9400            | 8750            | -1300              | 2023-09-01                                  | 69                               | 96                             | Emergency shutdown of Raigarh- Pugalur HVDC Pole-2                 |
| 2     | SR_IMPORT | 16150           | 15150           | 14850           | 13850           | -1300              | 2023-09-01                                  | 69                               | 96                             | Emergency shutdown of Raigarh- Pugalur HVDC Pole-2                 |
| 3     | SR-WR     | 7650            | 7000            | 6850            | 6200            | -800               | 2023-09-01                                  | 69                               | 96                             | Emergency shutdown of Raigarh- Pugalur HVDC Pole-2                 |
| 4     | SR_EXPORT | 6600            | 5950            | 5800            | 5150            | -800               | 2023-09-01                                  | 69                               | 72                             | Emergency shutdown of Raigarh- Pugalur HVDC Pole-2                 |
| 5     | SR_EXPORT | 5150            | 4500            | 4350            | 3700            | -800               | 2023-09-01                                  | 73                               | 96                             | Emergency shutdown of Raigarh- Pugalur HVDC Pole-2                 |

SCE-NLDC