

GRID CONTROLLER OF INDIA LIMITED
National Load Despatch Centre



From: The Shift Charge Manager, NLDC

To: The Shift Charge Manager, WRLDC/ERLDC/SRLDC

Date: 11/24/2023
Time: 10:35:13 PM

Sl.No	Corridor	Current TTC(MW)	Current ATC(MW)	Revised TTC(MW)	Revised ATC(MW)	Change in ATC (MW)	Date for which Revision is done(dd-mm-yyyy)	Time Block for Revision(From TB)	Time Block for Revision(To TB)	Reason for Revision/Event for which TTC/ATC Revision is being done
1	WR-SR	14250	13600	13350	12700	-900	2023-11-25	1	34	HVDC 800KV PUGALUR HVDC POLE 1,2,3 & 4 Shutdown Cancelled so ATC revived and HVDC Bhadrwati shutdown continued to ATC Curtailed
2	WR-SR	8250	7600	13350	12700	5100	2023-11-25	35	96	HVDC 800KV PUGALUR HVDC POLE 1,2,3 & 4 Shutdown Cancelled so ATC revived and HVDC Bhadrwati shutdown continued to ATC Curtailed
3	SR_IMPORT	20200	19200	19150	18150	-1050	2023-11-25	1	24	HVDC 800KV PUGALUR HVDC POLE 1,2,3 & 4 Shutdown Cancelled so ATC revived and HVDC Bhadrwati shutdown continued to ATC Curtailed
4	SR_IMPORT	20200	19200	20200	19200	0	2023-11-25	25	34	HVDC 800KV PUGALUR HVDC POLE 1,2,3 & 4 Shutdown Cancelled so ATC revived and HVDC Bhadrwati shutdown continued to ATC Curtailed
5	SR_IMPORT	14200	13200	19150	18150	4950	2023-11-25	35	72	HVDC 800KV PUGALUR HVDC POLE 1,2,3 &

Sl.No	Corridor	Current TTC(MW)	Current ATC(MW)	Revised TTC(MW)	Revised ATC(MW)	Change in ATC (MW)	Date for which Revision is done(dd-mm-yyyy)	Time Block for Revision(From TB)	Time Block for Revision(To TB)	Reason for Revision/Event for which TTC/ATC Revision is being done
										4 Shutdown Cancelled so ATC revived and HVDC Bhadrwati shutdown continued to ATC Curtailed
6	SR-WR	6000	5350	5700	5050	-300	2023-11-25	1	24	HVDC 800KV PUGALUR HVDC POLE 1,2,3 & 4 Shutdown Cancelled so ATC revived and HVDC Bhadrwati shutdown continued to ATC Curtailed
7	SR-WR	7650	7000	8600	7950	950	2023-11-25	25	34	HVDC 800KV PUGALUR HVDC POLE 1,2,3 & 4 Shutdown Cancelled so ATC revived and HVDC Bhadrwati shutdown continued to ATC Curtailed
8	SR-WR	6400	5750	7350	6700	950	2023-11-25	35	72	HVDC 800KV PUGALUR HVDC POLE 1,2,3 & 4 Shutdown Cancelled so ATC revived and HVDC Bhadrwati shutdown continued to ATC Curtailed
9	SR-WR	6000	5350	5700	5050	-300	2023-11-25	73	96	HVDC 800KV PUGALUR HVDC POLE 1,2,3 & 4 Shutdown Cancelled so ATC revived and HVDC Bhadrwati shutdown continued to ATC Curtailed
10	SR_EXPORT	5150	4500	4850	4200	-300	2023-11-25	1	24	HVDC 800KV PUGALUR HVDC POLE 1,2,3 & 4 Shutdown Cancelled so ATC revived and HVDC Bhadrwati shutdown continued to ATC Curtailed

Sl.No	Corridor	Current TTC(MW)	Current ATC(MW)	Revised TTC(MW)	Revised ATC(MW)	Change in ATC (MW)	Date for which Revision is done(dd-mm-yyyy)	Time Block for Revision(From TB)	Time Block for Revision(To TB)	Reason for Revision/Event for which TTC/ATC Revision is being done
11	SR_EXPORT	6600	5950	7550	6900	950	2023-11-25	25	34	HVDC 800KV PUGALUR HVDC POLE 1,2,3 & 4 Shutdown Cancelled so ATC revived and HVDC Bhadrwati shutdown continued to ATC Curtailed
12	SR_EXPORT	5350	4700	6300	5650	950	2023-11-25	35	72	HVDC 800KV PUGALUR HVDC POLE 1,2,3 & 4 Shutdown Cancelled so ATC revived and HVDC Bhadrwati shutdown continued to ATC Curtailed
13	SR_EXPORT	5150	4500	4850	4200	-300	2023-11-25	73	96	HVDC 800KV PUGALUR HVDC POLE 1,2,3 & 4 Shutdown Cancelled so ATC revived and HVDC Bhadrwati shutdown continued to ATC Curtailed
14	S1-(S2&S3)	8050	7600	9500	9050	1450	2023-11-25	25	96	HVDC 800KV PUGALUR HVDC POLE 1,2,3 & 4 Shutdown Cancelled so ATC revived and HVDC Bhadrwati shutdown continued to ATC Curtailed
15	ER-SR	5950	5600	5800	5450	-150	2023-11-25	1	96	HVDC 800KV PUGALUR HVDC POLE 1,2,3 & 4 Shutdown Cancelled so ATC revived and HVDC Bhadrwati shutdown continued to ATC Curtailed