

National Load Despatch Centre
Import of Arunachal Pradesh Transfer Capability for February 2021

Issue Date: 28th January 2021

Issue Time: 1600 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Feb 2021 to 28th Feb 2021	00 - 17	207	5	202	6	196	-	
1st Feb 2021 to 28th Feb 2021	17- 23	203	5	198	6	192	-	
1st Feb 2021 to 28th Feb 2021	23 - 24	208	5	203	6	197	-	
Limiting Constraints: N-1 of 132 kV Ranganadi-Zero S/C and limiting observed at 132 kV Naharlagun-Pare S/C								

Note : These are indicative figures to encourage self regulation among states.

National Load Despatch Centre
Import of Arunachal Pradesh Transfer Capability for Feb 2021

Revision No	Date of Revision	Period of Revision	Reason for Revision