

National Load Despatch Centre
Import of Arunachal Pradesh Transfer Capability for November 2021

Issue Date: 27th Oct 2021

Issue Time: 2000 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Nov 2021 to 30th Nov 2021	00 - 17	180	5	175	6	169	-	
	17 - 21	180	5	175	6	169	-	
	21 - 24	180	5	175	6	169	-	

Limiting Constraints: N-1 of 132 kV Naharlagun - Pare and limiting observed at 132 kV Pare - Itanagar S/C