

National Load Despatch Centre
Import of Assam Transfer Capability for February 2021

Issue Date: 28th January 2021

Issue Time: 1600 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Feb 2021 to 28th Feb 2021	00 - 17	1075	40	1035	271	764	-	
1st Feb 2021 to 28th Feb 2021	17- 23	1050	40	1010	271	739	-	
1st Feb 2021 to 28th Feb 2021	23 - 24	1782	40	1742	271	1471	-	
Limiting Constraints	N-1 of 220/132 kV,160 MVA ICT at BTPS and Limiting constraint observed at 220/132 kV ,100 MVA ICT at BTPS							

Note : These are indicative figures to encourage self regulation among states.

National Load Despatch Centre
Import of Assam Transfer Capability for Feb 2021

Revision No	Date of Revision	Period of Revision	Reason for Revision