

**National Load Despatch Centre  
Total Transfer Capability for April 2015**

Issue Date: 14/04/2015

Issue Time: 1510 hrs

Revision No. 12

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
NR-WR *	1st April 2015 to 30th April 2015	00-24	2500	500	2000	706	1294			
WR-NR *	1st April 2015 to 11th April 2015	00-17	5100	500	4600	5157	0			
		23-24	5100		4600		0			
	12th April 2015	00-07	5100	500	4600	5157	0			
		07-24	4850		4350		0			
	13th April 2015 to 30th April 2015	00-17	5100	500	4600	5157	0			
		23-24	5100		4600		0			
		17-23	5100		4600		0			
NR-ER*	1st April 2015 to 30th April 2015	00-06	2000	200	1800	293	1507			
		06-18	2000		1800	358	1442			
		18-24	2000		1800	293	1507			
ER-NR *	1st April 2015 to 30th April 2015	00-17	3400	300	3100	2431	669			
		23-24	3400		3100		669			
W3-ER <sup>s</sup>	1st April 2015 to 30th April 2015	00-24	No limit is being specified. Re-routing is allowed via W3-ER-NR.							No
ER-W3	1st April 2015 to 30th April 2015	00-24	1000	300	700	874	0			
WR-SR	1st April 2015 to 6th April 2015	05-22	2300	750	1550	1350	200			
		00-05	2700		1950		600			
		22-24	2700		1950		600			
	7th April 2015	00-05	2700	750	1950	1350	600			
		05-06	2300		1550		200			
		06-08	2150		1400		50			
		08-22	1800		1050		0			
		22-24	2200		1450		100			
	8th April 2015 to 14th April 2015	00-05	2700	750	1950	1350	600			
		05-22	2300		1550		200			
		22-24	2300		1550		200			
	15th April 2015	00-05	2700	750	1950	1350	600			
		05-22	2300		1550		200			
		22-24	2300		1550		200			
16th April 2015 to 30th April 2015	05-22	2300	750	1550	1350	200				
	00-05	2700		1950		600				
		22-24	2300		1550	200	-400	Due to S/D of 400 KV Sholapur(PG) Bus-2		
SR-WR *	1st April 2015 to 30th April 2015	00-24	No limit is being Specified.							
ER-SR	1st April 2015 to 30th April 2015	00-06	2650	0	2650	2585	65			
		18-24				2650	0			
SR-ER *	1st April 2015 to 30th April 2015	00-24	No limit is being Specified.							
ER-NER	1st April 2015 to 30th April 2015	00-17	1100	40	1060	210	850			
		23-24			920		880			670
NER-ER	1st April 2015 to 30th April 2015		No limit is being Specified.							
S1-S2	1st April 2015 to 3rd April 2015	00-24	2885	315	2570	2535	35			
	4th April 2015	00-08	2885	315	2570	2535	35			
		08-24	3330	315	3015	2535	480			
	5th April 2015 to 6th April 2015	00-24	3330	315	3015	2535	480			
	7th April 2015	00-24	2970	315	2655	2535	120			
		0000-1030	2970	315	2655	2535	120			
	8th April 2015	1030-2400	3165	315	2850	2644	206			
		00-08	3165	315	2850	2644	206			
	08-18	3015	2700		2644	56				
	18-24	2880	2565		2535	30				
10th April 2015 to 12th April 2015	00-24	2880	315	2565	2535	30				
	0000-1015	2880		2565	2535	30				

**National Load Despatch Centre  
Total Transfer Capability for April 2015**

Issue Date: 14/04/2015

Issue Time: 1510 hrs

Revision No. 12

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
	13th April 2015	1015-1800	2810	315	2495	2535	0		
		18-24'	2810		2495	2535	0		
	14th April 2015 to 30th April 2015	00-24	2880	315	2565	2535	30		

**National Load Despatch Centre  
Total Transfer Capability for April 2015**

Issue Date: 14/04/2015

Issue Time: 1510 hrs

Revision No. 12

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
<b>Import of Punjab</b>	1st April 2015 to 30th April 2015	00-24	5700	300	5400	3790	1610		
<b>Import TTC for DD &amp; DNH</b>	1st April 2015 to 30th April 2015	00-24	1200	0	1200	LTA and MTOA as per ex-pp schedule			
<b>W3 zone Injection</b>	1st April 2015 to 30th April 2015	00-17	9400	200	9200	7094	2106		
		23-24							
		17-23	9900		9700		2606		

\* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

\$ As per Simulations, predominant direction of flow is on West to North Corridor. Hence, in case injection point is in Western Region (W1,W2,W3), STOA/PX transactions from West to North on West-East-North corridor shall not be allowed as such transaction increases congestion in the West to North Corridor.

- 1) ER-SR TTC declared at Talcher Interconnector and Gazuwaka HVDC B/B seam
- 2) S1 comprises of AP and Karnataka: S2 comprises of Tamil Nadu, Kerala and Pondicherry
- 3) W3 comprises of the following regional entities :
  - a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak
  - f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPCCL, n)Vandana Vidyut

# The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/ Fuel shortage/New units being commissioned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

In case of TTC Revision due to any shutdown :

- 1) The TTC value will be revised to normal values after restoration of shutdown.
- 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.

**Limiting Constraints**

Corridor	Constraint
<b>NR-WR</b>	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.
<b>WR-NR</b>	High Loading of 400kV Singrauli-Anpara & High loading of 765 kV Agra-Gwalior (1250 MW SPS setting on each circuit of 765 kV Gwalior-Agra) and Loop flows on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda (power flowing from WR to NR on 765kV Gwalior-Agra D/C and from NR to WR on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda).
<b>NR-ER</b>	(n-1) contingency of 400 kV Saranath-Pusauli
<b>ER-NR</b>	(n-1) contingency of Kahalgaon-Banka S/C
<b>ER-W3</b>	1. n-1 of 400 kV Wardha – Parli will lead to 30 degrees angular separation between Wardha and Parli. 2. (n-1) contingency of one circuit of 400kV Parli(PG)-Sholapur(PG)
<b>WR-SR &amp; ER-SR</b>	1. n-1 of 400 kV Wardha – Parli will lead to 30 degrees angular separation between Wardha and Parli. 2. (n-1) contingency of one circuit of 400kV Parli(PG)-Sholapur(PG) 3. ER-SR TTC has been declared assuming more than 1100 MW generation at Talcher Stage-2. In case Talcher Stage-2 generation goes below 1100 MW, then the ER-SR TTC would be revised downward as constraints within ER would emerge.
<b>ER-NER</b>	(N-1) contingency of 400/132 kV, 2x200 MVA ICTs at Silchar leads to high loading on 2nd ICT.
<b>S1-S2</b>	(n-1) contingency of one circuit of 400 kV Kolar-Hosur D/C
<b>Import of DD &amp; DNH</b>	(n-1) contingency of 400/220KV 315MVA ICT at VAPI
<b>Import of Punjab</b>	(n-1) contingency of ICT at Dhuri and (n-1) contingency of 220kV Moga(PG)-Moga(PSTCL)
<b>W3 zone Injection</b>	1. n-1 of 400 kV Wardha – Parli will lead to 30 degrees angular separation between Wardha and Parli. 2. (n-1) contingency of one circuit of 400kV Parli(PG)-Sholapur(PG)

\*Primary constraints

### Simultaneous Import Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER									
NR	1st April 2015 to 30th April 2015	00-17 23-24	8500	800	7700	7588	112		
		17-23	8500		7700		112		
NER	1st April 2015 to 30th April 2015	00-17 23-24	1100	40	1060	210	850		
		17-23	920		880		670		
WR									
SR	1st April 2015 to 6th April 2015	00-05	5350	750	4600	3935	665		
		05-06'	4950		4200	3935	265		
		06-18'	4950		4200	4000	200		
		18-22	4950		4200	3935	265		
		22-24	5350		4600	3935	665		
	7th April 2015	00-05	5350	750	4600	3935	665		
		05-06'	4950		4200	3935	265		
		06-08'	4800		4050	4000	50		
		08-18'	4450		3700	4000	0		
		18-22	4450		3700	3935	0		
	8th April 2015 to 30th April 2015	00-05	5350	750	4600	3935	665		
		05-06'	4950		4200	3935	265		
		06-18'	4950		4200	4000	200		
		18-22	4950		4200	3935	265		
		22-24	5350		4600	3935	665		

### Simultaneous Export Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR*	1st April 2015 to 30th April 2015	00-06	4500	700	3800	999	2801		
		06-17'			3800	1064	2736		
		23-24			3800	999	2801		
NER	1st April 2015 to 30th April 2015	00-24	No limit is being Specified.						
WR									
SR *	1st April 2015 to 30th April 2015	00-24	No limit is being Specified.						

\* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

## Limiting Constraints

<b>NR</b>	<b>Import</b>	(n-1) contingency of Kahalgaon-Banka S/C High loading of 765 kV Agra-Gwalior (1250 MW SPS setting on each circuit of 765 kV Gwalior-Agra) and high loop flows on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda (power flowing from WR to NR on 765kV Gwalior-Agra D/C and from NR to WR on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda).
	<b>Export</b>	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak. (n-1) contingency of 400 kV Saranath-Pusauli
<b>NER</b>	<b>Import</b>	(N-1) contingency of 400/132 kV, 2x200 MVA ICTs at Silchar leads to high loading on 2nd ICT.
<b>SR</b>	<b>Import</b>	1. n-1 of 400 kV Wardha – Parli will lead to 30 degrees angular separation between Wardha and Parli. 2. (n-1) contingency of one circuit of 400kV Parli(PG)-Sholapur(PG) 3. ER-SR TTC has been declared assuming more than 1100 MW generation at Talcher Stage-2. In case Talcher Stage-2 generation goes below 1100 MW, then the ER-SR TTC would be revised downward as constraints within ER would emerge.

\*Primary constraints

**National Load Despatch Centre  
Total Transfer Capability for April 2015**

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor Affected
1	2/12/2015	Whole Month	Margin revised due to cancellation of LTA/MTOA.	NR-WR/ ER-W3
2	3/2/2015	Whole Month	STOA Margins revised due to grant of MTOA from Chattisgarh to KSEB by CTU.	W3-ER/ W3 Zone
			Revised due to commissioning of Kudankulam Unit-1, Coastal energen Unit-1 and Vallur Unit-3	S1-S2
3	3/20/2015	Whole month	Revised considering maintenance schedule of Singrauli - Rihand complex and reviewed HVDC set points.	WR-NR
			Revised considering revised thermal ratings of the lines in ER and expected flows on ER-NR corridor	ER-NR
			Revised considering the present Maharashtra Demand pattern and the commissioning of 765kV Pune-Sholapur S/C.	WR-SR
4	3/31/2015	Whole month	STOA margin revised due to commissioning of Sasan Unit-6	WR-NR
			Revised considering the revised thermal ratings of the lines in ER and network topology changes in NER.	ER-NER
5	4/4/2015	04.04.2015 - 06.04.2015	Revised due to NCTPS Unit Outage.	S1-S2
		07.04.2015 - 30.4.2015	Revised due to 765kV level Charging of Kurnool - Thiruvallam D/c and LGBR Changes.	
6	4/6/2015	4/7/2015	Revised due to Shutdown of HVDC Bhadrawati Block-1 and 400 kV 400kV Ramagundam-Bhadrawati-Ckt-1.	WR-SR
7	4/8/2015	4/8/2015	Revised due to outage of Vallur unit 1	S1-S2
		4/9/2015	Revised due to outage of Vallur unit 1 and shutdown of 220 kV Kadakola - Kaniyampetta	
		10-04-2015 - 30-04-2015	Revised after a corrected calculation in the simulation	
8	4/9/2015	4/9/2015	Revised due to revival of Vallur Unit-1	S1-S2
9	4/13/2015	13-04-015	Revised due to shutdown of 400 kV Nellore - Sriperumbudur S/C	S1-S2
10	4/13/2015	4/13/2015	Revised due to extension of shutdown of 400 kV Nellore - Sriperumbudur S/C	S1-S2
11	4/13/2015	4/13/2015	Revised due to extension of shutdown of 400 kV Nellore - Sriperumbudur S/C	S1-S2
12	4/14/2015	4/15/2015	Revised due to shutdown 400 KV Sholapur(PG) Bus-2	WR-SR

## ASSUMPTIONS IN BASECASE

Month : Apr '15

S.No.	Name of State/Area	Load		Generation	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
<b>I</b>	<b>NORTHERN REGION</b>				
1	Punjab	5409	4445	3101	2272
2	Haryana	5737	4159	1726	1522
3	Rajasthan	7500	5646	5073	4432
4	Delhi	4025	2614	1009	650
5	Uttar Pradesh	11849	12777	5434	5454
6	Jammu & Kashmir	2100	1779	650	588
7	Uttarakhand	1344	1113	480	343
8	Himachal Pradesh	1293	927	530	423
9	Chandigarh	186	114	0	0
10	ISGS/IPPs	0	0	15905	12209
	<b>Total NR</b>	<b>39443</b>	<b>33574</b>	<b>33908</b>	<b>27893</b>
<b>II</b>	<b>EASTERN REGION</b>				
1	West Bengal	7200	5800	5000	4000
2	Jharkhand	1100	850	470	350
3	Orissa	3800	3100	2900	2150
4	Bihar	2550	2100	110	0
5	Damodar Valley Corporation	2650	2200	3300	2750
6	Sikkim	95	60	-	-
7	Bhutan	-	-	235	175
8	ISGS/IPPs			9520	8395
	<b>Total ER</b>	<b>17395</b>	<b>14110</b>	<b>21535</b>	<b>17820</b>
<b>III</b>	<b>WESTERN REGION</b>				
1	Chattisgarh	3486	3181	1610	1473
2	Madhya Pradesh	7270	5274	3570	1181
3	Maharashtra	19386	15678	15142	10934
4	Gujarat	13740	9287	9985	5532
5	Goa	410	340	0	0
6	Daman and Diu	253	261	0	0
7	Dadra and Nagar Haveli	588	626	0	0
8	ISGS/IPPs	0	0	20446	20446
	<b>Total WR</b>	<b>45133</b>	<b>34647</b>	<b>50753</b>	<b>39566</b>

## ASSUMPTIONS IN BASECASE

Month : Apr '15

S.No.	Name of State/Area	Load		Generation	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
<b>IV</b>	<b>SOUTHERN REGION</b>				
1	Telangana	5832	5116	2399	2197
2	Andhra Pradesh	5307	4653	5314	4759
3	Tamil Nadu	10840	9969	6783	5823
4	Karnataka	7890	6637	6897	4860
5	Kerala	3341	2427	2082	1081
6	Pondy	340	245		
7	Goa	89	89		
8	ISGS/IPPs			7730	7730
	<b>Total SR</b>	<b>33639</b>	<b>29136</b>	<b>31205</b>	<b>26450</b>
<b>V</b>	<b>NORTH-EASTERN REGION</b>				
1	Arunachal Pradesh	69	31	0	0
2	Assam	749	566	225	160
3	Manipur	68	40	0	0
4	Meghalaya	201	106	104	44
5	Mizoram	51	31	4	3
6	Nagaland	63	53	10	6
7	Tripura	228	161	104	104
8	ISGS/IPPs			856	578
	<b>Total NER</b>	<b>1429</b>	<b>988</b>	<b>1303</b>	<b>895</b>
	<b>Total All India</b>	<b>137039</b>	<b>112455</b>	<b>138704</b>	<b>112624</b>