

National Load Despatch Centre
Total Transfer Capability for April 2017

Issue Date: 3/2/2016

Issue Time: 1200 hrs

Revision No. 1

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments		
NR-WR *	1st Apr 2017 to 30th Apr 2017	00-06	2500	500	2000	55	1945				
		06-18									
		18-24									
WR-NR*	1st Apr 2017 to 30th Apr 2017	00-24	7200	500	6700	6850	0				
NR-ER*	1st Apr 2017 to 30th Apr 2017	00-06	2000	200	1800	193	1607				
		06-18'	2000		1800	303	1497				
		18-24	2000		1800	193	1607				
ER-NR*	1st Apr 2017 to 30th Apr 2017	00-24	4200	300	3900	2931	969				
W3-ER	1st Apr 2017 to 30th Apr 2017	00-24	No limit is being specified.								
ER-W3	1st Apr 2017 to 30th Apr 2017	00-24	No limit is being specified.								
WR-SR	1st Apr 2017 to 30th Apr 2017	00-05	4000	750	3250	3384	0				
		05-22	4000		3250		0				
		22-24	4000		3250		0				
SR-WR *	1st Apr 2017 to 30th Apr 2017	00-24	No limit is being Specified.								
ER-SR	1st Apr 2017 to 30th Apr 2017	00-06	2650	0	2650	2565	85				
		06-18'								2650	0
		18-24								2650	85
SR-ER *	1st Apr 2017 to 30th Apr 2017	00-24	No limit is being Specified.								
ER-NER	1st Apr 2017 to 30th Apr 2017	00-17	1040	45	995	225	770				
		17-23	1050		1005		780				
		23-24	1040		995		770				
NER-ER	1st Apr 2017 to 30th Apr 2017	00-17	1230	45	1185	0	1185				
		17-23	1300		1255		1255				
		23-24	1230		1185		1185				
W3 zone Injection	1st Apr 2017 to 30th Apr 2017	00-24	No limit is being specified (In case of any constraints appearing in the system, W3 zone export would be revised accordingly)								

Note: TTC/ATC of S1-S2 corridor, Import of Punjab and Import of DD & DNH is uploaded on NLDC website under Intra-Regional Section in Monthly ATC.

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

National Load Despatch Centre
Total Transfer Capability for April 2017

Issue Date: 3/2/2016

Issue Time: 1200 hrs

Revision No. 1

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
----------	------	-------------------	---------------------------------	--------------------	-------------------------------------	--	--	-------------------------------------	----------

1) S1 comprises of Telangana, AP and Karnataka; S2 comprises of Tamil Nadu, Kerala and Puducherry

2) W3 comprises of the following regional entities :

a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak
 f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPC, n)Vandana Vidyt o)RKM, p)GMR Raikheda, q)Ind Barath and any other regional entity generator in Chhattisgarh

The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/ Fuel shortage/New units being commissioned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis.

In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

In case of TTC Revision due to any shutdown :

- 1) The TTC value will be revised to normal values after restoration of shutdown.
- 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.

Limiting Constraints

Corridor	Constraint
NR-WR	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak
WR-NR	1. (n-1) Contingency of 765kV Gwalior-Agra one ckt leads to 2750 MW loading on second circuit. 2.High Loading of 400kV Singrauli-Anpara S/C.
NR-ER	(n-1) contingency of 400 kV Saranath-Pusauli
ER-NR	(n-1) contingencies of N.Ranchi - Chandawa S/C & (n-1) contingencies of 400kV MPL- Maithon S/C
WR-SR & ER-SR	00-05 hrs & 22-24 hrs: (n-1) contingency of one circuit of 765 kV Raichur - Sholapur will lead to 2750 MW loading on the other circuit. 05-22 hrs: (n-1) contingency of one circuit of 765 kV Aurangabad - Sholapur will lead to 2750 MW loading on the other circuit and 10kV voltage dip at Sholapur (PG) Low Voltage at Gazuwaka (East) Bus.
ER-NER	a. (n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa b. High loading of 220 kV Samaguri-Sonabil line(200 MW)
NER-ER	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other 400/220 kV, 315 MVA ICT at Misa
W3 zone Injection	---

Simultaneous Import Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER									
NR*	1st Apr 2017 to 30th Apr 2017	00-07	10300	800	9500	9781	0		
		07-18	10300		9500		0		
		18-23	9600		8800		0		
		23-24	10300		9500		0		
NER	1st Apr 2017 to 30th Apr 2017	00-17	1040	45	995	225	770		
		17-23	1050		1005		780		
		23-24	1040		995		770		
WR									
SR	1st Apr 2017 to 30th Apr 2017	00-05	6650	750	5900	5949	0		STOA margin revised considering Solar allocation in LTA/MTOA during non solar hours
		05-06	6650		5900	5949	0		
		06-18	6650		5900	6034	0		
		18-22	6650		5900	5949	0		
		22-24	6650		5900	5949	0		

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

* For approving STOA Bilateral transactions, margin available in Simultaneous Import of NR would be apportioned on WR-NR Corridor & ER-NR Corridor in the following ratio:
 Margin in Simultaneous import of NR = A
 WR-NR ATC = B
 ER-NR ATC = C

 Margin for WR-NR applicants = $A * B / (B+C)$
 Margin for ER-NR Applicants = $A * C / (B+C)$

Simultaneous Export Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR*	1st Apr 2017 to 30th Apr 2017	00-06	4500	700	3800	248	3552		
		06-18'			3800	368	3432		
		18-24			3800	248	3552		
NER	1st Apr 2017 to 30th Apr 2017	00-17	1230	45	1185	0	1185		
		17-23	1300		1255		1007		
		23-24	1230		1185		1185		
WR									
SR *	1st Apr 2017 to 30th Apr 2017	00-24	No limit is being Specified.						

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Limiting Constraints

NR	Import	(n-1) contingencies of N.Ranchi - Chandawa S/C & (n-1) contingencies of 400kV MPL- Maithon S/C. 1. (n-1) Contingency of 765kV Gwalior-Agra one ckt leads to 2750 MW loading on second circuit. 2.High Loading of 400kV Singrauli-Anpara S/C.
	Export	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak. (n-1) contingency of 400 kV Saranath-Pusauli
NER	Import	a. (n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa b. High loading of 220 kV Samaguri-Sonabil line(200 MW)
	Export	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other 400/220 kV, 315 MVA
SR	Import	00-05 hrs & 22-24 hrs: (n-1) contingency of one circuit of 765 kV Raichur - Sholapur will lead to 2750 MW loading on the other circuit. 05-22 hrs: (n-1) contingency of one circuit of 765 kV Aurangabad - Sholapur will lead to 2750 MW loading on the other circuit and 10kV voltage dip at Sholapur (PG) Low Voltage at Gazuwaka (East) Bus.

**National Load Despatch Centre
Total Transfer Capability for April 2017**

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor Affected
1	3/2/2017	Whole month	STOA margin revised considering Solar allocation in LTA/MTOA during non solar hours	Import of SR

ASSUMPTIONS IN BASECASE					
				Month : April'17	
S.No.	Name of State/Area	Load		Generation	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
I	NORTHERN REGION				
1	Punjab	6138	5892	2760	2789
2	Haryana	6634	4998	2470	2470
3	Rajasthan	8620	8226	6298	6298
4	Delhi	4678	4074	437	437
5	Uttar Pradesh	13735	12612	7711	7738
6	Uttarakhand	1920	1329	728	691
7	Himachal Pradesh	1342	929	379	547
8	Jammu & Kashmir	2372	1687	618	700
9	Chandigarh	232	164	0	0
10	ISGS/IPPs	175	133	17627	11556
	Total NR	45844	40044	39027	33225
II	EASTERN REGION				
1	Bihar	3680	2648	200	131
2	Jharkhand	1042	883	400	400
3	Damodar Valley Corporation	2531	2207	3741	3372
4	Orissa	4031	2991	3359	2199
5	West Bengal	7642	5394	5049	3656
6	Sikkim	89	39	0	0
7	Bhutan	245	245	842	527
8	ISGS/IPPs	563	568	9897	8843
	Total ER	19793	14946	23459	19114
III	WESTERN REGION				
1	Maharashtra	19346	14655	15124	11320
2	Gujarat	13639	12072	9171	8787
3	Madhya Pradesh	7977	7209	3825	4078
4	Chattisgarh	3532	3572	2830	2020
5	Daman and Diu	303	258	0	0
6	Dadra and Nagar Haveli	787	692	0	0
7	Goa-WR	436	327	0	0
8	ISGS/IPPs	3139	3282	31411	27887
	Total WR	49158	42068	62360	54091

ASSUMPTIONS IN BASECASE					
				Month : April'17	
S.No.	Name of State/Area	Load		Generation	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
IV	SOUTHERN REGION				
1	Andhra Pradesh	8268	7479	7920	6664
2	Telangana	8627	7461	3853	3386
3	Karnataka	9575	8509	7352	5568
4	Tamil Nadu	14817	12625	7110	6510
5	Kerala	4200	3110	1698	650
6	Pondy	395	330	0	0
7	Goa-SR	89	89	0	0
8	ISGS/IPPs	0	0	14288	12255
	Total SR	45971	39603	42222	35033
V	NORTH-EASTERN REGION				
1	Arunachal Pradesh	110	68	0	0
2	Assam	1042	812	230	180
3	Manipur	132	74	0	0
4	Meghalaya	244	135	75	15
5	Mizoram	86	60	8	8
6	Nagaland	98	76	12	8
7	Tripura	217	135	82	77
8	ISGS/IPPs	83	60	1534	1070
	Total NER	2012	1420	1941	1358
	Total All India	162877	138219	169753	143348