

**National Load Despatch Centre
Total Transfer Capability for April 2019**

Issue Date: 12th March 2019

Issue Time: 1645 hrs

Revision No. 8

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
NR-WR*	1st April 2019 to 30th April 2019	00-06	2500	500	2000	195	1805			
		06-18				250	1750			
		18-24				195	1805			
WR-NR*	1st April 2019 to 30th April 2019	00-24	13250	500	12750	9485	3265			
			12300**		11800**	8535**	3265**			
NR-ER*	1st April 2019 to 30th April 2019	00-06	2000	200	1800	193	1607			
		06-18	2000			303	1497			
		18-24	2000			193	1607			
ER-NR*	1st April 2019 to 30th April 2019	00-24	5250	300	4950	3979	971			
W3-ER	1st April 2019 to 30th April 2019	00-24	No limit is being specified.							
ER-W3	1st April 2019 to 30th April 2019	00-24	No limit is being specified.							
WR-SR	1st April 2019 to 05th April 2019	00-05	5550	500	5050	4435	615			
		05-22	5550		5050		615			
		22-24	5550		5050		615			
	6th April 2019 to 20th April 2019	00-05	5050	500	4550	4435	115			
		05-22	5050		4550		115			
		22-24	5050		4550		115			
	21st April 2019 to 30th April 2019	00-05	5550	500	5050	4435	615			
		05-22	5550		5050		615			
		22-24	5550		5050		615			
SR-WR *	1st April 2019 to 30th April 2019	00-24	No limit is being Specified.							
ER-SR	1st April 2019 to 05th April 2019	00-06	4950	250	4700	2762	1938			
		06-18				2847	1853			
		18-24				2762	1938			
	06th April 2019	00-06	4950	250	4700	2762	1938			
		06-0830	4950		4700	2847	1853			
		0830-18	4650		4400	2847	1553			
		18-24	4650		4400	2762	1638			
	07th April 2019	00-06	4950	250	4700	2762	1938			
		06-0830	4950		4700	2847	1853			
		0830-18	4650		4400	2847	1553			
		18-24	4650		4400	2762	1638			
	08th April 2019 to 13th April 2019	00-06	4950	250	4700	2762	1938			
		06-18				2847	1853			
		18-24				2762	1938			
	14th April 2019	00-06	4950	250	4700	2762	1938		Revised due to day time shutdown of 400kV Rengali-Indravati line	
		06-730	4950		4700	2847	1853			
		730-18	4650		4400	2847	1553	-300		
		18-24	4650		4400	2762	1638	-300		
	15th April 2019 to 30th April 2019	00-06	4950	250	4700	2762	1938			
		06-18				2847	1853			
		18-24				2762	1938			
	SR-ER *	1st April 2019 to 30th April 2019	00-24	No limit is being Specified.						

**National Load Despatch Centre
Total Transfer Capability for April 2019**

Issue Date: 12th March 2019

Issue Time: 1645 hrs

Revision No. 8

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER-NER	1st April 2019	00-08'	1340	45	1295	265	1030		
		08-17'	1180		1135		870		
		17-23	1150		1105		840		
		23-24	1180		1135		870		
	2nd April 2019	00-17	1180	45	1135	265	870		
		17-23	1150		1105		840		
		23-24	1180		1135		870		
ER-NER	3rd April 2019 to 05th April 2019	00-17	1340	45	1295	265	1030		
		17-23	1410		1365		1100		
		23-24	1340		1295		1030		
	06th April 2019	00-08'	1340	45	1295	326	969		
		08-17'	1260		1215		889		
		17-23	1340		1295		969		
		23-24	1260		1215		889		
	07th April 2019 to 10th April 2019	00-08'	1340	45	1295	326	969		
		08-17'	910		865		539		
		17-23	1070		1025		699		
		23-24	910		865		539		
	11th April 2019	00-17	1340	45	1295	326	969		
		17-23	1410		1365		1039		
		23-24	1340		1295		969		
	12th April 2019 to 13th April 2019	00-08'	1340	45	1295	326	969		
		08-17'	910		865		539		
		17-23	1070		1025		699		
		23-24	910		865		539		
	14th April 2019	00-08'	1340	45	1295	326	969		
		08-17'	1340		1295		969	430	
		17-23	1410		1365		1039	340	
		23-24	1340		1295		969	430	
	15th April 2019 to 30th April 2019	00-17	1340	45	1295	326	969		
		17-23	1410		1365		1039		
		23-24	1340		1295		969		
	NER-ER	1st April 2019	00-08'	2260	45	2215	0	2215	
			08-17'	1070		1025		1025	
			17-23	1100		1055		1055	
23-24			1070	1025		1025			
2nd April 2019		00-17	1070	45	1025	0	1025		
		17-23	1100		1055		1055		
		23-24	1070		1025		1025		
3rd April 2019 to 05th April 2019		00-17	2260	45	2215	0	2215		
		17-23	2310		2265		2265		
		23-24	2260		2215		2215		
06th April 2019		00-08'	2260	45	2215	0	2215		
		08-17'	2060		2015		2015		
		17-23	2090		2045		2045		
		23-24	2060		2015		2015		
07th April 2019 to 10th April 2019		00-08'	2260	45	2215	0	2215		
		08-17'	2060		2015		2015		
		17-23	2030		1985		1985		
		23-24	2060		2015		2015		
11th April 2019		00-17	2260	45	2215	0	2215		
		17-23	2310		2265		2265		
		23-24	2260		2215		2215		
12th April 2019 to 13th April 2019		00-08'	2260	45	2215	0	2215		
		08-17'	2060		2015		2015		
		17-23	2030		1985		1985		
		23-24	2060		2015		2015		

**National Load Despatch Centre
Total Transfer Capability for April 2019**

Issue Date: 12th March 2019

Issue Time: 1645 hrs

Revision No. 8

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NER-ER	14th April 2019	00-08'	2260	45	2215	0	2215		Revised due to rescheduling of shutdown of 400kV Misa-Balipara-1 to 16.04.19
		08-17'	2260		2215		200		
		17-23	2310		2265		280		
		23-24	2260		2215		200		
	15th April 2019 to 30th April 2019	00-17	2260	45	2215	0	2215		
		17-23	2310		2265				
		23-24	2260		2215				
W3 zone Injection	1st April 2019 to 30th April 2019	00-24	No limit is being specified (In case of any constraints appearing in the system, W3 zone export would be revised accordingly)						

Note: TTC/ATC of S1-(S2&S3) corridor, Import of S3(Kerala), Import of Punjab and Import of DD & DNH is uploaded on NLDC website under Intra-Regional Section in Monthly ATC.

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

**Considering 400 kV Rihand stage-III - Vindhyaachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.

1) S1 comprises of Telangana, AP and Karnataka; S2 comprises of Tamil Nadu and Puducherry; S3 comprises Kerala

2) W3 comprises of the following regional entities :

a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak

f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPCCL, n)Vandana Vidyut o)RKM, p)GMR Raikheda, q)Ind Barath and any other regional entity generator in Chhattisgarh

The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/ Fuel shortage/New units being commissioned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis.

In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

In case of TTC Revision due to any shutdown :

1) The TTC value will be revised to normal values after restoration of shutdown.

2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.

Simultaneous Import Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER									
NR	1st April 2019 to 30th April 2019	00-06	17650	800	16850	13464	3386		
			16700**		15900**		3386**		
		06-17	18900		18100		4636		
			17950**		17150**		4636**		
	17-24	17000	16200	2736					
		16050**	15250**	2736**					
NER	1st April 2019	00-08'	1340	45	1295	265	1030		
		08-17'	1180		1135		870		
		17-23	1150		1105		840		
		23-24	1180		1135		870		
	2nd April 2019	00-17	1180	45	1135	265	870		
		17-23	1150		1105		840		
		23-24	1180		1135		870		
	06th April 2019	00-08'	1340	45	1295	326	969		
		08-17'	1260		1215		889		
		17-23	1340		1295		969		
		23-24	1260		1215		889		
	07th April 2019 to 10th April 2019	00-08'	1340	45	1295	326	969		
		08-17'	910		865		539		
		17-23	1070		1025		699		
		23-24	910		865		539		
	11th April 2019	00-17	1340	45	1295	326	969		
17-23		1410	1365		1039				
23-24		1340	1295		969				
NER	12th April 2019 to 13th April 2019	00-08'	1340	45	1295	326	969		
		08-17'	910		865		539		
		17-23	1070		1025		699		
		23-24	910		865		539		
	14th April 2019	00-08'	1340	45	1295	326	969		
		08-17'	1340		1295		969	430	
		17-23	1410		1365		1039	340	
		23-24	1340		1295		969	430	
	15th April 2019 to 30th April 2019	00-17	1340	45	1295	326	969		
		17-23	1410		1365		1039		
		23-24	1340		1295		969		
	WR								
SR	1st April 2019 to 05th April 2019	00-06	10500	750	9750	7197	2553		
		06-18	10500		9750	7282	2468		
		18-24	10500		9750	7197	2553		
	06th April 2019	00-06	10000	750	9250	7197	2053		
		06-0830	10000		9250	7282	1968		
		0830-18	9700		8950	7282	1668		
		18-24	9700		8950	7197	1753		
	07th April 2019	00-06	10000	750	9250	7197	2053		
		06-0830	10000		9250	7282	1968		
		0830-18	9700		8950	7282	1668		
		18-24	9700		8950	7197	1753		
	08th April 2019 to 13th April 2019	00-06	10000	750	9250	7197	2053		
06-18		10000	9250		7282	1968			
18-24		10000	9250		7197	2053			
14th April 2019	00-06	10000	750	9250	7197	2053			
	06-730	10000		9250	7282	1968			
	730-18	9700		8950	7282	1668	-300		

Revised due to day time shutdown of 400kV Rengali-Indravati line

SR		18-24	9700		8950	7197	1753	-300	
	15th April 2019 to 20th April 2019	00-06	10000	750	9250	7197	2053		
		06-18	10000		9250	7282	1968		
		18-24	10000		9250	7197	2053		
	21st April 2019 to 30th April 2019	00-06	10500	750	9750	7197	2553		
		06-18	10500		9750	7282	2468		
		18-24	10500		9750	7197	2553		

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

**Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.

* For approving STOA Bilateral transactions, margin available in Simultaneous Import of NR would be apportioned on WR-NR Corridor & ER-NR Corridor in the following ratio:

Margin in Simultaneous import of NR = A

WR-NR ATC =B

ER-NR ATC = C

Margin for WR-NR applicants = $A * B/(B+C)$

Margin for ER-NR Applicants = $A * C/(B+C)$

Simultaneous Export Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR*	1st April 2019 to 30th April 2019	00-06	4500	700	3800	388	3412		
		06-18			3800	553	3247		
		18-24			3800	388	3412		
NER	1st April 2019	00-08'	2260	45	2215	0	2215		
		08-17'	1070		1025		1025		
		17-23	1100		1055		1055		
		23-24	1070		1025		1025		
	2nd April 2019	00-17	1070	45	1025	0	1025		
		17-23	1100		1055		1055		
		23-24	1070		1025		1025		
	06th April 2019	00-08'	2260	45	2215	0	2215		
		08-17'	2060		2015		2015		
		17-23	2090		2045		2045		
		23-24	2060		2015		2015		
	07th April 2019 to 10th April 2019	00-08'	2260	45	2215	0	2215		
		08-17'	2060		2015		2015		
		17-23	2030		1985		1985		
		23-24	2060		2015		2015		
	11th April 2019	00-17	2260	45	2215	0	2215		
		17-23	2310		2265		2265		
		23-24	2260		2215		2215		
	12th April 2019 to 13th April 2019	00-08'	2260	45	2215	0	2215		
		08-17'	2060		2015		2015		
		17-23	2030		1985		1985		
		23-24	2060		2015		2015		
	14th April 2019	00-08'	2260	45	2215	0	2215		Revised due to rescheduling of shutdown of 400kV Misa-Balipara-1 to 16.04.19
		08-17'	2260		2215		2215	200	
17-23		2310	2265		2265		280		
23-24		2260	2215		2215		200		
15th April 2019 to 30th April 2019	00-17	2260	45	2215	0	2215			
	17-23	2310		2265		2265			
	23-24	2260		2215		2215			
WR									
SR *	1st April 2019 to 30th April 2019	00-24	No limit is being Specified.						

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Limiting Constraints (Corridor wise)

Corridor	Constraint	Applicable Revisions
NR-WR	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak	Rev-0 to 8
WR-NR	(n-1) Contingency of 765kV Aligarh-Jhatikara leads to 2500 MW loading on 765kV Aligarh-Greater Noida.	Rev-0 to 1
	RVO operation of HVDC Champa Kurukshetra Poles	Rev-0 to 1
	Reversal of BNC-Agra pole towards BNC & blocking of APD-Agra pole due to lean hydro period in NER	Rev-2 to 8
	n-1 contingency of 2x1500 MVA, 765/400 kV ICTs at Agra (PG) will lead to overloading of the second ICT	Rev-0 to 8
NR-ER	(n-1) contingency of 400 kV Saranath-Pusauli	Rev-0 to 8
ER-NR	1. N-1 contingencies of 400 kv Mejia-Maithon A S/c 2. N-1 contingencies of 400 kv Kahalgaon-Banka S/c 3. N-1 contingencies of 400kV MPL- Maithon S/C	Rev-0 to 8
WR-SR and ER-SR	n-1 contingency of 2x315 MVA, 400/220 kV ICTs at Mardam will lead to overloading of the second ICT	Rev-0 to 8
	n-1 contingency of 2x1500 MVA, 765/400 kV ICTs at Vemagiri (PG) will lead to overloading of the second ICT	Rev-0 to 5,7
	Low Voltage at Gazuwaka (East) Bus.	Rev-0 to 8
ER-NER	a. (n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa b. High loading of 220 kV Balipara-Sonabil line(200 MW)	Rev-0 to 4
	a) N-1 contingency of either ckt of 400 kV Bongaigaon -New Siliguri line b) High Loading of 220 kV Salakati - Alipurduar D/C (200 MW)	Rev-5-6
	a) N-1 contingency of 400/220 kV, 500 MVA ICT at Misa High Loading of 220 kV Balipara- Sonabil (200 MW)	b) Rev-7-8
	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other ICT at Misa	Rev-0 to 4
NER-ER	a) N-1 contingency of either ckt of 400 kV Bongaigaon -New Siliguri line b) High Loading of 220 kV Salakati - Alipurduar D/C (200 MW)	Rev-5-6
	a) N-1 contingency of 400/220 kV, 500 MVA ICT at Misa High Loading of of 400/220 kV, 315 MVA ICT at Misa	b) Rev-7-8
	a) N-1 contingency of 400 kV Balipara - Misa II Line High Loading of 220 kV Balipara- Sonabil (200 MW)	b) Rev-7-8
	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other ICT at Misa	Rev-0 to 4
	a) N-1 contingency of either ckt of 400 kV Bongaigaon -New Siliguri line b) High Loading of 220 kV Salakati - Alipurduar D/C (200 MW)	Rev-5-6
W3 zone Injection	---	Rev-0 to 8

Limiting Constraints (Simultaneous)

		Applicable Revisions	
NR	Import	1. N-1 contingencies of 400 kV Mejia-Maithon A S/c 2. N-1 contingencies of 400 kV Kahalgaon-Banka S/c 3. N-1 contingencies of 400kV MPL- Maithon S/c	Rev-0 to 8
		(n-1) Contingency of 765kV Aligarh-Jhatikara leads to 2500 MW loading on 765kV Aligarh-Greater Noida.	Rev-0 to 1
		RVO operation of HVDC Champa Kurukshetra Poles	Rev-0 to 1
		Reversal of BNC-Agra pole towards BNC & blocking of APD-Agra pole due to lean hydro period in NER	Rev-2 to 8
	Export	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220 kV Badod-Modak. (n-1) contingency of 400 kV Saranath-Pusauli	Rev-0 to 8
NER	Import	a. (n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa b. High loading of 220 kV Balipara-Sonabil line (200 MW)	Rev-0 to 4
		a) N-1 contingency of either ckt of 400 kV Bongaigaon -New Siliguri line b) High Loading of 220 kV Salakati - Alipurduar D/C (200 MW)	Rev-5-6
		a) N-1 contingency of 400/220 kV, 500 MVA ICT at Misa b) High Loading of 220 kV Balipara- Sonabil (200 MW)	Rev-7-8
		(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other ICT at Misa	Rev-0 to 4
	Export	a) N-1 contingency of either ckt of 400 kV Bongaigaon -New Siliguri line b) High Loading of 220 kV Salakati - Alipurduar D/C (200 MW)	Rev-5-6
		a) N-1 contingency of 400/220 kV, 500 MVA ICT at Misa High Loading of of 400/220 kV, 315 MVA ICT at Misa	b) Rev-7-8
		a) N-1 contingency of 400 kV Balipara - Misa II Line b) High Loading of 220 kV Balipara- Sonabil (200 MW)	b) Rev-7-8
		(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other ICT at Misa	Rev-0 to 4
SR	Import	n-1 contingency of 2x315 MVA, 400/220 kV ICTs at Mardam will lead to overloading of the second ICT	Rev-0 to 8
		n-1 contingency of 2x1500 MVA, 765/400 kV ICTs at Vemagiri (PG) will lead to overloading of the second ICT	Rev-0 to 5,7
		Low Voltage at Gazuwaka (East) Bus.	Rev-0 to 8

**National Load Despatch Centre
Total Transfer Capability for April 2019**

Revision No	Date of Revision	Period of Revision	Reason for Revision/Comment	Corridor Affected
1	4th Jan 2019	Whole Month	Revised STOA margins due to: (i) Additional 20 MW LTA to Delhi from Ostro Kutch Wind Power Ltd (OKWPL) (ii) Operationalization of 108 MW MTOA from SKS Power Gen Ltd to Noida Power Company	WR-NR/Import of NR
			Revised TTC due to: (i) Change in load generation balance (ii) Commissioning of circuit 3 & 4 of 765 kV Angul Jharsuguda (iii) Prevailing pattern of load in downstream of 400/220 kV Maradam ICTs	ER-SR/WR-SR/Import of SR
2	28th Jan 2019	Whole Month	Revised TTC due to normalization of Champa Kurukshetra bipole	WR-NR/Import of NR
			Change in pattern of inter-regional flow towards NR	Import of NR
			Revised STOA margin due to termination of 100 MW MTOA from LANCO Anpara power limited to TANGEDCO	WR-SR/Import of SR
3	07th Mar 2019	Whole Month	Operationalization of 87 MW LTA from Teesta - III HEP to Rajasthan	ER-NR/Import of NR
			Operationalization of 50 MW LTA from Orange Sirong Wind Power Limited (OSWPPL) to Haryana	WR-NR/Import of NR
4	28th Mar 2019	Whole Month	Operationalization of the following LTAs:- a) Tuticorin - Mytrah Power to UPPCL, Uttar Pradesh - 51.84 MW	WR-NR/Import of NR
			Allocation of 40 MW power from Mouda Stg-II to Assam	ER-NER/Import of NER
5	29th Mar 2019	1st April to 02nd April 2019	Revised due to Shutdown of 400 kV Bongaigaon - Alipurduar D/C and due to change in load - generation balance and charging of new elements (400/220/33 kV 500 MVA ICT-1 replaced 400/220/33 kV, 315 MVA ICT-1 at Misa, 400/220/33 kV, 315 MVA ICT-2 at Bongaigaon , 400/132 kV, 3x40 MVA ICT at Kameng)	ER-NER/NER-ER/Import and Export of NER
		3rd April to 30th April 2019	Revised due to change in load - generation balance and charging of new elements (400/220/33 kV 500 MVA ICT-1 replaced 400/220/33 kV, 315 MVA ICT-1 at Misa, 400/220/33 kV, 315 MVA ICT-2 at Bongaigaon , 400/132 kV, 3x40 MVA ICT at Kameng)	ER-NER/NER-ER/Import and Export of NER
6	04th April 2019	06th April 2019 to 07th April 2019	Revised due to day time shutdown of 400kV Rengali-Indravati line	ER-SR/Import of SR
7	05th April 2019	06th April 2019 to 20th April 2019	Revised due Forced outage of Pole-2 at Bhadravathi	WR-SR/Import of SR
		06th April 2019	Revised due to shutdown of 400 kV Bongaigaon - Azara Line and Revised STOA margin due to operationalisation of following LTA : a). Assam from Tuticorin Mytrah (Wind Power Plant) : 25.74 MW b) Assam from NVVN (Solar Power Plant): 5 MW c) LTA of Arunachal Pradesh from Unchahar (Thermal Power Plant): 30 MW	ER-NER/NER-ER/Import and Export of NER

7	05th April 2019	07th April 2019 to 10th April 2019 and 12th April to 14th April 2019	Revised due to shutdown of 400kV Misa-Balipara-I and Revised STOA margin due to operationalisation of following LTA : a). Assam from Tuticorin Mytrah (Wind Power Plant) : 25.74 MW b) Assam from NVVN (Solar Power Plant): 5 MW c) LTA of Arunachal Pradesh from Unchahar (Thermal Power Plant): 30 MW	ER-NER/NER-ER/Import and Export of NER
		15th April 2019 to 30th April 2019	Revised STOA margin due to operationalisation of following LTA : a). Assam from Tuticorin Mytrah (Wind Power Plant) : 25.74 MW b) Assam from NVVN (Solar Power Plant): 5 MW c) LTA of Arunachal Pradesh from Unchahar (Thermal Power Plant): 30 MW	ER-NER/Import of NER
8	12th April 2019	14th April 2019	Revised due to day time shutdown of 400kV Rengali-Indravati line	ER-SR/Import of SR
			Revised due to rescheduling of shutdown of 400kV Misa-Balipara-1 to 16.04.19	ER-NER/NER-ER/Import and Export of NER

ASSUMPTIONS IN BASECASE					
				Month : April'19	
S.No.	Name of State/Area	Load		Generation	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
I	NORTHERN REGION				
1	Punjab	7290	6249	3543	3588
2	Haryana	7873	7139	2583	2583
3	Rajasthan	10474	9250	7473	7473
4	Delhi	5387	4170	612	612
5	Uttar Pradesh	14130	11663	6246	6367
6	Uttarakhand	1784	1304	816	544
7	Himachal Pradesh	1459	970	173	131
8	Jammu & Kashmir	2387	1613	771	761
9	Chandigarh	243	144	0	0
10	ISGS/IPPs	30	29	18558	10652
	Total NR	51057	42529	40775	32711
II	EASTERN REGION				
1	Bihar	4534	3290	352	285
2	Jharkhand	994	702	354	229
3	Damodar Valley Corporation	3022	2497	5147	3743
4	Orissa	4128	3314	2371	2471
5	West Bengal	6921	4534	5279	3958
6	Sikkim	107	94	0	0
7	Bhutan	200	198	414	336
8	ISGS/IPPs	626	627	11872	8472
	Total ER	20531	15257	25789	19494
III	WESTERN REGION				
1	Maharashtra	20141	17026	16345	14514
2	Gujarat	15838	13877	10402	10095
3	Madhya Pradesh	10831	7721	5491	4520
4	Chattisgarh	4459	3483	2797	2985
5	Daman and Diu	349	297	0	0
6	Dadra and Nagar Haveli	886	722	0	0
7	Goa-WR	625	439	0	0
8	ISGS/IPPs	4956	4343	40029	30899
	Total WR	58085	47909	75062	63015

S.No.	Name of State/Area	Load		Generation	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
IV	SOUTHERN REGION				
1	Andhra Pradesh	8469	7401	6235	4544
2	Telangana	9553	8303	4964	4464
3	Karnataka	9353	6123	7638	5619
4	Tamil Nadu	15346	13709	8538	7138
5	Kerala	4133	2777	1574	716
6	Pondy	327	321	0	0
7	Goa-SR	73	72	0	0
8	ISGS/IPPs	0	0	13098	11619
	Total SR	47254	38706	42049	34101
V	NORTH-EASTERN REGION				
1	Arunachal Pradesh	66	54	0	0
2	Assam	879	806	195	142
3	Manipur	119	87	0	0
4	Meghalaya	284	213	162	96
5	Mizoram	99	59	64	8
6	Nagaland	81	74	12	6
7	Tripura	209	149	74	74
8	ISGS/IPPs	153	83	1326	1151
	Total NER	1890	1525	1833	1477
	Total All India	179317	146360	185946	151169