

National Load Despatch Centre										
Total Transfer Capability for Apr 2023										
Issue Date:Apr 10 2023					Issue Time:18:00:11			Revision No :9		
Corridor	Date	Time Period(hrs)	Total Transfer Capability(TTC)	Reliability Margin(RM)	Available Transfer Capability(ATC)	Long Term Access(LTA)/Medium Term Open Access(MTOA)	Margin Available For Short Term Open Access(STOA)	Chnages w.r.t. Previous Revision		
ER-NER	01 Apr to 05 Apr	00:00 to 17:00	1720	60	1660	455	1205	0		
		17:00 to 21:00	1500	60	1440	455	985	0		
		21:00 to 24:00	1720	60	1660	455	1205	0		
	06 Apr to 06 Apr	00:00 to 07:00	1720	60	1660	455	1205	0		
		07:00 to 17:00	1530	60	1470	455	1015	0		
		17:00 to 21:00	1310	60	1250	455	795	0		
	07 Apr to 30 Apr	21:00 to 24:00	1530	60	1470	455	1015	0		
		00:00 to 17:00	1720	60	1660	455	1205	0		
		17:00 to 21:00	1500	60	1440	455	985	0		
	21:00 to 24:00	1720	60	1660	455	1205	0			
	01 Apr to 01 Apr	00:00 to 24:00	8000	400	7600	4969	2631	0		
		02 Apr to 03 Apr	00:00 to 08:00	8000	400	7600	4969	2631	0	
08:00 to 24:00			7800	400	7400	4969	2431	0		
ER-NR	04 Apr to 30 Apr	00:00 to 24:00	8000	400	7600	4969	2631	0		
	01 Apr to 30 Apr	00:00 to 06:00	5700	350	5350	3250	2100	0		
		06:00 to 18:00	5700	350	5350	3316	2034	0		
18:00 to 24:00		5700	350	5350	3250	2100	0			
ER-W3	01 Apr to 30 Apr	00:00 to 24:00							No limit is being specified.	
NER-ER	01 Apr to 05 Apr	00:00 to 17:00	2980	60	2920	258	2662	0		
		17:00 to 21:00	2950	60	2890	258	2632	0		
		21:00 to 24:00	2980	60	2920	258	2662	0		
	06 Apr to 06 Apr	00:00 to 07:00	2980	60	2920	258	2662	0		
		07:00 to 17:00	2700	60	2640	258	2382	0		
		17:00 to 21:00	2650	60	2590	258	2332	0		
	07 Apr to 30 Apr	21:00 to 24:00	2700	60	2640	258	2382	0		
		00:00 to 17:00	2980	60	2920	258	2662	0		
		17:00 to 21:00	2950	60	2890	258	2632	0		
	NR-ER	21:00 to 24:00	2980	60	2920	258	2662	0		
		01 Apr to 30 Apr	00:00 to 06:00	2000	200	1800	125	1675	0	
			06:00 to 18:00	2000	200	1800	1990	0	0	
18:00 to 24:00	2000		200	1800	125	1675	0			
NR-WR	01 Apr to 10 Apr	00:00 to 06:00	4000	500	3500	1232	2268	0		
		06:00 to 18:00	4000	500	3500	5035	0	0		
		18:00 to 24:00	4000	500	3500	1232	2268	0		
	11 Apr to 11 Apr	00:00 to 06:00	4000	500	3500	1232	2268	0		
		06:00 to 08:00	4000	500	3500	5035	0	0		
		08:00 to 18:00	3750	500	3250	5035	0	0		
	12 Apr	18:00 to 24:00	3750	500	3250	1232	2018	0		
		00:00 to 06:00	4000	500	3500	1567	1933	0	Revised STOA Margin due to, i) 50 MW increase in LTA quantum from APMPL_BHDL to MP ii) New approv	

Corridor	Date	Time Period(hrs)	Total Transfer Capability(TTC)	Reliability Margin(RM)	Available Transfer Capability(ATC)	Long Term Access(LTA)/Medium Term Open Access(MTOA)	Margin Available For Short Term Open Access(STOA)	Chnages w.r.t. Previous Revision		
SR-ER	to 12 Apr	06:00 to 08:00	4000	500	3500	5477	0	0		
	13 Apr to 30 Apr	08:00 to 18:00	3750	500	3250	5477	0	-250	TTC/AT	
		18:00 to 24:00	3750	500	3250	1567	1683	-250		
	01 Apr to 30 Apr	00:00 to 06:00	4000	500	3500	1567	1933	0		
		06:00 to 18:00	4000	500	3500	5477	0	0		
	01 Apr to 30 Apr	18:00 to 24:00	4000	500	3500	1567	1933	0		
		00:00 to 24:00							No limit is being specified.	
	SR-WR	01 Apr to 30 Apr	00:00 to 06:00	6700	650	6050	852	5198	0	
			06:00 to 18:00	6700	650	6050	1052	4998	0	
			18:00 to 24:00	6700	650	6050	852	5198	0	
W3 Injection	01 Apr to 30 Apr	00:00 to 24:00	NA	NA		NA		0		
									No limit is being specified.	
W3-ER	01 Apr to 30 Apr	00:00 to 24:00							No limit is being specified.	
WR-NR	01 Apr to 01 Apr	00:00 to 06:00	17800	1000	16800	11135	5665	0		
		06:00 to 18:00	17800	1000	16800	11434	5366	0		
WR-NR	01 Apr to 01 Apr	18:00 to 24:00	17800	1000	16800	11135	5665	0		
		00:00 to 06:00	17800	1000	16800	11135	5665	0		
WR-NR	02 Apr to 03 Apr	06:00 to 08:00	17800	1000	16800	11434	5366	0		
		08:00 to 18:00	17100	1000	16100	11434	4666	0		
WR-SR	04 Apr to 30 Apr	18:00 to 24:00	17100	1000	16100	11135	4965	0		
		00:00 to 06:00	17800	1000	16800	11135	5665	0		
	01 Apr to 30 Apr	06:00 to 18:00	17800	1000	16800	11434	5366	0		
		18:00 to 24:00	17800	1000	16800	11135	5665	0		
	01 Apr to 30 Apr	00:00 to 06:00	11600	650	10950	3611	7339	0		
		06:00 to 18:00	11600	650	10950	4573	6377	0		
		18:00 to 24:00	11600	650	10950	3611	7339	0		

- Based on the actual distribution of corridor flows, Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for short-term transactions wherever applicable.
- Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.
- S1 comprises of Telangana, AP and Karnataka; S2 comprises of Tamil Nadu and Puducherry; S3 comprises Kerala 2) W3 comprises of the following regional entities : a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) Lanco Amarkantak f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPCCL, n)Vandana Vidyut o)RKM, p)GMR Raikheda, q)Ind Barath and any other regional entity generator in Chhattisgarh
- The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/ Fuel shortage/New units being commissioned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.
- In case of TTC Revision due to any shutdown : 1) The TTC value will be revised to normal values after restoration of shutdown. 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.
- Real Time TTC/ATC revisions are uploaded on Grid-India/NLDC "News Update" (Flasher) Section

**Simultaneous Import Capability**

Corridor	Date	Time Period(hrs)	Total Transfer Capability(TTC)	Reliability Margin(RM)	Available Transfer Capability(ATC)	Long Term Access(LTA)/Medium Term Open Access(MTOA)	Margin Available For Short Term Open Access(STOA)	Chnages w.r.t. Previous Revision	Comment
ER	01 Apr to 30 Apr	00:00 to 24:00	NA	NA		NA		0	
NER	01 Apr to 05 Apr	00:00 to 17:00	1220	60	1160	455	705	0	
		17:00 to 21:00	1000	60	940	455	485	0	
		21:00 to 24:00	1220	60	1160	455	705	0	
	06 Apr to 06 Apr	00:00 to 07:00	1220	60	1160	455	705	0	
		07:00 to 17:00	1030	60	970	455	515	0	
		17:00 to 21:00	810	60	750	455	295	0	
	21:00 to 24:00	1030	60	970	455	515	0		
07 Apr to 30 Apr	00:00 to 17:00	1220	60	1160	455	705	0		
	17:00 to 21:00	1000	60	940	455	485	0		
	21:00 to 24:00	1220	60	1160	455	705	0		
NR	01 Apr to 01 Apr	00:00 to 06:00	25800	1400	24400	16104	8296	0	
		06:00 to 18:00	25800	1400	24400	16403	7997	0	
		18:00 to 24:00	25800	1400	24400	16104	8296	0	

Corridor	Date	Time Period(hrs)	Total Transfer Capability(TTC)	Reliability Margin(RM)	Available Transfer Capability(ATC)	Long Term Access(LTA)/Medium Term Open Access(MTOA)	Margin Available For Short Term Open Access(STOA)	Chnages w.r.t. Previous Revision	Comment
SR	02 Apr to 03 Apr	00:00 to 06:00	25800	1400	24400	16104	8296	0	
		06:00 to 08:00	25800	1400	24400	16403	7997	0	
		08:00 to 18:00	24900	1400	23500	16403	7097	0	
		18:00 to 24:00	24900	1400	23500	16104	7396	0	
	04 Apr to 30 Apr	00:00 to 06:00	25800	1400	24400	16104	8296	0	
		06:00 to 18:00	25800	1400	24400	16403	7997	0	
		18:00 to 24:00	25800	1400	24400	16104	8296	0	
	01 Apr to 30 Apr	00:00 to 06:00	17300	1000	16300	6862	9438	0	
		06:00 to 18:00	17300	1000	16300	7889	8411	0	
		18:00 to 24:00	17300	1000	16300	6862	9438	0	
WR	01 Apr to 30 Apr	00:00 to 24:00	NA	NA			0	0	

- Based on the actual distribution of corridor flows, Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for short-term transactions wherever applicable.
- Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.
- S1 comprises of Telangana, AP and Karnataka; S2 comprises of Tamil Nadu and Puducherry; S3 comprises Kerala 2) W3 comprises of the following regional entities : a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) Lanco Amarkantak f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPCCL, n)Vandana Vidyut o)RKM, p)GMR Raikheda, q)Ind Barath and any other regional entity generator in Chhattisgarh
- The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/ Fuel shortage/New units being commissioned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.
- In case of TTC Revision due to any shutdown : 1) The TTC value will be revised to normal values after restoration of shutdown. 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.
- Real Time TTC/ATC revisions are uploaded on Grid-India/NLDC "News Update" (Flasher) Section

**Simultaneous Export Capability**

Corridor	Date	Time Period(hrs)	Total Transfer Capability(TTC)	Reliability Margin(RM)	Available Transfer Capability(ATC)	Long Term Access(LTA)/Medium Term Open Access(MTOA)	Margin Available For Short Term Open Access(STOA)	Chnages w.r.t. Previous Revision	Comment	
ER	01 Apr to 30 Apr	00:00 to 24:00	NA	NA		NA		0		
NER	01 Apr to 05 Apr	00:00 to 17:00	3480	60	3420	258	3162	0		
		17:00 to 21:00	3450	60	3390	258	3132	0		
		21:00 to 24:00	3480	60	3420	258	3162	0		
	06 Apr to 06 Apr	00:00 to 07:00	3480	60	3420	258	3162	0		
		07:00 to 17:00	3200	60	3140	258	2882	0		
		17:00 to 21:00	3150	60	3090	258	2832	0		
		21:00 to 24:00	3200	60	3140	258	2882	0		
	07 Apr to 30 Apr	00:00 to 17:00	3480	60	3420	258	3162	0		
		17:00 to 21:00	3450	60	3390	258	3132	0		
		21:00 to 24:00	3480	60	3420	258	3162	0		
	NR	01 Apr to 10 Apr	00:00 to 06:00	4000	500	3500	1357	2143	0	
			06:00 to 18:00	4000	500	3500	7025	0	0	
18:00 to 24:00			4000	500	3500	1357	2143	0		
11 Apr to 11 Apr		00:00 to 06:00	4000	500	3500	1357	2143	0		
		06:00 to 08:00	4000	500	3500	7025	0	0		
		08:00 to 18:00	3750	500	3250	7025	0	0		
		18:00 to 24:00	3750	500	3250	1357	1893	0		
12 Apr to 12 Apr		00:00 to 06:00	4000	500	3500	1694	1806	0	Revised STOA Margin due to, i) 50 MW increase in LTA quantum from APMPL_BHDL to MP ii) New approved LTA from TPREL to TPCMSEB iii)Discontinuation of MTOA of 58 MW from RUVNL to MP iv) Reallocation of 300 MW unallocated share of NR CGSs to Gujarat	
		06:00 to 08:00	4000	500	3500	7467	0	0		
		08:00 to 18:00	3750	500	3250	7467	0	-250	TTC/ATC curtailed due to shutdown of 400kV RAPP-Shujalpur-1 Line	
		18:00 to 24:00	3750	500	3250	1694	1556	-250		
13 Apr to 30 Apr		00:00 to 06:00	4000	500	3500	1694	1806	0		
	06:00 to 18:00	4000	500	3500	7467	0	0			
	18:00 to 24:00	4000	500	3500	1694	1806	0			
SR	01 Apr to 30 Apr	00:00 to 06:00	5650	650	5000	1970	3030	0		
		06:00 to 18:00	5650	650	5000	2320	2680	0		
		18:00 to 24:00	5650	650	5000	1970	3030	0		
WR	01 Apr to 30 Apr	00:00 to 24:00	NA	NA		NA		0		

- Based on the actual distribution of corridor flows, Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for short-term transactions wherever applicable.

- Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.
- S1 comprises of Telangana, AP and Karnataka; S2 comprises of Tamil Nadu and Puducherry; S3 comprises Kerala 2) W3 comprises of the following regional entities : a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPC, n)Vandana Vidyut o)RKM, p)GMR Raikheda, q)Ind Barath and any other regional entity generator in Chhattisgarh
- The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/ Fuel shortage/New units being commissioned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.
- In case of TTC Revision due to any shutdown : 1) The TTC value will be revised to normal values after restoration of shutdown. 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.
- Real Time TTC/ATC revisions are uploaded on Grid-India/NLDC "News Update" (Flasher) Section

**Limiting Constraints**

Corridor	Constraints	Revisions
WR-NR	N-1 contingency of one ckt of 765 kV Vindhyachal-Varanasi will overload the other circuit	0-9
NR-ER	(n-1) contingency of 400 kV Saranath-Pusauli	0-9
ER-NR	Inter-regional flow pattern towards NR	0-9
WR-SR	N-1 of one ICT of 765/400 kV, 1500 MVA ICT at Nizamabad will overload the other ICT	0-9
ER-SR	Low Voltage at Gazuwaka (East) Bus.	0-9
SR-WR	a) N-1 contingency of one ckt of 400 kV Kolhapur-PG - Kolhapur-MS D/C will overload of the other ckt b) N-1 contingency of 500 MVA ICT at 400 kV Kolhapur-MS will overload the other 2x315 MVA ICTs	0-9
ER-NER	a) N-1 contingency of 400 kV Bongaigaon - Azara line b) High Loading of 220 kV Salakati - BTPS D/C	0-9
NER-ER	a) N-1 contingency of 220 kV Salakati - Alipurduar I or II b) High Loading of 220 kV Salakati - Alipurduar II or I	3-9
NR_IMPORT	N-1 contingency of one ckt of 765 kV Vindhyachal-Varanasi will overload the other circuit	0-9
NR_EXPORT	(N-1) Contingency of 400 kV Kankroli-Zerda-S/C will overload 400 kV Bhinmal-Zerda-S/C	1-9
NER_IMPORT	a) N-1 contingency of 400 kV Bongaigaon - Azara line b) High Loading of 220 kV Salakati - BTPS D/C	0-9
NER_EXPORT	a) N-1 contingency of 220 kV Salakati - Alipurduar I or II b) High Loading of 220 kV Salakati - Alipurduar II or I	3-9
SR_IMPORT	N-1 of one ICT of 765/400 kV, 1500 MVA ICT at Nizamabad will overload the other ICT Low Voltage at Gazuwaka (East) Bus	0-9
SR_EXPORT	N-1 contingency of one ckt of 400 kV Kolhapur-PG - Kolhapur-MS D/C will overload of the other ckt	0-9

**Revision Summary**

Revision	Date Of Revision	Period Of Revision	Reason for Revision/Comment
0	28 Dec		
1	28 Jan	01 Apr to 30 Apr	TTC/ATC revised due to change in LGB and network configuration
		01 Apr to 30 Apr	Revised STOA margin due to (i)operationalisation of new approved allocation of 50 MW from BARH stage-1 to Uttrakhand (ii)operationalisation of new approved allocation of 64.24 MW from Da allocation of 9.195 MW from FSTPP III to Uttrakhand (iv) operationalisation of new approved allocation of 14.266 MW from KHSTPP I to Uttrakhand (v) operationalisation of new approved all operationalisation of new approved allocation of 46.57 MW from MANGDECHU to Uttrakhand
		01 Apr to 30 Apr	Revised STOA margin due to (i)operationalisation of new approved allocation of 50 MW from BARH stage-1 to Uttrakhand (ii)operationalisation of new approved allocation of 64.24 MW from Da allocation of 9.195 MW from FSTPP III to Uttrakhand (iv) operationalisation of new approved allocation of 14.266 MW from KHSTPP I to Uttrakhand (v) operationalisation of new approved all operationalisation of new approved allocation of 46.57 MW from MANGDECHU to Uttrakhand
		01 Apr to 30 Apr	TTC/ATC revised due to change in LGB and network configuration
2	28 Feb	01 Apr to 30 Apr	Revised STOA margin due to decrease in allocation by 28.1 MW from KAHALGAON STPS STAGE II to Uttrakhand
		01 Apr to 30 Apr	Revised STOA margin due to decrease in allocation by 28.1 MW from KAHALGAON STPS STAGE II to Uttrakhand
3	28 Mar	01 Apr to 30 Apr	Revised STOA margin due to I) Discontinuation of Allocation of 100 MW from SR ISGS to Uttarakhand. II) Operationalisation of new LTA quantum of 50 MW from OEPL to UPPCL III) Operationalisat
		01 Apr to 30 Apr	Revised STOA margin due to I) Discontinuation of Allocation of 46.57 MW from MANGDECHU to Uttarakhand II) Discontinuation of Allocation of 64.24 MW from Darlipali to Uttarakhand III) Discontin IV) Discontinuation of Allocation of 50 MW from BARH stage-1 to Uttarakhand V) Discontinuation of Allocation of 14.26 MW from KAHALGAON STPS STAGE I to Uttarakhand VI) Decrease in Allocati Uttarakhand
		01 Apr to 30 Apr	Revised STOA margin due to I) Discontinuation of Allocation of 100 MW from SR ISGS to Uttarakhand. II) Operationalisation of new LTA quantum of 50 MW from OEPL to UPPCL III) Operationalisat Discontinuation of Allocation of 46.57 MW from MANGDECHU to Uttarakhand IV) Discontinuation of Allocation of 64.24 MW from Darlipali to Uttarakhand V) Discontinuation of Allocation of 9.1 Allocation of 50 MW from BARH stage-1 to Uttarakhand VII) Discontinuation of Allocation of 14.26 MW from KAHALGAON STPS STAGE I to Uttarakhand VIII) Decrease in Allocation quantum by 5
4	30 Mar	01 Apr to 30 Apr	TTC/ATC curtailed due to shutdown of 400KV-KOLHAPUR-MS-KOLHAPUR GIS-2
		01 Apr to 30 Apr	TTC/ATC revised due to change in LGB
		01 Apr to 30 Apr	TTC/ATC revised due to change in LGB
		01 Apr to 30 Apr	TTC/ATC revised due to change in LGB
		01 Apr to 30 Apr	TTC/ATC revised due to change in LGB
		01 Apr to 30 Apr	TTC/ATC curtailed due to shutdown of 400KV-KOLHAPUR-MS-KOLHAPUR GIS-2
5	31 Mar	02 Apr to 04 Apr	TTC/ATC curtailed in view of shutdown of 765 kV Jbalapur Orai Ckt 1
		02 Apr to 04 Apr	TTC/ATC curtailed in view of shutdown of 765 kV Jbalapur Orai Ckt 1
		02 Apr to 04 Apr	TTC/ATC curtailed in view of shutdown of 765 kV Jbalapur Orai Ckt 1
6	02 Apr		
7	04 Apr	06 Apr to 06 Apr	TTC/ATC curtailed due to shutdown of 400kV Mirza - Bongaigaon Line

Revision	Date Of Revision	Period Of Revision	Reason for Revision/Comment
8	09 Apr	06 Apr to 06 Apr	TTC/ATC curtailed due to shutdown of 400kV Mirza - Bongaigaon Line
		06 Apr to 06 Apr	TTC/ATC curtailed due to shutdown of 400kV Mirza - Bongaigaon Line
		06 Apr to 06 Apr	TTC/ATC curtailed due to shutdown of 400kV Mirza - Bongaigaon Line
		11 Apr to 11 Apr	TTC/ATC curtailed due to shutdown of 400kV RAPP-Shujalpur-1 Line
9	10 Apr	11 Apr to 11 Apr	TTC/ATC curtailed due to shutdown of 400kV RAPP-Shujalpur-1 Line
		12 Apr to 12 Apr	Revised STOA Margin due to, i) 50 MW increase in LTA quantum from APMPL_BHDL to MP ii) New approved LTA from TPREL to TPCMSEB iii)Discontinuation of MTOA of 58 MW from RUVNL to MP iv)
		12 Apr to 12 Apr	TTC/ATC curtailed due to shutdown of 400kV RAPP-Shujalpur-1 Line
9	10 Apr	12 Apr to 12 Apr	Revised STOA Margin due to, i) 50 MW increase in LTA quantum from APMPL_BHDL to MP ii) New approved LTA from TPREL to TPCMSEB iii)Discontinuation of MTOA of 58 MW from RUVNL to MP iv)
		12 Apr to 12 Apr	TTC/ATC curtailed due to shutdown of 400kV RAPP-Shujalpur-1 Line

BASECASE LGBR					
S.No.	Name of State/Region	Load	Generation	Month: June'23	
				Peak Load (MW)	Off Peak (MW)
NORTHERN REGION					
1	Punjab	6187	4431	4320	2467
2	Haryana	6301	2327	4633	2029
3	Rajasthan	14634	8964	8276	6149
4	Delhi	4138	530	1632	506
5	Uttar Pradesh	15439	10732	10852	7505
6	Uttarakhand	1894	383	1473	297
7	Himachal Pradesh	1707	546	1017	240
8	Jammu & Kashmir	2488	236	2157	227
9	Chandigarh	197	0	89	0
10	ISGS/IPPs	53	21207	52	9340
	Total NR	53038	49356	34501	28761
EASTERN REGION					
1	Bihar	4303	484	3220	409
2	Jharkhand	1498	436	1268	409
3	Damodar Valley Corporation	3224	5182	3002	4218
4	Odisha	5447	3217	4870	2628
5	West Bengal	5848	5542	4471	4582
6	Sikkim	103	0	55	0
7	Bhutan	57	107	56	68
8	ISGS/IPPs	748	14253	698	11518
	Total ER	21230	29221	17642	23833
WESTERN REGION					
1	Maharashtra	24497	16678	17173	12825
2	Gujarat	18565	8330	15139	8534
3	Madhya Pradesh	15672	6140	9581	4836
4	Chattisgarh	4723	2439	3510	2625
5	Daman and Diu	0	0	0	0
6	Dadra and Nagar Haveli	903	0	910	0
7	Goa-WR	538	0	427	0
8	ISGS/IPPs	5326	46483	4186	31327
	Total WR	70222	80070	50926	60147
SOUTHERN REGION					
1	Andhra Pradesh	10976	6488	7444	4721
2	Telangana	12210	7160	9955	4955
3	Karnataka	13204	7228	8407	5718
4	Tamil Nadu	16464	9475	13330	5630
5	Kerala	3474	1037	3023	583
6	Pondy	385	0	377	0
7	Goa-SR	90	0	88	0
8	ISGS/IPPs	0	19219	0	15358
	Total SR	56804	50606	42625	36964
NORTH-EASTERN REGION					
1	Arunachal Pradesh	123	7	94	7
2	Assam	1193	289	1068	292
3	Manipur	188	0	118	0
4	Meghalaya	367	100	288	24
5	Mizoram	92	33	63	54
6	Nagaland	160	18	162	17
7	Tripura	214	164	229	159
8	ISGS/IPPs	0	2248	0	2153

	Total NER	2338	2022	2859	2707
	Total All India	203632	147716	212112	152412