

National Load Despatch Centre
Total Transfer Capability for August 2017

Issue Date: 28th April 2017

Issue Time: 1200 hrs

Revision No. 0

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR-WR*	1st August 2017 to 31st August 2017	00-06	2500	500	2000	55	1945		
		06-18				65	1935		
		18-24				55	1945		
WR-NR*	1st August 2017 to 31st August 2017	00-24	9050	500	8550	7951	599		
NR-ER*	1st August 2017 to 31st August 2017	00-06	2000	200	1800	193	1607		
		06-18'	2000		1800	303	1497		
		18-24	2000		1800	193	1607		
ER-NR*	1st August 2017 to 31st August 2017	00-24	4500	300	4200	2983	1217		
W3-ER	1st August 2017 to 31st August 2017	00-24	No limit is being specified.						
ER-W3	1st August 2017 to 31st August 2017	00-24	No limit is being specified.						
WR-SR	1st August 2017 to 31st August 2017	00-05	4350	500	3850	3950	0		
		05-22	4350		3850		0		
		22-24	4350		3850		0		
SR-WR *	1st August 2017 to 31st August 2017	00-24	No limit is being Specified.						
ER-SR	1st August 2017 to 31st August 2017	00-06	3450	250	3200	3240	0		
		06-18'				3325	0		
		18-24				3240	0		
SR-ER *	1st August 2017 to 31st August 2017	00-24	No limit is being Specified.						
ER-NER	1st August 2017 to 31st August 2017	00-17	1045	45	1000	225	775		
		17-23	1065		1020		795		
		23-24	1045		1000		775		
NER-ER	1st August 2017 to 31st August 2017	00-17	1280	45	1235	0	1235		
		17-23	1240		1195		1195		
		23-24	1280		1235		1235		
W3 zone Injection	1st August 2017 to 31st August 2017	00-24	No limit is being specified (In case of any constraints appearing in the system, W3 zone export would be revised accordingly)						
Note: TTC/ATC of S1-(S2&S3) corridor, Import of S3(Kerala), Import of Punjab and Import of DD & DNH is uploaded on NLDC website under Intra-Regional Section in Monthly ATC.									

National Load Despatch Centre
Total Transfer Capability for August 2017

Issue Date: 28th April 2017

Issue Time: 1200 hrs

Revision No. 0

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
----------	------	-------------------	---------------------------------	--------------------	-------------------------------------	--	--	-------------------------------------	----------

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

1) S1 comprises of Telangana, AP and Karnataka; S2 comprises of Tamil Nadu and Puducherry; S3 comprises Kerala

2) W3 comprises of the following regional entities :

a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak
 f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPCCL, n)Vandana Vidyut o)RKM, p)GMR Raikheda, q)Ind Barath and any other regional entity generator in Chhattisgarh

The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/ Fuel shortage/New units being commissioned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

In case of TTC Revision due to any shutdown :

- 1) The TTC value will be revised to normal values after restoration of shutdown.
- 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.

Limiting Constraints

Corridor	Constraint
NR-WR	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak
WR-NR	1. (n-1) Contingency of 765kV Gwalior-Agra one ckt leads to 2750 MW loading on second circuit.
NR-ER	(n-1) contingency of 400 kV Saranath-Pusauli
ER-NR	(n-1) contingencies of N.Ranchi - Chandawa S/c & (n-1) contingencies of 400kV MPL- Maithon S/c
WR-SR & ER-SR	(n-1) contingency of 400 kV Dichipalli-Ramagundam or one ckt of 765 kV Aurangabad-Solapur D/C will lead to 874 MW loading on 400kV Vemagiri(PG)-Gazuwaka (With Opening of 400kV Vemagiri(PG)-Nunna S/C) Low Voltage at Gazuwaka (East) Bus.
ER-NER	a. (n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa
NER-ER	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other 400/220 kV, 315 MVA ICT at Misa
W3 zone Injection	---

Simultaneous Import Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER									
NR	1st August 2017 to 31st August 2017	00-05	12900	800	12100	10934	1166		
		05-08	12000		11200		266		
		08-18	12900		12100		1166		
		18-23	11600		10800		0		
		23-24	12900		12100		1166		
NER	1st August 2017 to 31st August 2017	00-17	1045	45	1000	225	775		
		17-23	1065		1020		795		
		23-24	1045		1000		775		
WR									
SR	1st August 2017 to 31st August 2017	00-05	7800	750	7050	7190	0		
		05-06	7800		7050	7190	0		
		06-18	7800		7050	7275	0		
		18-22	7800		7050	7190	0		
		22-24	7800		7050	7190	0		

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

* For approving STOA Bilateral transactions, margin available in Simultaneous Import of NR would be apportioned on WR-NR Corridor & ER-NR Corridor in the following ratio:

Margin in Simultaneous import of NR = A

WR-NR ATC = B

ER-NR ATC = C

Margin for WR-NR applicants = $A * B / (B + C)$

Margin for ER-NR Applicants = $A * C / (B + C)$

Simultaneous Export Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR*	1st August 2017 to 31st August 2017	00-06	4500	700	3800	248	3552		
		06-18'			3800	368	3432		
		18-24	4500		3800	248	3552		
NER	1st August 2017 to 31st August 2017	00-17	1280	45	1235	0	1235		
		17-23	1240		1195		1195		
		23-24	1280		1235		1235		
WR									
SR *	1st August 2017 to 31st August 2017	00-24	No limit is being Specified.						

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Limiting Constraints

NR	Import	(n-1) contingencies of N.Ranchi - Chandawa S/c & (n-1) contingencies of 400kV MPL- Maithon S/c. 1. (n-1) Contingency of 765kV Gwalior-Agra one ckt leads to 2750 MW loading on second circuit. 2.High Loading of 400kV Singrauli-Anpara S/C.
	Export	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak. (n-1) contingency of 400 kV Saranath-Pusauli
NER	Import	a. (n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa High loading of 220 kV Balipara-Sonabil line(200 MW) b.
	Export	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other 400/220 kV, 315 MVA ICT at Misa.
SR	Import	(n-1) contingency of 400 kV Dichipalli-Ramagundam or one ckt of 765 kV Aurangabad-Solapur D/C will lead to 874 MW loading on 400kV Vemagiri(PG)-Gazuwaka (With Opening of 400kV Vemagiri(PG)-Nunna S/C) Low Voltage at Gazuwaka (East) Bus.

**National Load Despatch Centre
Total Transfer Capability for August 2017**

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor Affected

ASSUMPTIONS IN BASECASE					
				Month : August'17	
S.No.	Name of State/Area	Load		Generation	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
I	NORTHERN REGION				
1	Punjab	10497	8528	3609	3397
2	Haryana	8596	8584	1533	1533
3	Rajasthan	9006	8817	4563	4520
4	Delhi	5341	5181	853	853
5	Uttar Pradesh	14805	16256	9962	9981
6	Uttarakhand	1908	1745	980	979
7	Himachal Pradesh	1269	986	1118	1107
8	Jammu & Kashmir	2138	1165	1034	1038
9	Chandigarh	341	262	0	0
10	ISGS/IPPs	26	27	20580	17730
	Total NR	53927	51551	44232	41138
II	EASTERN REGION				
1	Bihar	4058	2540	238	178
2	Jharkhand	1324	897	187	187
3	Damodar Valley Corporation	3150	2572	4808	3850
4	Orissa	4422	3237	3382	2120
5	West Bengal	8620	5872	5753	4270
6	Sikkim	90	90	0	0
7	Bhutan	245	245	1493	1493
8	ISGS/IPPs	571	568	11250	8880
	Total ER	22450	15993	27052	20919
III	WESTERN REGION				
1	Maharashtra	16411	11943	11524	8836
2	Gujarat	12600	9774	8990	7258
3	Madhya Pradesh	6788	5553	3473	3351
4	Chattisgarh	3711	2946	2656	2025
5	Daman and Diu	320	289	0	0
6	Dadra and Nagar Haveli	690	742	0	0
7	Goa-WR	562	319	0	0
8	ISGS/IPPs	3794	3496	33999	28312
	Total WR	44876	35062	60643	49781

IV	SOUTHERN REGION				
1	Andhra Pradesh	8762	7562	6412	5385
2	Telangana	7965	6695	5245	3519
3	Karnataka	9680	8700	6779	5232
4	Tamil Nadu	14600	12900	8305	6705
5	Kerala	3650	1950	1572	283
6	Pondy	395	395	0	0
7	Goa-SR	89	89	0	0
8	ISGS/IPPs	0	0	11261	11290
	Total SR	45141	38291	39573	32413
V	NORTH-EASTERN REGION				
1	Arunachal Pradesh	143	87	0	0
2	Assam	1214	1070	240	200
3	Manipur	154	78	0	0
4	Meghalaya	262	209	232	194
5	Mizoram	97	69	8	8
6	Nagaland	123	83	22	16
7	Tripura	235	250	34	41
8	ISGS/IPPs	100	60	1930	1804
	Total NER	2328	1906	2466	2263
	Total All India	168967	143047	175460	148010