

**National Load Despatch Centre
Total Transfer Capability for December 2014**

Issue Date: 28/08/2014

Issue Time: 1600 hrs

Revision No. 0

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR-WR *	1st December 2014 to 31st December 2014	00-24	2500	500	2000	706	1294		
WR-NR	1st December 2014 to 31st December 2014	00-17 23-24	4900	500	4400	4380	20		
		17-23	4900		4400		20		
NR-ER*	1st December 2014 to 31st December 2014	00-06	2000	200	1800	293	1507		
		06-18'	2000		1800	358	1442		
		18-24	2000		1800	293	1507		
ER-NR	1st December 2014 to 31st December 2014	00-17 23-24	3500	300	3200	2431	769		
		17-23	3600		3300		869		
W3-ER [§]	1st December 2014 to 31st December 2014	00-24	1900	300	1600	697	903		
ER-W3	1st December 2014 to 31st December 2014	00-24	1000	300	700	874	0		
WR-SR	1st December 2014 to 31st December 2014	00-24	2100	750	1350	1350	0		
SR-WR *	1st December 2014 to 31st December 2014	00-24	No limit is being Specified.						
ER-SR	1st December 2014 to 31st December 2014	00-06 18-24	2700	0	2700	2512	188		
		06-18'				2577	123		
SR-ER *	1st December 2014 to 31st December 2014	00-24	No limit is being Specified.						
ER-NER	1st December 2014 to 31st December 2014	00-17 23-24	650	50	600	210	390		
		17-23	720		670		460		
NER-ER	1st December 2014 to 31st December 2014	00-17 23-24	540	100	440	0	440		
		17-23	525		425		425		

**National Load Despatch Centre
Total Transfer Capability for December 2014**

Issue Date: 28/08/2014

Issue Time: 1600 hrs

Revision No. 0

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
S1-S2	1st December 2014 to 31st December 2014	00-24	2445	295	2150	2850	0		
Import of Punjab	1st December 2014 to 31st December 2014	00-24	5700	300	5400	3790	1610		
Import TTC for DD & DNH	1st December 2014 to 31st December 2014	00-24	1200	0	1200	LTA and MTOA as per ex-pp schedule			
W3 zone Injection	1st December 2014 to 31st December 2014	00-17	9400	200	9200	6843	2357		
		23-24					2857		
		17-23	9900		9700				

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

\$ As per Simulations, predominant direction of flow is on West to North Corridor. Hence, in case injection point is in Western Region (W1,W2,W3), STOA/PX transactions from West to North on West-East-North corridor shall not be allowed as such transaction increases congestion in the West to North Corridor.

1) S1 comprises of AP and Karnataka; S2 comprises of Tamil Nadu, Kerala and Pondicherry

2) W3 comprises of the following regional entities :

a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak
f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPCCL, n)Vandana Vidyut

The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/ Fuel shortage/New units being commissioned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

In case of TTC Revision due to any shutdown :

1) The TTC value will be revised to normal values after restoration of shutdown.

2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.

National Load Despatch Centre
Total Transfer Capability for December 2014

Issue Date: 28/08/2014

Issue Time: 1600 hrs

Revision No. 0

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
----------	------	-------------------	---------------------------------	--------------------	-------------------------------------	--	--	-------------------------------------	----------

Limiting Constraints

Corridor	Constraint
NR-WR	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.
WR-NR	High loading of 765 kV Agra-Gwalior (1250 MW SPS setting on each circuit of 765 kV Gwalior-Agra) and Loop flows on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda (power flowing from WR to NR on 765kV Gwalior-Agra D/C and from NR to WR on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda).
NR-ER	(n-1) contingency of 400 kV Allahabad-Pusauli
ER-NR & ER- NER	Outage of one circuit of 400KV Kahalgaon-Banka leads to thermal loading of second circuit.
NER-ER	Outage of one 315 MVA, 400/220kV ICT at Misa leads to overloading of second ICT at MISA.
W3-ER	(n-1) contingency of 400kV Sterlite-Rourkela S/C
ER-W3	(n-1) contingency of 400kV Raigarh-Jharsuguda-Rourkela
WR-SR & ER-SR	1. Outage of one circuit of 400kV Parli(PG)-Sholapur(PG) leads to thermal loading of second circuit. 2. ER-SR TTC has been declared assuming more than 1100 MW generation at Talcher Stage-2. In case Talcher Stage-2 generation goes below 1100 MW, then the ER-SR TTC would be revised downward as constraints within ER would emerge.
S1-S2	(n-1) contingency of one circuit of 400 kV Kolar-Hosur
Import of DD & DNH	(n-1) contingency of 400/220KV 315MVA ICT at VAPI
Import of Punjab	(n-1) contingency of ICT at Dhuri and (n-1) contingency of 220kV Moga(PG)-Moga(PSTCL)
W3 zone Injection	(n-1-1) contingency of 400 kV Raipur-Bhadrawati D/C section and High loading of 400kV Raipur-Wardha (850 MW SPS setting on each circuit of 400kV Raipur-Wardha)

*Primary constraints

Simultaneous Import Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER									
NR	1st December 2014 to 31st December 2014	00-17 23-24	8400	800	7600	6811	789		
		17-23	8500		7700		889		
NER	1st December 2014 to 31st December 2014	00-17 23-24	650	50	600	210	390		
		17-23	720		670		460		
WR									
SR	1st December 2014 to 31st December 2014	00-06 18-24	4800	750	4050	3862	188		
		06-18'	4800		4050		123		

Simultaneous Export Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR*	1st December 2014 to 31st December 2014	00-06	4500	700	3800		2801		
		06-17'					2736		
		17-18'					2736		
		18-24					2801		
NER	1st December 2014 to 31st December 2014	00-17 23-24	540	100	440	0	440		
		17-23	525		425		425		
WR									
SR *	1st December 2014 to 31st December 2014	00-24	No limit is being Specified.						

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Limiting Constraints

NR	Import	Outage of one circuit of 400KV Kahalgaon-Banka leads to thermal loading of second circuit. High loading of 765 kV Agra-Gwalior (1250 MW SPS setting on each circuit of 765 kV Gwalior-Agra) and high loop flows on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda (power flowing from WR to NR on 765kV Gwalior-Agra D/C and from NR to WR on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda).
	Export	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak. (n-1) contingency of 400 kV Allahabad-Pusauli
NER	Import	Outage of one circuit of 400KV Kahalgaon-Banka leads to thermal loading of second circuit.
	Export	Outage of one 315 MVA, 400/220kV ICT at Misa leads to overloading of second ICT at MISA.
SR	Import	1. Outage of one circuit of 400kV Parli(PG)-Sholapur(PG) leads to thermal loading of second circuit.
		2. ER-SR TTC has been declared assuming more than 1100 MW generation at Talcher Stage-2. In case Talcher Stage-2 generation goes below 1100 MW, then the ER-SR TTC would be revised downward as constraints within ER would emerge.

*Primary constraints

**National Load Despatch Centre
Total Transfer Capability for December 2014**

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor Affected
------------------------	-----------------------------	-------------------------------	----------------------------	------------------------------