

**National Load Despatch Centre  
Total Transfer Capability for December 2014**

Issue Date: 11/12/2014

Issue Time: 1330 hrs

Revision No. 13

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
<b>NR-WR *</b>	1st December 2014 to 31st December 2014	00-24	2500	500	2000	1055	945		
<b>WR-NR</b>	1st December 2014 to 2nd December 2014	00-07'	4900	500	4400	4380	20		
		07-24'	4100		3600		0		
	3rd December 2014	00-07'	4900	500	4400	4380	20		
		07-14'	4100		3600		0		
		14-24	3600		3600		0		
	4th December 2014	00-07'	4400	500	3900	4380	0		
		07-24'	3600		3100		0		
	5th December 2014 to 11th December 2014	00-07	4900	500	4400	4380	20		
		07-24	4100		3600		0		
	12th December 2014 to 18th December 2014	00-07	4900	500	4400	4380	20		
		07-24	4100		3600		0		
	19th December 2014 to 31st December 2014	00-17	4900	500	4400	4380	20		
		23-24	4900		4400		20		
			17-23	4900		4400		20	
<b>NR-ER*</b>	1st December 2014 to 31st December 2014	00-06	2000	200	1800	293	1507		
		06-18'	2000		1800	358	1442		
		18-24	2000		1800	293	1507		
<b>ER-NR</b>	1st December 2014 to 31st December 2014	00-17	3500	300	3200	2431	769		
		23-24	3500		3300		869		
		17-23	3600		3300		869		
<b>W3-ER<sup>s</sup></b>	1st December 2014 to 31st December 2014	00-24	1900	300	1600	697	903		
<b>ER-W3</b>	1st December 2014 to 31st December 2014	00-24	1000	300	700	973	0		
<b>WR-SR</b>	1st December 2014 to 9th December 2014	00-24	2100	750	1350	1350	0		
	10th December 2014	00-05	2100	750	1350	1350	0		
		10-24'	1750		1000	1350	0		
	11th December 2014	05-22	2100	750	1350	1350	0		
		00-05	2500		1750	1350	400		
	12th December 2014 to 13th December 2014	05-08	2100	750	1350	1350	0		
		08-22'	1600		850	1350	0	-500	Revised due to shutdown of HVDC Bhadrawati Pole 2
		22-24	2000		1250	1350	0		
	00-05	2500	1750	1350	400				
	14th December 2014 to 31st December 2014	05-22	2100	750	1350	1350	0		
00-05		2500	1750		1350	400			
<b>SR-WR *</b>	1st December 2014 to 31st December 2014	00-24	No limit is being Specified.						

**National Load Despatch Centre  
Total Transfer Capability for December 2014**

Issue Date: 11/12/2014

Issue Time: 1330 hrs

Revision No. 13

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
ER-SR	1st December 2014 to 4th December 2014	00-06	2300	0	2300	2435	0			
		18-24				2500	0			
		06-18'				2435	0			
	5th December 2014	00-06	2300	0	2300	2435	0			
		06-13'	2300			2500	0			
		13-18'	2500			2500	0			
		18-24	2500			2435	65			
	6th December 2014 to 7th December 2014	00-06	2650	0	2650	2435	215			
		18-24				2500	150			
		06-18'				2435	215			
	8th December 2014 to 15th December 2014	00-06	2650	0	2650	2435	215			
		18-24				2500	150			
16th December 2014 to 31st December 2014	00-06	2650	0	2650	2435	215				
	18-24				2500	150				
06-18'	2435	150								
SR-ER *	1st December 2014 to 31st December 2014	00-24	No limit is being Specified.							
ER-NER	1st December 2014	00-17	650	40	610	210	400			
		23-24					420			
	17-23	670	630							
	2nd December 2014 to 8th December 2014	00-17	685	40	645	210	435			
		23-24					460			
		17-23					710			670
	9th December 2014	00-08	685	40	645	210	435			
		23-24					210			
		08-17'					460			670
	17-23	710	460							
	10th December 2014 to 31st December 2014	00-17	685	40	645	210	435			
		23-24					460			
17-23	710	670								
NER-ER	1st December 2014 to 8th December 2014	00-17	480	30	450	0	450			
		23-24		40			470			470
		17-23		500			40			470
	9th December 2014	00-08	480	30	450	0	450			
		23-24					245			
		08-17'					275			30
	17-23	500	40	470	470					
	10th December 2014 to 31st December 2014	00-17	480	30	450	0	450			
		23-24					470			
	17-23	500	40	470	470					
	S1-S2	1st December 2014 to 2nd December 2014	00-24	3300	295	3005	2879	126		
		3rd December 2014	00-10	3300	295	3005	2879	126		
1000-1730			3210	295	2915	2879	36			
1730-2400			3300	295	3005	2879	126			
4th December 2014 to 9th December 2014		00-24	3300	295	3005	2879	126			
11th December 2014		00-06	3300	295	3005	3029	0			
		06-24	3575	295	3280	3138	142			
12th December 2014 to 14th December 2014		00-24	3575	295	3280	3138	142			
15th December 2014 to 28th December 2014	00-24	3300	295	3005	2978	27				

**National Load Despatch Centre  
Total Transfer Capability for December 2014**

Issue Date: 11/12/2014

Issue Time: 1330 hrs

Revision No. 13

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
	29th December 2014 to 30th December 2014	00-24	3300	295	3005	2942	63		
	31st December 2014	00-24	3300	295	3005	2865	140		
<b>Import of Punjab</b>	1st December 2014 to 31st December 2014	00-24	5700	300	5400	3790	1610		
<b>Import TTC for DD &amp; DNH</b>	1st December 2014 to 31st December 2014	00-24	1200	0	1200	LTA and MTOA as per ex-pp schedule			
<b>W3 zone Injection</b>	1st December 2014 to 31st December 2014	00-17	9400	200	9200	6843	2357		
		23-24					2857		
		17-23					9900		

\* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

\*\* Maharashtra's off peak demand is considered to be lower than the peak demand by approximately 5000 MW from 2200 hrs to 0500 hrs

\$ As per Simulations, predominant direction of flow is on West to North Corridor. Hence, in case injection point is in Western Region (W1,W2,W3), STOA/PX transactions from West to North on West-East-North corridor shall not be allowed as such transaction increases congestion in the West to North Corridor.

- 1) ER-SR TTC declared at Talcher Interconnector and Gazuwaka HVDC B/B seam
- 2) S1 comprises of AP and Karnataka: S2 comprises of Tamil Nadu, Kerala and Pondicherry
- 3) W3 comprises of the following regional entities :
  - a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak
  - f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPCCL, n)Vandana Vidyut

# The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/ Fuel shortage/New units being commissioned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

In case of TTC Revision due to any shutdown :

- 1) The TTC value will be revised to normal values after restoration of shutdown.
- 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.

**Limiting Constraints**

Corridor	Constraint
<b>NR-WR</b>	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.
<b>WR-NR</b>	High Loading of 400kV Singrauli-Anpara & High loading of 765 kV Agra-Gwalior (1250 MW SPS setting on each circuit of 765 kV Gwalior-Agra) and Loop flows on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda (power flowing from WR to NR on 765kV Gwalior-Agra D/C and from NR to WR on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda).
<b>NR-ER</b>	(n-1) contingency of 400 kV Allahabad-Pusauli
<b>ER-NR &amp; ER-NER</b>	Outage of one circuit of 400KV Kahalgaon-Banka leads to thermal loading of second circuit.
<b>W3-ER</b>	(n-1) contingency of 400kV Sterlite-Rourkela S/C
<b>ER-W3</b>	(n-1) contingency of 400kV Raigarh-Jharsuguda-Rourkela
<b>WR-SR &amp; ER-SR</b>	1. (n-1) contingency of one circuit of 400kV Parli(PG)-Sholapur(PG)
	2. ER-SR TTC has been declared assuming more than 1100 MW generation at Talcher Stage-2. In case Talcher Stage-2 generation goes below 1100 MW, then the ER-SR TTC would be revised downward as constraints within ER would emerge.
<b>ER-NER</b>	Palatana unit tripping leading to the thermal overloading of 220 kV BTPS - Salakati D/C
<b>NER-ER</b>	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa and High loading of 220kV Misa-Samaguri D/C
<b>S1-S2</b>	(n-1) contingency of one circuit of 400 kV Kolar-Hosur
<b>Import of DD &amp; DNH</b>	(n-1) contingency of 400/220KV 315MVA ICT at VAPI
<b>Import of Punjab</b>	(n-1) contingency of ICT at Dhuri and (n-1) contingency of 220kV Moga(PG)-Moga(PSTCL)
<b>W3 zone Injection</b>	(n-1-1) contingency of 400 kV Raipur-Bhadrawati D/C section and High loading of 400kV Raipur-Wardha (850 MW SPS setting on each circuit of 400kV Raipur-Wardha)

\*Primary constraints

**Simultaneous Import Capability**

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
ER										
NR	1st December 2014 to 2nd December 2014	00-07	8400	800	7600	6811	789			
		07-'17	7600		6800		0			
		17-23	7700		6900		89			
		23-24	7600		6800		0			
	3rd December 2014	00-07	8400	800	7600	6811	789			
		07-'14	7600		6800		0			
		14-'17	7100		7100		0			
		17-23	7200		6400		0			
	23-24	7100	6300	0						
		4th December 2014	00-07	7900	800	7100	6811	289		
			07-'17	7100		6300		0		
			17-23	7200		6400		0		
	23-24		7100	6300		0				
	5th December 2014 to 11th December 2014	00-07	8400	800	7600	6811	789			
		07-17	7600		6800		0			
		23-24	7600		6900		89			
		17-23	7700		6900		89			
	12th December 2014 to 18th December 2014	00-07	8400	800	7600	6811	789			
		07-17	7600		6800		0			
		23-24	7600		6900		89			
		17-23	7700		6900		89			
	19th December 2014 to 31st December 2014	00-17	8400	800	7600	6811	789			
		23-24	8400		7700		889			
		17-23	8500		7700		889			

NER	1st December 2014	00-17	650	40	610	210	400			
		23-24			630		420			
	2nd December 2014 to 8th December 2014	00-17	685	40	645	210	435			
		23-24			670		460			
	9th December 2014	00-08	685	40	645	210	435			
		23-24			420		210			
		08-17'	460		670		460			
	10th December 2014 to 31st December 2014	00-17	685	40	645	210	435			
		23-24			670		460			
	WR									
	SR	1st December 2014 to 4th December 2014	00-06	4400	750	3650	3785	0		
18-24							3850	0		
5th December 2014		06-18'		750	3650	3785	0			
		00-06	4400			3850	0			
		06-13'	4400			3850	0			
		13-18'	4600			3850	0			
6th December 2014 to 7th December 2014		18-24	4600	750	4000	3785	65			
		06-18'	4750			3850	215	150		
8th December 2014 to 9th December 2014		00-06	4750	750	4000	3785	215			
		18-24					3850	150		
10th December 2014		06-18'		750	4000	3785	215			
		00-05	4750			3785	215			
		18-24	4400			3650	3785	0		
		05-06'	4400			3650	3850	0		
11th December 2014		06'-10	4750	750	4000	3850	150			
		10-18'	5150			4400	3785	615		
		00-05	4750			4000	3850	150		
		06-18'	4750			4000	3785	215		
12th December 2014 to 13th December 2014		22-24	5150	750	4400	3785	615			
		00-05	5150			4400	3785	615		
		06-08'	4750			4000	3850	150		
		08-18'	4250			3500	3850	-350		
14th December 2014 to 31st December 2014		18-22	4250	750	4000	3785	-285	-500	Revised due to shutdown of HVDC Bhadrawati Pole 2	
		22-24	4650			3900	3785			115
14th December 2014 to 31st December 2014		00-05	5150	750	4400	3785	615			
		06-18'	4750			4000	3850	150		
		18-22	4750			4000	3785	215		
		22-24	5150			4400	3785	615		

## Simultaneous Export Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR*	1st December 2014 to 31st December 2014	00-06	4500	700	3800	999	2801		
		06-17'			3800	1064	2736		
		17-18'	4500		3800	1064	2736		
		18-24	4500		3800	999	2801		
NER	1st December 2014 to 8th December 2014	00-17	480	30	450	0	450		
		23-24	500	40	470		470		
	9th December 2014	00-08	480	30	450	0	450		
		23-24	275	30	245		245		
		08-17'	500	40	470		470		
	10th December 2014 to 31st December 2014	00-17	480	30	450	0	450		
		23-24	500	40	470		470		
	WR								
SR *	1st December 2014 to 31st December 2014	00-24	No limit is being Specified.						

\* Fifty Percent (50 % ) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

### Limiting Constraints

NR	<b>Import</b>	Outage of one circuit of 400KV Kahalgaon-Banka leads to thermal loading of second circuit. High loading of 765 kV Agra-Gwalior (1250 MW SPS setting on each circuit of 765 kV Gwalior-Agra) and high loop
	<b>Export</b>	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak. (n-1) contingency of 400 kV Allahabad-Pusauli
NER	<b>Import</b>	Outage of one circuit of 400KV Kahalgaon-Banka leads to thermal loading of second circuit.
	<b>Export</b>	Outage of one 315 MVA, 400/220kV ICT at Misa leads to overloading of second ICT at MISA.
SR	<b>Import</b>	1. (n-1) contingency of one circuit of 400kV Parli(PG)-Sholapur(PG)
		2. ER-SR TTC has been declared assuming more than 1100 MW generation at Talcher Stage-2. In case Talcher Stage-

\*Primary constraints

**National Load Despatch Centre  
Total Transfer Capability for December 2014**

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor Affected
1	21-11-2014	Whole Month	Revised due to 400kV Jeypore-Gazuwaka D/C line Tower collapse	ER-SR
			Revised due to 400kV KalivendapattuPugalur-2 and 400/230kV Tiruvalam Downstream commissioning & Revised LGBR by constituents.	S1-S2
2	27-11-2014	Whole month	LTA revised due to allocation of power from North to West	NR-WR
			LTA revised due to allocation of LTA from ER to MP	ER-W3
		1-12-2014 to 4-12-2014	Revised due to shutdown of Mundra-Mohindergerh HVDC Pole-2	WR-NR
		Whole Month	Revised due to NCTPS Stage -2 Unit-1 outage extension & Synchronisation of 765kV Karnool-Tiruvalam DC line ( at 400kV level).	S1-S2
Revised considering network restructuring in NER region	ER-NER			
3	01-12-2014	1-12-2014 to 7-12-2014	Revised considering the revival of 400 kV Jeypore Gazuwaka ckt 2 after cyclone Hudhud	ER-SR
		Whole month	Revised considering the real time load generation balance conditions in ER region	ER-NER
			Revised considering network restructuring and real time load generation balance in NER region	NER-ER
4	02-12-2014	03-12-2014	Revised due to shutdown of 400kV Nellore - Alamatty	S1-S2
5	03-12-2014	03-12-2014 to 04-12-2014	Revised due to restriction of Power order of HVDC Vindhychal B/B to 250 MW for maintenance reasons.	WR-NR
6	04-12-2014	05-12-2014 to 11-12-2014	Revised due to shutdown of HVDC Rihand - Dadri pole 1	WR-NR
		12-12-2014 to 18-12-2014	Revised due to shutdown of HVDC Rihand - Dadri pole 2	
7	05-12-2014	05-12-2014 to 15-12-2014	Revised considering the revival of 400 kV Jeypore Gazuwaka ckt 2 after cyclone Hudhud	ER-SR
8	06-12-2014	whole month	Revised considering the revival of 400 kV Jeypore Gazuwaka ckt 1 after cyclone Hudhud	ER-SR
9	08-12-2014	09-12-2014	Revised due to shutdown of 220 kV Azara	ER-NER / NER-ER
10	09-12-2014	10-12-2014	Revised due to shutdown of 400 kV Parli - Sholapur ckt 2	WR-SR
11	10-12-2014	11-12-2014 to 31-12-2014	Revised considering the present demand pattern of Maharashtra** during off -peak conditions	WR-SR
12	10-12-2014	11-12-2014 to 14-12-2014	Revised due to outage of Vallur unit 1	S1-S2
13	11-12-2014	12-12-2014 to 13-12-2014	Revised due to shutdown of HVDC Bhadravati Pole 2	WR-SR