

**National Load Despatch Centre
Total Transfer Capability for December 2019**

Issue Date: 26th December 2019

Issue Time: 1230 hrs

Revision No. 15

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR-WR*	1st December 2019 to 31st December 2019	00-06	2500	500	2000	195	1805		
		06-18				250	1750		
		18-24				195	1805		
WR-NR*	1st December 2019 to 02nd December 2019	00-730	14900	500	14400	10404	3996		
			13950**		13450**	9454**	3996**		
	730-24	12300	500	11800	10404	1396			
		11350**		10850**	9454**	1396**			
	03rd December 2019	00-730	14900	500	14400	10404	3996		
			13950**		13450**	9454**	3996**		
	730-24	14900	500	14400	10404	3996			
		13950**		13450**	9454**	3996**			
	04th December 2019 to 12th December 2019	00-24	14900	500	14400	10404	3996		
			13950**		13450**	9454**	3996**		
	13th December 2019 to 16th December 2019	00-07'	14900	500	14400	10404	3996		
			13950**		13450**	9454**	3996**		
	07-24'	13900	500	13400	10404	2996			
		12950**		12450**	9454**	2996**			
	17th December 2019 to 18th December 2019	00-07'	14900	500	14400	10404	3996		
			13950**		13450**	9454**	3996**		
	07-24'	13900	500	13400	10404	2996			
		12950**		12450**	9454**	2996**			
	19th December 2019 to 21st December 2019	00-730'	14900	500	14400	10404	3996		
			13950**		13450**	9454**	3996**		
	730-24'	14200	500	13700	10404	3296			
		13250**		12750**	9454**	3296**			
	22nd December 2019 to 23rd December 2019	00-730'	14900	500	14400	10404	3996		
			13950**		13450**	9454**	3996**		
730-24'	14200	500	13700	10404	3296				
	13250**		12750**	9454**	3296**				
24th December 2019 to 31st December 2019	00-24	14900	500	14400	10404	3996			
		13950**		13450**	9454**	3996**			
NR-ER*	1st December 2019 to 31st December 2019	00-06	2000	200	1800	193	1607		
		06-18	2000		1800	303	1497		
		18-24	2000		1800	193	1607		

National Load Despatch Centre
Total Transfer Capability for December 2019

Issue Date: 26th December 2019

Issue Time: 1230 hrs

Revision No. 15

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments		
ER-NR*	1st December 2019 to 31st December 2019	00-24	5250	300	4950	4050	900				
W3-ER	1st December 2019 to 31st December 2019	00-24	No limit is being specified.								
ER-W3	1st December 2019 to 31st December 2019	00-24	No limit is being specified.								
WR-SR	1st December 2019 to 15th December 2019	00-05	5550	500	5050	3988	1062				
		05-22	5550		5050		1062				
		22-24	5550		5050		1062				
	16th December 2019 to 31st December 2019	00-05	5050	500	4550	3988	562				
		05-22	5050		4550		562				
		22-24	5050		4550		562				
SR-WR *	1st December 2019 to 31st December 2019	00-24	No limit is being Specified.								
ER-SR	1st December 2019 to 20th December 2019	00-06	4950	250	4700	2748	1952				
		06-18				2833	1867				
		18-24				2748	1952				
ER-SR	21st December 2019 to 22nd December 2019	00-06	4950	250	4700	2748	1952				
		06-09				4950	4700	2833		1867	
		09-18				4650	4400	2833		1567	
		18-24				4650	4400	2748		1652	
ER-SR	23rd December 2019	00-06	4950	250	4700	2748	1952				
		06-18				2833	1867				
		18-24				2748	1952				
ER-SR	24th December 2019 to 25th December 2019	00-06	4950	250	4700	2748	1952				
		06-09				4950	4700	2833		1867	
		09-18				4650	4400	2833		1567	
		18-24				4650	4400	2748		1652	
ER-SR	26th December 2019	00-06	4950	250	4700	2748	1952				
		06-18				2833	1867				
		18-24				2748	1952				
ER-SR	27th December 2019 to 29th December 2019	00-06	4950	250	4700	2748	1952		Revised due to shutdown of i) 400KV Jeypore – Bolangir Line on 27.12.19 & 28.12.19. ii) 400 KV Jeypore –Indravati Line on 29.12.19.		
		06-09				4950	4700	2833		1867	
		09-18				4650	4400	2833		1567	-300
		18-24				4650	4400	2748		1652	-300
ER-SR	30th December 2019 to 31st December 2019	00-06	4950	250	4700	2748	1952				
		06-18				2833	1867				
		18-24				2748	1952				
SR-ER *	1st December 2019 to 31st December 2019	00-24	No limit is being Specified.								

National Load Despatch Centre
Total Transfer Capability for December 2019

Issue Date: 26th December 2019

Issue Time: 1230 hrs

Revision No. 15

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER-NER	1st December 2019 to 5th December 2019	00-17	1550	45	1505	334	1171		
		17-23	1000		955		621		
		23-24	1550		1505		1171		
	6th December 2019	00-07	1550	45	1505	334	1171		
		07-17	1180		1135		801		
		17-23	750		705		371		
		23-24	1180		1135		801		
	7th December 2019 to 22nd December 2019	00-17	1550	45	1505	334	1171		
		17-23	1000		955		621		
		23-24	1550		1505		1171		
	23rd December 2019	00-06	1550	45	1505	334	1171		
		06-17'	1450		1405		1071		
17-23		950	905		571				
23-24		1450	1405		1071				
ER-NER	24th December 2019	00-06	1450	45	1405	334	1071		
		06-17'	1450		1405		1071		
		17-23	950		905		571		
		23-24	1450		1405		1071		
	25th December 2019 to 31st December 2019	00-17	1550	45	1505	334	1171		
17-23	1000	955	621						
23-24	1550	1505	1171						
NER-ER	1st December 2019 to 5th December 2019	00-17	2730	45	2685	0	2685		
		17-23	2460		2415		2415		
		23-24	2730		2685		2685		
	6th December 2019	00-07	2730	45	2685	0	2685		
		07-17	2380		2335		2335		
		17-23	2240		2195		2195		
		23-24	2380		2335		2335		
	7th December 2019 to 22nd December 2019	00-17	2730	45	2685	0	2685		
		17-23	2460		2415		2415		
		23-24	2730		2685		2685		
	23rd December 2019	00-06'	2730	45	2685	0	2685		
		06-17'	2400		2355		2355		
		17-23	2150		2105		2105		
		23-24	2400		2355		2355		
	24th December 2019	00-06'	2400	45	2355	0	2355		
06-17'		2400	2355		2355				
17-23		2150	2105		2105				
23-24		2400	2355		2355				
25th December 2019 to 31st December 2019	00-17	2730	45	2685	0	2685			
	17-23	2460		2415		2415			
	23-24	2730		2685		2685			
W3 zone Injection	1st December 2019 to 31st December 2019	00-24	No limit is being specified (In case of any constraints appearing in the system, W3 zone export would be revised accordingly)						

Note: TTC/ATC of S1-(S2&S3) corridor, Import of S3(Kerala), Import of Punjab and Import of DD & DNH is uploaded on NLDC website under Intra-Regional Section in Monthly ATC.

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

**Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.

1) S1 comprises of Telangana, AP and Karnataka; S2 comprises of Tamil Nadu and Puducherry; S3 comprises Kerala

2) W3 comprises of the following regional entities :

National Load Despatch Centre
Total Transfer Capability for December 2019

Issue Date: 26th December 2019

Issue Time: 1230 hrs

Revision No. 15

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
----------	------	-------------------	---------------------------------	--------------------	-------------------------------------	--	--	-------------------------------------	----------

a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak
f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPC, n)Vandana Vidyut o)RKM, p)GMR Raikheda, q)Ind Barath
and any other regional entity generator in Chhattisgarh

The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/ Fuel shortage/New units being commissioned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

In case of TTC Revision due to any shutdown :

- 1) The TTC value will be revised to normal values after restoration of shutdown.
- 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.

Simultaneous Import Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER									
NR	1st December 2019 to 2nd December 2019	00-06	20400	800	19600	14454 13504**	5146		
			19450**		18650**		5146**		
		06-730	21900		21100		6646		
			20950**		20150**		6646**		
		730-09	18100		17300		2846		
	17150**		16350**		2846**				
	09-17	16850	16050		1596				
	17-24	15900**	15100**		1596**				
		16400	15600		1146				
			15450**		14650**		1146**		
NR	03rd December 2019	00-06	20400	800	19600	14454 13504**	5146		
			19450**		18650**		5146**		
		06-730	21900		21100		6646		
			20950**		20150**		6646**		
		730-09	21900		21100		6646		
	20950**		20150**		6646**				
	09-17	20400	19600		5146				
		19450**	18650**		5146**				
	17-24	19850	19050		4596				
		18900**	18100**		4596**				
NR	04th December 2019 to 12th December 2019	00-06	20400	800	19600	14454 13504**	5146		
			19450**		18650**		5146**		
		06-09	21900		21100		6646		
			20950**		20150**		6646**		
		09-17	20400		19600		5146		
19450**	18650**		5146**						
17-24	19850	19050	4596						
		18900**	18100**	4596**					

NR	13th December 2019 to 16th December 2019	00-06	20400	800	19600	14454	5146		
			19450**		18650**		5146**		
		06-07	21900		21100		6646		
			20950**		20150**		6646**		
		07-09	20450		19650		5196		
			19500**		18700**		5196**		
09-17	19050	18250	3796						
	18100**	17300**	3796**						
17-24	18550	17750	3296						
	17600**	16800**	3296**						
NR	17th December 2019 to 18th December 2019	00-06	20400	800	19600	14454	5146		
			19450**		18650**		5146**		
		06-07	21900		21100		6646		
			20950**		20150**		6646**		
		07-09	20450		19650		5196		
			19500**		18700**		5196**		
09-17	19050	18250	3796						
	18100**	17300**	3796**						
17-24	18550	17750	3296						
	17600**	16800**	3296**						
NR	19th December 2019 to 21st December 2019	00-06	20400	800	19600	14454	5146		
			19450**		18650**		5146**		
		06-730	21900		21100		6646		
			20950**		20150**		6646**		
		730-09	20900		20100		5646		
			19950**		19150**		5646**		
09-17	19450	18650	4196						
	18500**	17700**	4196**						
17-24	18950	18150	3696						
	18000**	17200**	3696**						

NR	22nd December 2019 to 23rd December 2019	00-06	20400 19450**	800	19600 18650**	14454 13504**	5146 5146**						
		06-730	21900 20950**		21100 20150**		6646 6646**						
			730-09		20900 19950**		20100 19150**	5646 5646**					
		09-17	19450 18500**		18650 17700**		4196 4196**						
			17-24		18950 18000**		18150 17200**	3696 3696**					
		NR			24th December 2019 to 31st December 2019		00-06	20400 19450**	800	19600 18650**	14454 13504**	5146 5146**	
06-09	21900 20950**		21100 20150**	6646 6646**									
	09-17		20400 19450**	19600 18650**		5146 5146**							
17-24			19850 18900**	19050 18100**		4596 4596**							
	NER		1st December 2019 to 5th December 2019	00-17		1550	45	1505		334		1171	
17-23				1000		955		621					
23-24		1550		1505	1171								
6th December 2019		00-07	1550	45	1505	334	1505						
		07-17	1180		1135		1135						
		17-23	750		705		705						
		23-24	1180		1135		1135						
7th December 2019 to 22nd December 2019		00-17	1550	45	1505	334	1171						
		17-23	1000		955		621						
	23-24	1550	1505		1171								
NER	23rd December 2019	00-06	1550	45	1505	334	1171						
		06-17'	1450		1405		1071						
		17-23	950		905		571						
		23-24	1450		1405		1071						
24th December 2019	00-06	1450	45	1405	334	1071							
	06-17'	1450		1405		1071							
	17-23	950		905		571							
	23-24	1450		1405		1071							
25th December 2019 to 31st December 2019	00-17	1550	45	1505	334	1171							
	17-23	1000		955		621							
	23-24	1550		1505		1171							

WR								
SR	1st December 2019 to 15th December 2019	00-06	10500	750	9750	6736	3014	
		06-18	10500		9750	6821	2929	
		18-24	10500		9750	6736	3014	
	16th December 2019 to 20th December 2019	00-06	10000	750	9250	6736	2514	
		06-18	10000		9250	6821	2429	
		18-24	10000		9250	6736	2514	
	21st December 2019 to 22nd December 2019	00-06	10000	750	9250	6736	2514	
		06-09	10000		9250	6821	2429	
		09-18	9700		8950	6821	2129	
		18-24	9700		8950	6736	2214	
	23rd December 2019	00-06	10000	750	9250	6736	2514	
		06-18	10000		9250	6821	2429	
		18-24	10000		9250	6736	2514	
	24th December 2019 to 25th December 2019	00-06	10000	750	9250	6736	2514	
		06-09	10000		9250	6821	2429	
		09-18	9700		8950	6821	2129	
		18-24	9700		8950	6736	2214	
	26th December 2019	00-06	10000	750	9250	6736	2514	
		06-18	10000		9250	6821	2429	
		18-24	10000		9250	6736	2514	
	27th December 2019 to 29th December 2019	00-06	10000	750	9250	6736	2514	
		06-09	10000		9250	6821	2429	
		09-18	9700		8950	6821	2129	-300
		18-24	9700		8950	6736	2214	-300
30th December 2019 to 31st December 2019	00-06	10000	750	9250	6736	2514		
	06-18	10000		9250	6821	2429		
	18-24	10000		9250	6736	2514		

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

**Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.

* For approving STOA Bilateral transactions, margin available in Simultaneous Import of NR would be apportioned on WR-NR Corridor & ER-NR Corridor in the following ratio:

Margin in Simultaneous import of NR = A

WR-NR ATC = B

ER-NR ATC = C

Margin for WR-NR applicants = $A * B / (B + C)$

Margin for ER-NR Applicants = $A * C / (B + C)$

Simultaneous Export Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR*	1st December 2019 to 31st December 2019	00-06	4500	700	3800	388	3412		
		06-18			3800	553	3247		
		18-24	4500		3800	388	3412		
NER	1st December 2019 to 5th December 2019	00-17	2730	45	2685	0	2685		
		17-23	2460		2415		2415		
		23-24	2730		2685		2685		
	6th December 2019	00-07	2730	45	2685	0	2685		
		07-17	2380		2335		2335		
		17-23	2240		2195		2195		
		23-24	2380		2335		2335		
	7th December 2019 to 22nd December 2019	00-17	2730	45	2685	0	2685		
		17-23	2460		2415		2415		
		23-24	2730		2685		2685		
	23rd December 2019	00-06'	2730	45	2685	0	2685		
		06-17'	2400		2355		2355		
		17-23	2150		2105		2105		
		23-24	2400		2355		2355		
	24th December 2019	00-06'	2400	45	2355	0	2355		
		06-17'	2400		2355		2355		
		17-23	2150		2105		2105		
		23-24	2400		2355		2355		
	25th December 2019 to 31st December 2019	00-17	2730	45	2685	0	2685		
		17-23	2460		2415		2415		
		23-24	2730		2685		2685		
	WR								
	SR *	1st December 2019 to 31st December 2019	00-24	No limit is being Specified.					

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Limiting Constraints (Corridor wise)

Corridor	Constraint	Applicable Revisions
NR-WR	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Bhanpura-Modak	Rev-0 to 15
WR-NR	n-1 contingency of 765 kV Aligarh - Jhatikara Line will lead to overloading of 765 kV Aligarh - Gr. Noida Line	Rev-0 to 15
NR-ER	(n-1) contingency of 400 kV Saranath-Pusauli	Rev-0 to 15
ER-NR	1. N-1 contingencies of 400 kv Mejia-Maithon A S/C 2. N-1 contingencies of 400 kv Kahalgaon-Banka S/C 3. N-1 contingencies of 400kV MPL- Maithon S/C	Rev-0 to 15
WR-SR and ER-SR	n-1 contingency of 2x315 MVA, 400/220 kV ICTs at Mardam will lead to overloading of the second ICT	Rev-0 to 15
	n-1 contingency of 2x1500 MVA, 765/400 kV ICTs at Vemagiri (PG) will lead to overloading of the second ICT	Rev-0 to 15
	Low Voltage at Gazuwaka (East) Bus.	Rev-0 to 15
ER-NER	a. (n-1) contingency of 400/220 kV, 2x500 MVA ICTs at Misa b. High Loading of 220 kV Salakati-BTPS Double circuit (200 MW)	Rev-0 to 2
	a) N-1 contingency of 400 kV Azara-Bongaigaon b) High Loading of 220 kV Salakati-BTPS Double circuit (200 MW)	Rev 3 to 5,7-15
	N-1 contingency of 400 kV Byrnihat - Bongaigaon will lead to high Loading of 220 kV Samaguri - Sonabil line	Rev-6
NER-ER	a. N-1 contingency of 400 kV Silchar- Azara Line b. High Loading of 400 kV Bongaigaon-Killing line	Rev-0 to 2
	a) N-1 contingency of 400 kV Silchar- Azara Line b) High Loading in internal Power System of Meghalaya	Rev-3 to 5,7-15
	N-1 contingency of 400 kV Byrnihat - Bongaigaon will lead to high Loading of 220 kV Samaguri - Sonabil line	Rev-6
W3 zone Injection	---	Rev-0 to 15

Limiting Constraints (Simultaneous)

		Applicable Revisions	
NR	Import	1. N-1 contingencies of 400 kv Mejia-Maithon A S/C 2. N-1 contingencies of 400 kv Kahalgaon-Banka S/C 3. N-1 contingencies of 400kV MPL- Maithon S/C	Rev-0 to 15
		n-1 contingency of 765 kV Aligarh - Jhatikara Line will lead to overloading of 765 kV Aligarh - Gr. Noida Line	Rev-0 to 15
	Export	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.	Rev-0 to 15
		(n-1) contingency of 400 kV Saranath-Pusauli	Rev-0 to 15
NER	Import	a. (n-1) contingency of 400/220 kV, 2x500 MVA ICTs at Misa b. High Loading of 220 kV Salakati-BTPS Double circuit (200 MW)	Rev-0 to 2
		a) N-1 contingency of 400 kV Azara-Bongaigaon b) High Loading of 220 kV Salakati-BTPS Double circuit (200 MW)	Rev 3 to 5,7-15
		N-1 contingency of 400 kV Byrnihat - Bongaigaon will lead to high Loading of 220 kV Samaguri - Sonabil line	Rev-6
	Export	a. N-1 contingency of 400 kV Silchar- Azara Line b. High Loading of 400 kV Bongaigaon-Killing line	Rev-0 to 2
a) N-1 contingency of 400 kV Silchar- Azara Line b) High Loading in internal Power System of Meghalaya		Rev-3 to 5,7-15	
N-1 contingency of 400 kV Byrnihat - Bongaigaon will lead to high Loading of 220 kV Samaguri - Sonabil line		Rev-6	
SR	Import	n-1 contingency of 2x315 MVA, 400/220 kV ICTs at Mardam will lead to overloading of the second ICT	Rev-0 to 15
		n-1 contingency of 2x1500 MVA, 765/400 kV ICTs at Vemagiri (PG) will lead to overloading of the second ICT	Rev-0 to 15
		Low Voltage at Gazuwaka (East) Bus.	Rev-0 to 15

**National Load Despatch Centre
Total Transfer Capability for December 2019**

Revision No	Date of Revision	Period of Revision	Reason for Revision/Comment	Corridor Affected
1	13th September 2019	Whole Month	Revised considering Load Generation balance and HVDC set points as per present system conditions	WR-NR/Import of NR
2	18th November 2019	Whole Month	Revised STOA margin due to 4.2 MW LTA and 19.76 MW MTOA to Assam from GIWEL	ER-NER/Import of NER
3	29th November 2019	Whole Month	Revised STOA margin due to the following. Operationalization of following LTAs:- a) AGEMPL to UPPCL – 40 MW b) GIWEL_SECI-III_RE to Punjab – 112 MW c) SEISPLP_MP to TPDDL – 90 MW Revision in LTA quantum of following:- a) INOX to UPPCL – 100 MW to 50 MW b) RPL-SECI-II-RE to UPPCL – 34.5 MW to 73.8 MW c) RPL-SECI-II-RE to Punjab – 73.8 MW to 100 MW d) Mahindra - Rewa UMSP to DMRC – 7.75 MW to 33 MW	WR-NR/Import of NR
			Revised STOA margin due to allocation of 100 MW quantum from NTPC-WR to Andhra Pradesh.	WR-SR/Import of SR
			Revision in TTC/ATC due to the following:- a) Non availability of 220 kV Misa-Kopili and 132 kV Khandong-Kopili link. b) Long outage of Kopili and Khandong generation due to bursting of Penstock at Kopili and c) Long Outage of Palatana Module-1 due to rotor earth fault. d) Change in Load-Generation of NER	ER-NER/NER-ER/Import-Export of NER
4	30th November 2019	01st December 2019 to 03rd December 2019	Revised due to shutdown of 765kV Agra-Jhatikara line on daily basis.	WR-NR/Import of NR
5	02nd December 2019	03rd December 2019	Revised due to non-availing shutdown of 765 kV Agra- Jhatikara line	WR-NR/Import of NR
6	5th December 2019	6th Dec 2019	Revised due to Shutdown of 400 kV Bongaigaon - Azara S/C for preventive maintenance related activities	ER-NER/NER-ER/Import-Export of NER
7	12th December 2019	13th December 2019 to 16th December 2019	Revised due to shutdown of HVDC Mundra-Mohindergarh Pole-2	WR-NR/Import of NR
8	15th December 2019	16th December 2019 to 31st December 2019	Revised due to forced outage of HVDC Bharawati Block#1 on account of Y-phase converter transformer failure	WR-SR/Import of SR
9	15th December 2019	17th December 2019 to 18th December 2019	Revised due to shutdown of HVDC Mundra-Mohindergarh Pole-1	WR-NR/Import of NR
10	18th December 2019	19th December 2019 to 21st December 2019	Revised due to shutdown of 765kV Phagi-Bhiwani-1	WR-NR/Import of NR
11	20th December 2019	21st December 2019	Revised due to shutdown of 400 kV Jeypore - G'waka-I	ER-SR/Import of SR
		22nd December 2019	Revised due to shutdown of 400 kV Jeypore - G'waka-II	
12	20th December 2019	22nd December 2019 to 23rd December 2019	Revised due to shutdown of 765kV Phagi-Bhiwani-2	WR-NR/Import of NR
13	22nd December 2019	23rd December 2019 to 24th December 2019	Revised due to shutdown of OTPC Palatana Block-2	ER-NER/NER-ER/Import-Export of NER
14	23rd December 2019	24th December 2019 to 25th December 2019	Revised due to shutdown of 400kV Angul-Bolangir line	ER-SR/Import of SR
15	26th December 2019	27th December 2019 to 29th December 2019	Revised due to shutdown of i) 400KV Jeypore – Bolangir Line on 27.12.19 & 28.12.19. ii) 400 KV Jeypore –Indravati Line on 29.12.19.	ER-SR/Import of SR

ASSUMPTIONS IN BASECASE					
				Month : December'19	
S.No.	Name of State/Area	Load		Generation	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
I	NORTHERN REGION				
1	Punjab	7977	6899	4008	3820
2	Haryana	7790	6011	1734	1734
3	Rajasthan	12153	12298	8096	8093
4	Delhi	4983	2942	718	718
5	Uttar Pradesh	14092	13018	6200	6051
6	Uttarakhand	2024	1656	764	398
7	Himachal Pradesh	1531	1094	279	197
8	Jammu & Kashmir	2344	2327	575	542
9	Chandigarh	304	172	0	0
10	ISGS/PPs	27	27	19267	12445
	Total NR	53225	46445	41640	33997
II	EASTERN REGION				
1	Bihar	4897	3256	168	161
2	Jharkhand	1228	949	369	319
3	Damodar Valley Corporation	2800	2851	4652	3775
4	Orissa	4145	2887	2847	2178
5	West Bengal	7399	5531	5024	3823
6	Sikkim	242	298	0	0
7	Bhutan	183	180	336	281
8	ISGS/PPs	641	644	12884	9320
	Total ER	21535	16597	26279	19856
III	WESTERN REGION				
1	Maharashtra	18000	15576	14005	12734
2	Gujarat	14422	14167	8700	10119
3	Madhya Pradesh	13071	10461	5848	5042
4	Chattisgarh	4019	3534	2670	2520
5	Daman and Diu	325	321	0	0
6	Dadra and Nagar Haveli	807	733	0	0
7	Goa-WR	522	463	0	0
8	ISGS/PPs	5119	4604	42069	35989
	Total WR	56284	49859	73293	66404

S.No.	Name of State/Area	Load		Generation	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
IV	SOUTHERN REGION				
1	Andhra Pradesh	10126	7849	6911	5245
2	Telangana	11656	7173	4899	4314
3	Karnataka	9505	5951	7902	4423
4	Tamil Nadu	14273	11462	6397	5897
5	Kerala	3361	2243	1475	157
6	Pondy	333	309	0	0
7	Goa-SR	65	60	0	0
8	ISGS/IPPs	0	0	18497	12129
	Total SR	49319	35047	46081	32166
V	NORTH-EASTERN REGION				
1	Arunachal Pradesh	123	70	0	0
2	Assam	1576	1047	204	176
3	Manipur	223	105	0	0
4	Meghalaya	331	257	144	33
5	Mizoram	99	69	36	28
6	Nagaland	119	79	16	0
7	Tripura	220	139	93	93
8	ISGS/IPPs	138	85	2271	1863
	Total NER	2828	1849	2764	2193
	Total All India	183191	149797	190057	154617