

National Load Despatch Centre Total Transfer Capability for Dec 2024										
Issue Date:Dec 06 2024				Issue Time:19:06:05				Revision No :21		
Corridor	Date	Time Period(hrs)	Total Transfer Capability(TTC)	Reliability Margin(RM)	Available Transfer Capability(ATC)	Approved GNA(MW)	Margin for T-GNA (MW)	Changes w.r.t. Previous Revision	Comment	
ER-NER	01 Dec to 03 Dec	00:00 to 17:00	2200	60	2140	824	1316	0		
		17:00 to 21:00	1800	60	1740	824	916	0		
		21:00 to 24:00	2200	60	2140	824	1316	0		
	04 Dec to 05 Dec	00:00 to 17:00	1200	60	1140	824	316	0		
		17:00 to 21:00	800	60	740	824	0	0		
		21:00 to 24:00	1200	60	1140	824	316	0		
	06 Dec to 06 Dec	00:00 to 09:00	1200	60	1140	824	316	0		
		09:00 to 17:00	900	60	840	824	16	0		
		17:00 to 21:00	610	60	550	824	0	0		
		21:00 to 24:00	900	60	840	824	16	0		
	07 Dec to 07 Dec	00:00 to 09:00	1200	60	1140	824	316	0		
		09:00 to 17:00	850	60	790	824	0	0		
		17:00 to 21:00	640	60	580	824	0	0		
		21:00 to 24:00	850	60	790	824	0	0		
	08 Dec to 31 Dec	00:00 to 17:00	1200	60	1140	824	316	0		
		17:00 to 21:00	800	60	740	824	0	0		
		21:00 to 24:00	1200	60	1140	824	316	0		
	ER-NR	01 Dec to 01 Dec	00:00 to 08:00	6700	400	6300	NA		0	
			08:00 to 24:00	6500	400	6100	NA		0	
	02 Dec to 03 Dec	00:00 to 08:00	6700	400	6300	NA		0		
		08:00 to 24:00	6500	400	6100	NA		0		
	04 Dec to 04 Dec	00:00 to 08:00	6700	400	6300	NA		0		
		08:00 to 09:00	6500	400	6100	NA		0		
		09:00 to 24:00	6250	400	5850	NA		0		
05 Dec to 05 Dec	00:00 to 07:00	6700	400	6300	NA		0			
	07:00 to 08:00	6100	400	5700	NA		0			
	08:00 to 24:00	5900	400	5500	NA		0			
06 Dec to 06 Dec	00:00 to 08:00	6700	400	6300	NA		0			

Corridor	Date	Time Period(hrs)	Total Transfer Capability(TTC)	Reliability Margin(RM)	Available Transfer Capability(ATC)	Approved GNA(MW)	Margin for T-GNA (MW)	Changes w.r.t. Previous Revision	Comment	
		08:00 to 24:00	6500	400	6100	NA		0		
	07 Dec to 08 Dec	00:00 to 24:00	6700	400	6300	NA		0		
	09 Dec to 09 Dec	00:00 to 09:00	6700	400	6300	NA		0		
		09:00 to 24:00	6550	400	6150	NA		-150	Shutdown Due to 765KV-GWALIOR-Phagi-2	
	10 Dec to 31 Dec	00:00 to 24:00	6700	400	6300	NA		0		
ER-SR	01 Dec to 01 Dec	00:00 to 08:00	6200	350	5850	NA		0		
		08:00 to 24:00	5400	350	5050	NA		0		
	02 Dec to 02 Dec	00:00 to 07:00	6200	350	5850	NA		0		
		07:00 to 24:00	6150	350	5800	NA		0		
	03 Dec to 03 Dec	00:00 to 07:00	6200	350	5850	NA		0		
		07:00 to 24:00	6150	350	5800	NA		0		
	04 Dec to 04 Dec	00:00 to 07:00	6150	350	5800	NA		0		
		07:00 to 24:00	6100	350	5750	NA		0		
	05 Dec to 05 Dec	00:00 to 24:00	6200	350	5850	NA		0		
	06 Dec to 06 Dec	00:00 to 08:00	6200	350	5850	NA		0		
		08:00 to 24:00	5400	350	5050	NA		0		
	07 Dec to 07 Dec	00:00 to 08:00	6200	350	5850	NA		0		
		08:00 to 24:00	6000	350	5650	NA		0		
	08 Dec to 08 Dec	00:00 to 09:00	6200	350	5850	NA		0		
		09:00 to 24:00	5400	350	5050	NA		0		
	09 Dec to 31 Dec	00:00 to 24:00	6200	350	5850	NA		0		
	ER-W3	01 Dec to 31 Dec	00:00 to 24:00	No limit is being specified.						
	ER-WR	01 Dec to 31 Dec	00:00 to 24:00	NA	NA		NA		0	
NER-ER	01 Dec to 03 Dec	00:00 to 24:00	3250	60	3190	NA		0		
	04 Dec to 05 Dec	00:00 to 24:00	3750	60	3690	NA		0		
	06 Dec to 06 Dec	00:00 to 09:00	3750	60	3690	NA		0		

Corridor	Date	Time Period(hrs)	Total Transfer Capability(TTC)	Reliability Margin(RM)	Available Transfer Capability(ATC)	Approved GNA(MW)	Margin for T-GNA (MW)	Changes w.r.t. Previous Revision	Comment	
	Dec	09:00 to 24:00	3600	60	3540	NA		0		
	07 Dec to 07 Dec	00:00 to 09:00	3750	60	3690	NA		0		
		09:00 to 24:00	3600	60	3540	NA		0		
	08 Dec to 31 Dec	00:00 to 24:00	3750	60	3690	NA		0		
NR-ER	01 Dec to 31 Dec	00:00 to 06:00	4000	300	3700	NA		0		
		06:00 to 18:00	4000	300	3700	NA		0		
		18:00 to 24:00	4000	300	3700	NA		0		
NR-WR	01 Dec to 31 Dec	00:00 to 06:00	6000	500	5500	NA		0		
		06:00 to 18:00	6000	500	5500	NA		0		
		18:00 to 24:00	6000	500	5500	NA		0		
SR-ER	01 Dec to 31 Dec	00:00 to 24:00	No limit is being specified.							
SR-WR	01 Dec to 02 Dec	00:00 to 06:00	7200	650	6550	NA		0		
		06:00 to 18:00	7100	650	6450	NA		0		
		18:00 to 24:00	7200	650	6550	NA		0		
	03 Dec to 03 Dec	00:00 to 06:00	7200	650	6550	NA		0		
		06:00 to 07:00	7100	650	6450	NA		0		
		07:00 to 18:00	6800	650	6150	NA		0		
		18:00 to 24:00	6900	650	6250	NA		0		
	04 Dec to 04 Dec	00:00 to 06:00	6900	650	6250	NA		0		
		06:00 to 18:00	6800	650	6150	NA		0		
		18:00 to 24:00	6900	650	6250	NA		0		
	05 Dec to 06 Dec	00:00 to 06:00	7200	650	6550	NA		0		
		06:00 to 18:00	7100	650	6450	NA		0		
		18:00 to 24:00	7200	650	6550	NA		0		
	07 Dec to 31 Dec	00:00 to 06:00	7200	650	6550	NA		0		
		06:00 to 18:00	7100	650	6450	NA		0		
		18:00 to 24:00	7200	650	6550	NA		0		
	W3 Injection	01 Dec to 31 Dec	00:00 to 24:00	NA	NA		NA		0	

Corridor	Date	Time Period(hrs)	Total Transfer Capability(TTC)	Reliability Margin(RM)	Available Transfer Capability(ATC)	Approved GNA(MW)	Margin for T-GNA (MW)	Changes w.r.t. Previous Revision	Comment
W3-ER	01 Dec to 31 Dec	00:00 to 24:00	No limit is being specified.						
WR-ER	01 Dec to 31 Dec	00:00 to 06:00	5500	300	5200	NA		0	
		06:00 to 18:00	5500	300	5200	NA		0	
		18:00 to 24:00	5500	300	5200	NA		0	
WR-NR	01 Nov to 01 Nov	00:00 to 08:00	22350	1000	21350	NA		0	
		08:00 to 09:00	21650	1000	20650	NA		0	
		09:00 to 15:00	18350	1000	17350	NA		0	
		15:00 to 16:00	19850	1000	18850	NA		0	
		16:00 to 24:00	21650	1000	20650	NA		0	
	02 Dec to 03 Dec	00:00 to 08:00	22350	1000	21350	NA		0	
		08:00 to 09:00	21650	1000	20650	NA		0	
		09:00 to 15:00	18350	1000	17350	NA		0	
		15:00 to 16:00	19850	1000	18850	NA		0	
		16:00 to 24:00	21650	1000	20650	NA		0	
	04 Dec to 04 Dec	00:00 to 08:00	22350	1000	21350	NA		0	
		08:00 to 09:00	21650	1000	20650	NA		0	
		09:00 to 15:00	17850	1000	16850	NA		0	
		15:00 to 16:00	19350	1000	18350	NA		0	
		16:00 to 24:00	21150	1000	20150	NA		0	
	05 Dec to 05 Dec	00:00 to 07:00	22350	1000	21350	NA		0	
		07:00 to 08:00	20800	1000	19800	NA		0	
		08:00 to 09:00	20100	1000	19100	NA		0	
		09:00 to 15:00	16800	1000	15800	NA		0	
		15:00 to 16:00	18300	1000	17300	NA		0	
		16:00 to 24:00	20100	1000	19100	NA		0	
	06 Dec to 06 Dec	00:00 to 08:00	22350	1000	21350	NA		0	
		08:00 to 09:00	21650	1000	20650	NA		0	
		09:00 to 15:00	18350	1000	17350	NA		0	
15:00 to 16:00		19850	1000	18850	NA		0		

Corridor	Date	Time Period(hrs)	Total Transfer Capability(TTC)	Reliability Margin(RM)	Available Transfer Capability(ATC)	Approved GNA(MW)	Margin for T-GNA (MW)	Changes w.r.t. Previous Revision	Comment
		16:00 to 24:00	21650	1000	20650	NA		0	
	07 Dec to 08 Dec	00:00 to 09:00	22350	1000	21350	NA		0	
		09:00 to 15:00	19050	1000	18050	NA		0	
		15:00 to 16:00	20550	1000	19550	NA		0	
		16:00 to 24:00	22350	1000	21350	NA		0	
	09 Dec to 09 Dec	00:00 to 09:00	22350	1000	21350	NA		0	
		09:00 to 15:00	18750	1000	17750	NA		-300	Shutdown Due to 765KV-GWALIOR-Phagi-2
		15:00 to 16:00	20250	1000	19250	NA		-300	
		16:00 to 24:00	22050	1000	21050	NA		-300	
	10 Dec to 31 Dec	00:00 to 09:00	22350	1000	21350	NA		0	
		09:00 to 15:00	19050	1000	18050	NA		0	
		15:00 to 16:00	20550	1000	19550	NA		0	
		16:00 to 24:00	22350	1000	21350	NA		0	
WR-SR	01 Dec to 01 Dec	00:00 to 06:00	16100	650	15450	NA		0	
		06:00 to 18:00	16100	650	15450	NA		0	
		18:00 to 24:00	16100	650	15450	NA		0	
	02 Dec to 02 Dec	00:00 to 07:00	16100	650	15450	NA		0	
		07:00 to 24:00	15550	650	14900	NA		0	
	03 Dec to 03 Dec	00:00 to 07:00	16100	650	15450	NA		0	
		07:00 to 24:00	15400	650	14750	NA		0	
	04 Dec to 04 Dec	00:00 to 07:00	15400	650	14750	NA		0	
		07:00 to 24:00	14850	650	14200	NA		0	
	05 Dec to 06 Dec	00:00 to 24:00	16100	650	15450	NA		0	
	07 Dec to 07 Dec	00:00 to 08:00	16100	650	15450	NA		0	
		08:00 to 24:00	15700	650	15050	NA		0	
	08 Dec to 31 Dec	00:00 to 24:00	16100	650	15450	NA		0	

- Based on the actual distribution of corridor flows, Counter flow benefit on account of transactions in the reverse direction would be considered for short-term transactions wherever applicable.
- Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.
- S1 comprises of Telangana, AP and Karnataka; S2 comprises of Tamil Nadu and Puducherry; S3 comprises Kerala

- W3 comprises of the following regional entities : a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) NTPC Korba I, II & III, j) NTPC Sipat I & II, k) KSK Mahanadi, l) DB Power, m) REGL (Previously KWPC), n) RKM, o) REL, p) Bharat Aluminium, q) MCCPL, r) SKS, s) TRN, t) NTPC Lara, u) Adani Power Limited Raipur and any other regional entity generator in Chhattisgarh
- The figure is based on GNA approved by CTU. In actual Operation, due to Units being on Maintenance/ Fuel shortage/New units being commissioned, the dispatches of units would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.
- In case of TTC Revision due to any shutdown : 1) The TTC value will be revised to normal values after restoration of shutdown. 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.
- Real Time TTC/ATC revisions are uploaded on Grid-India/NLDC "News Update" (Flasher) Section

Simultaneous Import Capability

Corridor	Date	Time Period(hrs)	Total Transfer Capability(TTC)	Reliability Margin(RM)	Available Transfer Capability(ATC)	Approved GNA(MW)	Margin for T-GNA (MW)	Changes w.r.t. Previous Revision	Comment	
ER	01 Dec to 31 Dec	00:00 to 24:00	NA	NA		NA		0		
NER	01 Dec to 05 Dec	00:00 to 17:00	1700	60	1640	824	816	0		
		17:00 to 21:00	1300	60	1240	824	416	0		
		21:00 to 24:00	1700	60	1640	824	816	0		
	06 Dec to 06 Dec	00:00 to 09:00	1700	60	1640	824	816	0		
		09:00 to 17:00	1400	60	1340	824	516	0		
		17:00 to 21:00	1110	60	1050	824	226	0		
		21:00 to 24:00	1400	60	1340	824	516	0		
	07 Dec to 07 Dec	00:00 to 09:00	1700	60	1640	824	816	0		
		09:00 to 17:00	1350	60	1290	824	466	0		
		17:00 to 21:00	1140	60	1080	824	256	0		
		21:00 to 24:00	1350	60	1290	824	466	0		
	08 Dec to 13 Dec	00:00 to 17:00	1700	60	1640	824	816	0		
		17:00 to 21:00	1300	60	1240	824	416	0		
		21:00 to 24:00	1700	60	1640	824	816	0		
	14 Dec to 31 Dec	00:00 to 17:00	1700	60	1640	824	816	0		
		17:00 to 21:00	1300	60	1240	824	416	0		
		21:00 to 24:00	1700	60	1640	824	816	0		
	NR	01 Dec to 01 Dec	00:00 to 08:00	25700	1400	24300	17344	6956	0	
			08:00 to 09:00	24800	1400	23400	17344	6056	0	
			09:00 to 15:00	19350	1400	17950	17344	606	0	
			15:00 to 16:00	20850	1400	19450	17344	2106	0	
			16:00 to 24:00	24800	1400	23400	17344	6056	0	
		02 Dec to 03	00:00 to 08:00	25700	1400	24300	17344	6956	0	

Corridor	Date	Time Period(hrs)	Total Transfer Capability(TTC)	Reliability Margin(RM)	Available Transfer Capability(ATC)	Approved GNA(MW)	Margin for T-GNA (MW)	Changes w.r.t. Previous Revision	Comment
	Dec	08:00 to 09:00	24800	1400	23400	17344	6056	0	
		09:00 to 15:00	19350	1400	17950	17344	606	0	
		15:00 to 16:00	20850	1400	19450	17344	2106	0	
		16:00 to 24:00	24800	1400	23400	17344	6056	0	
	04 Dec to 04 Dec	00:00 to 08:00	25700	1400	24300	17344	6956	0	
		08:00 to 09:00	24800	1400	23400	17344	6056	0	
		09:00 to 15:00	18600	1400	17200	17344	0	0	
		15:00 to 16:00	20100	1400	18700	17344	1356	0	
		16:00 to 24:00	24050	1400	22650	17344	5306	0	
	05 Dec to 05 Dec	00:00 to 07:00	25700	1400	24300	17344	6956	0	
		07:00 to 08:00	23550	1400	22150	17344	4806	0	
		08:00 to 09:00	22650	1400	21250	17344	3906	0	
		09:00 to 15:00	17200	1400	15800	17344	0	0	
		15:00 to 16:00	18700	1400	17300	17344	0	0	
		16:00 to 24:00	22650	1400	21250	17344	3906	0	
	06 Dec to 06 Dec	00:00 to 08:00	25700	1400	24300	17344	6956	0	
		08:00 to 09:00	24800	1400	23400	17344	6056	0	
		09:00 to 15:00	19350	1400	17950	17344	606	0	
		15:00 to 16:00	20850	1400	19450	17344	2106	0	
		16:00 to 24:00	24800	1400	23400	17344	6056	0	
	07 Dec to 08 Dec	00:00 to 09:00	25700	1400	24300	17344	6956	0	
		09:00 to 15:00	20250	1400	18850	17344	1506	0	
		15:00 to 16:00	21750	1400	20350	17344	3006	0	
		16:00 to 24:00	25700	1400	24300	17344	6956	0	
09 Dec to 09 Dec	00:00 to 09:00	25700	1400	24300	17344	6956	0		
	09:00 to 15:00	19800	1400	18400	17344	1056	-450	Shutdown Due to 765KV-GWALIOR-Phagi-2	
	15:00 to 16:00	21300	1400	19900	17344	2556	-450		
	16:00 to 24:00	25250	1400	23850	17344	6506	-450		
10 Dec to 31 Dec	00:00 to 09:00	25700	1400	24300	17344	6956	0		
	09:00 to 15:00	20250	1400	18850	17344	1506	0		

Corridor	Date	Time Period(hrs)	Total Transfer Capability(TTC)	Reliability Margin(RM)	Available Transfer Capability(ATC)	Approved GNA(MW)	Margin for T-GNA (MW)	Changes w.r.t. Previous Revision	Comment
		15:00 to 16:00	21750	1400	20350	17344	3006	0	
		16:00 to 24:00	25700	1400	24300	17344	6956	0	
SR	01 Dec to 01 Dec	00:00 to 08:00	22300	1000	21300	7601	13699	0	
		08:00 to 24:00	21500	1000	20500	7601	12899	0	
	02 Dec to 02 Dec	00:00 to 07:00	22300	1000	21300	7601	13699	0	
		07:00 to 24:00	21700	1000	20700	7601	13099	0	
	03 Dec to 03 Dec	00:00 to 07:00	22300	1000	21300	7601	13699	0	
		07:00 to 24:00	21550	1000	20550	7601	12949	0	
	04 Dec to 04 Dec	00:00 to 07:00	21550	1000	20550	7601	12949	0	
		07:00 to 24:00	20950	1000	19950	7601	12349	0	
	05 Dec to 05 Dec	00:00 to 24:00	22300	1000	21300	7601	13699	0	
	06 Dec to 06 Dec	00:00 to 24:00	21500	1000	20500	7601	12899	0	
	07 Dec to 07 Dec	00:00 to 08:00	22300	1000	21300	7601	13699	0	
		08:00 to 24:00	21700	1000	20700	7601	13099	0	
	08 Dec to 08 Dec	00:00 to 09:00	22300	1000	21300	7601	13699	0	
		09:00 to 24:00	21500	1000	20500	7601	12899	0	Due to shutdown of 765KV-ANGUL-SRIKAKULAM-1
09 Dec to 31 Dec	00:00 to 24:00	22300	1000	21300	7601	13699	0		
WR	01 Dec to 31 Dec	00:00 to 24:00	NA	NA		NA		0	

- Based on the actual distribution of corridor flows, Counter flow benefit on account of transactions in the reverse direction would be considered for short-term transactions wherever applicable.
- Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.
- S1 comprises of Telangana, AP and Karnataka; S2 comprises of Tamil Nadu and Puducherry; S3 comprises Kerala
- W3 comprises of the following regional entities : a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) NTPC Korba I, II & III, j) NTPC Sipat I & II, k) KSK Mahanadi, l) DB Power, m) REGL (Previously KWPC), n) RKM, o) REL, p) Bharat Aluminium, q) MCCPL, r) SKS, s) TRN, t) NTPC Lara, u) Adani Power Limited Raipur and any other regional entity generator in Chhattisgarh
- The figure is based on GNA approved by CTU. In actual Operation, due to Units being on Maintenance/ Fuel shortage/New units being commissioned, the dispatches of units would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.
- In case of TTC Revision due to any shutdown : 1) The TTC value will be revised to normal values after restoration of shutdown. 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.
- Real Time TTC/ATC revisions are uploaded on Grid-India/NLDC "News Update" (Flasher) Section

Simultaneous Export Capability

Corridor	Date	Time Period(hrs)	Total Transfer Capability(TTC)	Reliability Margin(RM)	Available Transfer Capability(ATC)	Approved GNA(MW)	Margin for T-GNA (MW)	Changes w.r.t. Previous Revision	Comment
ER	01 Dec to 31 Dec	00:00 to 24:00	NA	NA		NA		0	
NER	01 Dec to 05 Dec	00:00 to 24:00	3750	60	3690	NA		0	
	06 Dec to 06 Dec	00:00 to 09:00	3750	60	3690	NA		0	
		09:00 to 24:00	3600	60	3540	NA		0	
	07 Dec to 07 Dec	00:00 to 09:00	3750	60	3690	NA		0	
		09:00 to 24:00	3600	60	3540	NA		0	
08 Dec to 31 Dec	00:00 to 24:00	3750	60	3690	NA		0		
NR	01 Dec to 31 Dec	00:00 to 06:00	6000	500	5500	NA		0	
		06:00 to 18:00	6000	500	5500	NA		0	
		18:00 to 24:00	6000	500	5500	NA		0	
SR	01 Dec to 02 Dec	00:00 to 06:00	6400	650	5750	NA		0	
		06:00 to 18:00	6400	650	5750	NA		0	
		18:00 to 24:00	6400	650	5750	NA		0	
	03 Dec to 03 Dec	00:00 to 07:00	6400	650	5750	NA		0	
		07:00 to 24:00	6100	650	5450	NA		0	
	04 Dec to 04 Dec	00:00 to 24:00	6100	650	5450	NA		0	
	05 Dec to 06 Dec	00:00 to 24:00	6400	650	5750	NA		0	
07 Dec to 31 Dec	00:00 to 24:00	6400	650	5750	NA		0		
WR	01 Dec to 31 Dec	00:00 to 24:00	NA	NA		NA		0	

- Based on the actual distribution of corridor flows, Counter flow benefit on account of transactions in the reverse direction would be considered for short-term transactions wherever applicable.
- Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.
- S1 comprises of Telangana, AP and Karnataka; S2 comprises of Tamil Nadu and Puducherry; S3 comprises Kerala
- W3 comprises of the following regional entities : a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) NTPC Korba I, II & III, j) NTPC Sipat I & II, k) KSK Mahanadi, l) DB Power, m) REGL (Previously KWPC), n) RKM, o) REL, p) Bharat Aluminium, q) MCCPL, r) SKS, s) TRN, t) NTPC Lara, u) Adani Power Limited Raipur and any other regional entity generator in Chhattisgarh
- The figure is based on GNA approved by CTU. In actual Operation, due to Units being on Maintenance/ Fuel shortage/New units being commissioned, the dispatches of units would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.
- In case of TTC Revision due to any shutdown : 1) The TTC value will be revised to normal values after restoration of shutdown. 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.
- Real Time TTC/ATC revisions are uploaded on Grid-India/NLDC "News Update" (Flasher) Section

Limiting Constraints

Corridor	Constraints	Revisions
WR-NR	1. N-1 contingency of one ckt of 765 kV Vindhyachal-Varanasi will overload the other circuit 2. Low Voltages in major load Centres in the northern region during solar hours. 3. High loading of 765 KV Aligarh-Gr. Noida under N-1 contingency of 765 KV Bara-Mainpuri ckt	0-17,21
NR-ER	1. Overloading of one circuit of 400 kV New Ranchi – New PPSP D/C on the tripping of the other circuit 2. Overloading of one circuit of 400 kV Kahalgaon – Farakka D/C on the tripping of the other circuit 3. Overloading of 400 kV Farakka – Sagardighi – 1 on the tripping of 400 kV Farakka – Sagardighi - 2	0-17,21
WR-ER	1. Overloading of one circuit of 400 kV New Ranchi – New PPSP D/C on the tripping of the other circuit 2. Overloading of one circuit of 400 kV Kahalgaon – Farakka D/C on the tripping of the other circuit 3. Overloading of 400 kV Farakka – Sagardighi – 1 on the tripping of 400 kV Farakka – Sagardighi - 2	0-17,21
ER-NR	Inter-regional flow pattern towards NR	0-17,21
WR-SR	Outage of any one of the 2x1500 MVA, 765/400 kV ICTs at Maheswaram overloads the other ICT	0-17,21
ER-SR	1. Low Voltage at Gazuwaka (East) Bus.	0-17,21
SR-WR	a) Angular separation between Kudgi & Kolhapur (PG) under N-1 touches 30 deg. b) N-1 Contingency of 765/400 kV, 1500 MVA ICTs at Raichur - PG will overload the other circuit. c) N-1 Contingency of 400 kV Pune – Kalwa will overload 400 kV	0-17,21

Corridor	Constraints	Revisions
	Pune -Khargar & and vice-versa. d) N-1 Contingency of 400 kV Kolhapur – Karad D/C will overload the other circuit. e) N-1 non-compliance of 2*1500 MVA, 765/400 kV ICTs at Section– B at Raigarh – PS (Kotra) with operation of HVDC Raigarh – Pugalur Bipole – 1 in SR-WR direction	
ER-NER	N-1 contingency of 400 kV Bongaigaon - Azara line will lead to high Loading of 220 kV Balipara-Sonabil D/C	0-17,21
NER-ER	N-1 contingency of 400 kV Bongaigaon-Alipurduar I or II will lead to the High Loading of 400 kV Bongaigaon-Alipurduar II or I	0-17,21
NR_IMPORT	1. N-1 contingency of one ckt of 765 kV Vindhyachal-Varanasi will overload the other circuit 2. Low Voltages in major load Centres in the northern region during solar hours. 3. High loading of 765 KV Aligarh-Gr. Noida under N-1 contingency of 765 KV Bara-Mainpuri ckt	0-17,21
NR_EXPORT	Outage of any one of 765 kV Chittorgarh - Banaskantha D/C will overload 400 kV Zerda - Kankroli - 1 (Direct Line)	0-17,21
NER_IMPORT	N-1 contingency of 400 kV Bongaigaon - Azara line will lead to high Loading of 220 kV Balipara-Sonabil D/C	0-17,21
NER_EXPORT	N-1 contingency of 400 kV Bongaigaon-Alipurduar I or II will lead to the High Loading of 400 kV Bongaigaon-Alipurduar II or I	0-17,21
SR_IMPORT	1. Outage of any one of the 2x1500 MVA, 765/400 kV ICTs at Maheswaram overloads the other ICT 2. Low Voltage at Gazuwaka (East) Bus	0-17,21
SR_EXPORT	a) Angular separation between Kudgi & Kolhapur (PG) under N-1 touches 30 deg. b) N-1 Contingency of 765/400 kV, 1500 MVA ICTs at Raichur - PG will overload the other ICT. c) N-1 Contingency of 400 kV Pune – Kalwa will overload 400 kV Pune - Khargar & and vice-versa. d) N-1 Contingency of 400 kV Kolhapur – Karad D/C will overload the other circuit. e) N-1 non-compliance of 2*1500 MVA, 765/400 kV ICTs at Section– B at Raigarh – PS (Kotra) with operation of HVDC Raigarh – Pugalur Bipole – 1 in SR-WR direction	0-17,21

Revision Summary

Revision	Date Of Revision	Period Of Revision	Reason for Revision/Comment	Corridor Affected
1	26 Jan	01 Dec to 31 Dec	TTC/ATC revised in view of change in load generation balance and inter-regional flow pattern towards NR	WR-NR
		01 Dec to 31 Dec	TTC/ATC revised in view of change in load generation balance and inter-regional flow pattern towards NR	ER-NR
		01 Dec to 31 Dec	TTC/ATC increased with the Commissioning of 765/400 kV, 1500 MVA ICT - 3 at Nizamabad and Change in LGB	WR-SR
		01 Dec to 31 Dec	TTC/ATC increased with the Commissioning of 765/400 kV, 1500 MVA ICT - 3 at Nizamabad and Change in LGB	ER-SR
		01 Dec to 31 Dec	TTC/ATC revised in view of change in load generation balance and inter-regional flow pattern towards NR	NR_IMPORT
		01 Dec to 31 Dec	TTC/ATC increased with the Commissioning of 765/400 kV, 1500 MVA ICT - 3 at Nizamabad and Change in LGB	SR_IMPORT
2	28 Feb	01 Dec to 31 Dec	Revised T-GNA margin due to approval of 500 MW GNA for Andhra Pradesh from Outside Southern Region	SR_IMPORT
3	28 Mar	01 Dec to 31 Dec	Enhancement in TTC due to Bypassing of 400 kV Kankroli - Bhinmal and 400 kV Bhinmal - Zerda at Bhinmal - PG (Temporary Arrangement) & revival of 400 KV Jodhpur-Kankroli-S/C after reconductoring	NR-WR
		01 Dec to 31 Dec	Enhancement in TTC due to Bypassing of 400 kV Kankroli - Bhinmal and 400 kV Bhinmal - Zerda at Bhinmal - PG (Temporary Arrangement) & revival of 400 KV Jodhpur-Kankroli-S/C after reconductoring	NR_EXPORT
4	28 Apr	01 Dec to 31 Dec	1. Revised T-GNA margin due to approval of 6.54 MW GNA for Arunachal Pradesh from Outside North-Eastern Region. 2. Revised T-GNA margin due to approval of 371 MW GNA for Assam from Outside North-Eastern Region	NER_IMPORT
		01 Dec to 31 Dec	Revised T-GNA margin due to approval of 25 MW GNA for Goa from Outside Western Region	WR_IMPORT
		01 Dec to 31 Dec	Revised T-GNA margin due to approval of 500 MW GNA for Karnataka from Outside Southern Region	SR_IMPORT
		01 Dec to 31 Dec	Revised T-GNA margin due to approval of 24 MW GNA for West Bengal from Outside Eastern Region	ER_IMPORT
5	28 Aug	01 Dec to 31 Dec	TTC/ATC revised due to change in LGB	WR-NR
		01 Dec to 31 Dec	TTC/ATC revised due to change in LGB	SR-WR
		01 Dec to 31 Dec	TTC/ATC revised due to change in LGB	NR_IMPORT
		01 Dec to 31 Dec	TTC/ATC revised due to change in LGB	SR_EXPORT

Revision	Date Of Revision	Period Of Revision	Reason for Revision/Comment	Corridor Affected
6	29 Nov	01 Nov to 01 Nov	Due to HVDC 500KV APL POLE 1	WR-NR
		02 Dec to 31 Dec	TTC/ATC revised due to change in LGB	WR-NR
		01 Dec to 01 Dec	Due to HVDC 500KV APL POLE 1	ER-NR
		01 Dec to 01 Dec	Due to 765KV-SRIKAKULAM-ANGUL-2	ER-SR
		01 Dec to 13 Dec	TTC/ATC revised due to change in LGB	ER-NER
		01 Dec to 01 Dec	Due to HVDC 500KV APL POLE 1	NR_IMPORT
		02 Dec to 31 Dec	TTC/ATC revised due to change in LGB	NR_IMPORT
		01 Dec to 01 Dec	TTC/ATC revised due to change in LGB	NER_IMPORT
		02 Dec to 31 Dec	TTC/ATC revised due to change in LGB	NER_IMPORT
		01 Dec to 01 Dec	Due to 765KV-SRIKAKULAM-ANGUL-2	SR_IMPORT
		01 Dec to 31 Dec	TTC/ATC revised due to change in LGB	NER_EXPORT
7	30 Nov	02 Dec to 03 Dec	TTC/ATC curtailed due to shutdown of HVDC 500KV APL POLE 1	WR-NR
		02 Dec to 03 Dec	TTC/ATC curtailed due to shutdown of HVDC 500KV APL POLE 1	ER-NR
		02 Dec to 02 Dec	TTC/ATC curtailed due to shutdown of 765KV/400KV NIZAMABAD-ICT-1	WR-SR
		02 Dec to 02 Dec	TTC/ATC curtailed due to shutdown of 765KV/400KV NIZAMABAD-ICT-1	ER-SR
		02 Dec to 03 Dec	TTC/ATC curtailed due to shutdown of HVDC 500KV APL POLE 1	NR_IMPORT
		02 Dec to 02 Dec	TTC/ATC curtailed due to shutdown of 765KV/400KV NIZAMABAD-ICT-1	SR_IMPORT
8	01 Dec	03 Dec to 03 Dec	TTC/ATC curtailed due to shutdown of 400KV-BHADRAWATI HVDC-RAMAGUNDAM-1	WR-SR
		03 Dec to 03 Dec	TTC/ATC curtailed due to shutdown of 400KV-BHADRAWATI HVDC-RAMAGUNDAM-1	SR-WR
		03 Dec to 03 Dec	TTC/ATC curtailed due to shutdown of 400KV-BHADRAWATI HVDC-RAMAGUNDAM-1	ER-SR
		03 Dec to 03 Dec	TTC/ATC curtailed due to shutdown of 400KV-BHADRAWATI HVDC-RAMAGUNDAM-1	SR_IMPORT
		03 Dec to 03 Dec	TTC/ATC curtailed due to shutdown of 400KV-BHADRAWATI HVDC-RAMAGUNDAM-1	SR_EXPORT
9	02 Dec	01 Dec to 13 Dec	Due to change in LGB	ER-NER
		01 Dec to 31 Dec	Due to change in LGB	NER-ER
		01 Dec to 13 Dec	Due to change in LGB	NER_IMPORT
		01 Dec to 31 Dec	Due to change in LGB	NER_EXPORT
10	02 Dec	04 Dec to 04 Dec	Due to shutdown of HVDC 500KV APL POLE 2	WR-NR
		04 Dec to 04 Dec	Due to shutdown of 765KV-SATNA-BINA-1	WR-NR
		04 Dec to 04 Dec	Due to shutdown of HVDC 500KV APL POLE 2	ER-NR
		04 Dec to 04 Dec	Due to shutdown of 765KV-SATNA-BINA-1	ER-NR
		04 Dec to 04 Dec	Due to shutdown of 765KV/400KV NIZAMABAD-ICT-3	WR-SR

Revision	Date Of Revision	Period Of Revision	Reason for Revision/Comment	Corridor Affected
		04 Dec to 04 Dec	Due to shutdown of 765KV/400KV NIZAMABAD-ICT-3	ER-SR
		04 Dec to 04 Dec	Due to shutdown of HVDC 500KV APL POLE 2	NR_IMPORT
		04 Dec to 04 Dec	Due to shutdown of 765KV-SATNA-BINA-1	NR_IMPORT
		04 Dec to 04 Dec	Due to shutdown of 765KV/400KV NIZAMABAD-ICT-3	SR_IMPORT
11	02 Dec	04 Dec to 04 Dec	Due to shutdown of HVDC 500KV APL POLE 2	WR-NR
		04 Dec to 04 Dec	Due to shutdown of 765KV-SATNA-BINA-1	WR-NR
		04 Dec to 04 Dec	Due to shutdown of HVDC 500KV APL POLE 2	ER-NR
		04 Dec to 04 Dec	Due to shutdown of 765KV-SATNA-BINA-1	ER-NR
		04 Dec to 04 Dec	Due to shutdown of 765KV/400KV NIZAMABAD-ICT-3	WR-SR
		04 Dec to 04 Dec	Due to shutdown of 765KV/400KV NIZAMABAD-ICT-3	ER-SR
		01 Dec to 03 Dec	Due to change in LGB and Reversal of AGRA-BNC	ER-NER
		04 Dec to 31 Dec	Due to change in LGB and Reversal of AGRA-BNC	NER-ER
		04 Dec to 04 Dec	Due to shutdown of HVDC 500KV APL POLE 2	NR_IMPORT
		04 Dec to 04 Dec	Due to shutdown of 765KV-SATNA-BINA-1	NR_IMPORT
		01 Dec to 13 Dec	Due to change in LGB and Reversal of AGRA-BNC	NER_IMPORT
		04 Dec to 04 Dec	Due to shutdown of 765KV/400KV NIZAMABAD-ICT-3	SR_IMPORT
12	02 Dec	04 Dec to 04 Dec	Due to shutdown of HVDC 500KV APL POLE 2	WR-NR
		04 Dec to 04 Dec	Due to shutdown of 765KV-SATNA-BINA-1	WR-NR
		04 Dec to 04 Dec	Due to shutdown of HVDC 500KV APL POLE 2	ER-NR
		04 Dec to 04 Dec	Due to shutdown of 765KV-SATNA-BINA-1	ER-NR
		04 Dec to 04 Dec	Due to shutdown of 765KV/400KV NIZAMABAD-ICT-3	WR-SR
		04 Dec to 04 Dec	Due to shutdown of 765KV/400KV NIZAMABAD-ICT-3	ER-SR
		01 Dec to 03 Dec	Due to change in LGB and Reversal of AGRA-BNC	ER-NER
		04 Dec to 31 Dec	Due to change in LGB and Reversal of AGRA-BNC	NER-ER
		04 Dec to 04 Dec	Due to shutdown of HVDC 500KV APL POLE 2	NR_IMPORT
		04 Dec to 04 Dec	Due to shutdown of 765KV-SATNA-BINA-1	NR_IMPORT
		01 Dec to 13 Dec	Due to change in LGB and Reversal of AGRA-BNC	NER_IMPORT
		04 Dec to 04 Dec	Due to shutdown of 765KV/400KV NIZAMABAD-ICT-3	SR_IMPORT
13	03 Dec	05 Dec to 05 Dec	Due to shutdown of HVDC 500KV APL POLE 2	WR-NR
		05 Dec to 05 Dec	Due to shutdown of 765KV-SATNA-Gwalior-1	WR-NR
		05 Dec to 05 Dec	Due to shutdown of HVDC 500KV APL POLE 2	ER-NR

Revision	Date Of Revision	Period Of Revision	Reason for Revision/Comment	Corridor Affected
		05 Dec to 05 Dec	Due to shutdown of 765KV-SATNA-Gwalior-1	ER-NR
		05 Dec to 05 Dec	Due to shutdown of HVDC 500KV APL POLE 2	NR_IMPORT
		05 Dec to 05 Dec	Due to shutdown of 765KV-SATNA-Gwalior-1	NR_IMPORT
14	04 Dec	05 Dec to 06 Dec	Due to the deferment of shutdown of 400kV Bhadarwati Ramagundam -1	WR-SR
		05 Dec to 06 Dec	Due to the deferment of shutdown of 400kV Bhadarwati Ramagundam -1	SR-WR
		05 Dec to 06 Dec	Due to the deferment of shutdown of 400kV Bhadarwati Ramagundam -1	ER-SR
		05 Dec to 06 Dec	Due to the deferment of shutdown of 400kV Bhadarwati Ramagundam -1	SR_IMPORT
		05 Dec to 06 Dec	Due to the deferment of shutdown of 400kV Bhadarwati Ramagundam -1	SR_EXPORT
15	04 Dec	06 Dec to 06 Dec	Due to the shutdown of HVDC APL Pole - 2 and 765 kV Phagi - Gwalior -2	WR-NR
		06 Dec to 06 Dec	Due to the shutdown of HVDC APL Pole - 2 and 765 kV Phagi - Gwalior -2	ER-NR
		06 Dec to 06 Dec	Due to the shutdown of 765 kV Angul - Srikakulam - 1	ER-SR
		06 Dec to 06 Dec	Due to the shutdown of HVDC APL Pole - 2 and 765 kV Phagi - Gwalior -2	NR_IMPORT
		06 Dec to 06 Dec	Due to the shutdown of 765 kV Angul - Srikakulam - 1	SR_IMPORT
16	05 Dec	06 Dec to 06 Dec	Due to deferment of 765KV Phagi-Gwalior S/D	WR-NR
		06 Dec to 06 Dec	Due to deferment of 765KV Phagi-Gwalior S/D	ER-NR
		06 Dec to 06 Dec	Due to the shutdown of 765 kV Angul - Srikakulam - 1	ER-SR
		06 Dec to 06 Dec	Due to shutdown of 400kV Bongaigaon-Azara Line Reactor along with Line	ER-NER
		06 Dec to 06 Dec	Due to shutdown of 400kV Bongaigaon-Azara Line Reactor along with Line	NER-ER
		06 Dec to 06 Dec	Due to deferment of 765KV Phagi-Gwalior S/D	NR_IMPORT
		06 Dec to 06 Dec	Due to shutdown of 400kV Bongaigaon-Azara Line Reactor along with Line	NER_IMPORT
		06 Dec to 06 Dec	Due to the shutdown of 765 kV Angul - Srikakulam - 1	SR_IMPORT
		06 Dec to 06 Dec	Due to shutdown of 400kV Bongaigaon-Azara Line Reactor along with Line	NER_EXPORT
17	05 Dec	07 Dec to 07 Dec	Due to shutdown of 765KV-NIZAMABAD-WARDHA-2	WR-SR
		07 Dec to 07 Dec	Due to shutdown of 765KV-NIZAMABAD-WARDHA-2	ER-SR
		07 Dec to 07 Dec	Due to shutdown of 765KV-NIZAMABAD-WARDHA-2	SR_IMPORT
18	06 Dec	07 Dec to 07 Dec	Due to shutdown of 400kV Bongaigaon-Byrnihat Line	ER-NER
		07 Dec to 07 Dec	Due to shutdown of 400kV Bongaigaon-Byrnihat Line	NER-ER
		07 Dec to 07 Dec	Due to shutdown of 400kV Bongaigaon-Byrnihat Line	NER_IMPORT
		07 Dec to 07 Dec	Due to shutdown of 400kV Bongaigaon-Byrnihat Line	NER_EXPORT
19	06 Dec	08 Dec to 08 Dec	Due to shutdown of 765KV-ANGUL-SRIKAKULAM-1	ER-SR
		08 Dec to 08 Dec	Due to shutdown of 765KV-ANGUL-SRIKAKULAM-1	SR_IMPORT

Revision	Date Of Revision	Period Of Revision	Reason for Revision/Comment	Corridor Affected
20	07 Dec	09 Dec to 09 Dec	Due to shutdown of 765KV-GWALIOR-Phagi-2	WR-NR
		09 Dec to 09 Dec	Due to shutdown of 765KV-GWALIOR-Phagi-2	ER-NR
		09 Dec to 09 Dec	Due to shutdown of 765KV-GWALIOR-Phagi-2	NR_IMPORT
		08 Dec to 08 Dec	Due to shutdown of 765KV-ANGUL-SRIKAKULAM-1	SR_IMPORT
21	06 Dec	09 Dec to 09 Dec	Shutdown Due to 765KV-GWALIOR-Phagi-2	WR-NR
		09 Dec to 09 Dec	Shutdown Due to 765KV-GWALIOR-Phagi-2	ER-NR
		09 Dec to 09 Dec	Shutdown Due to 765KV-GWALIOR-Phagi-2	NR_IMPORT
		08 Dec to 08 Dec	Due to shutdown of 765KV-ANGUL-SRIKAKULAM-1	SR_IMPORT

ASSUMPTIONS IN BASECASE					
Month : December'24					
S.No.	Name of State/Area	Demand		Generation	
		Non-Solar Peak(MW)	Solar Peak (MW)	Non-Solar Peak(MW)	Solar Peak (MW)
I	NORTHERN REGION				
1	Punjab	6786	6770	3900	3660
2	Haryana	6932	7300	1426	3659
3	Rajasthan	13840	17619	6944	8474
4	Delhi	4003	4328	365	314
5	Uttar Pradesh	18915	17337	10369	10075
6	Uttarakhand	1977	1728	821	366
7	Himachal Pradesh	1660	1709	595	306
8	Jammu & Kashmir	2278	2673	226	230
9	Chandigarh	203	176	0	0
10	ISGS/IPPs	114	115	19978	22204
	Total NR	56708	59755	44624	49288
II	EASTERN REGION				
1	Bihar	5084	4030	445	436
2	Jharkhand	1645	1700	406	427
3	Damodar Valley Corporation	3510	3400	5600	5332
4	Orissa	6186	6000	3818	3764
5	West Bengal	7660	8000	6462	6115
6	Sikkim	106	98	0	0
7	Bhutan	33	49	307	372
8	ISGS/IPPs	920	728	16923	17242
	Total ER	25143	24005	33962	33688
III	WESTERN REGION				
1	Maharashtra	25755	29506	16723	19565
2	Gujarat	18687	20689	8270	8865
3	Madhya Pradesh	14705	17125	7923	9952
4	Chattisgarh	4208	3970	1768	1801
5	DD & DNH	971	974	0	0
6	Goa-WR	674	676	0	0
7	ISGS/IPPs	2490	2493	47245	48284
	Total WR	67491	75433	81929	88468
IV	SOUTHERN REGION				
1	Andhra Pradesh	9057	12431	5376	7080

2	Telangana	7435	9730	4578	7247
3	Karnataka	10750	13304	5081	7257
4	Tamil Nadu	16629	16830	5755	9952
5	Kerala	4253	3484	1637	646
6	Pondy	578	575	25	40
7	Goa-SR	87	87	0	0
8	ISGS/IPPs	12	12	21969	20081
	Total SR	48800	56452	44422	52305
V	NORTH-EASTERN REGION				
1	Arunachal Pradesh	164	100	0	0
2	Assam	1430	1140	271	444
3	Manipur	260	138	0	0
4	Meghalaya	468	348	139	13
5	Mizoram	169	140	31	8
6	Nagaland	157	119	14	7
7	Tripura	366	316	190	193
8	ISGS/IPPs	0	0	3215	2609
	Total NER	3014	2301	3860	3274
	Total All India	201120	217890	208385	226545