

National Load Despatch Centre
Total Transfer Capability for December 2018

Issue Date: 25th December 2018

Issue Time: 1730 hrs

Revision No. 10

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
NR-WR*	1st December 2018 to 31st December 2018	00-06	2500	500	2000	195	1805			
		06-18				250	1750			
		18-24				195	1805			
WR-NR*	1st December 2018 to 15th December 2018	00-24	12250 11300**	500	11750 10800**	9255 8305**	2495 2495**			
	16th December 2018 to 19th December 2018	00-06'	12250 11300**	500	11750 10800**	9255 8305**	2495 2495**			
		06-24'	11250 10300**	500	10750 9800**	9255 8305**	1495 1495**			
	20th December 2018 to 23th December 2018	00-06'	12250 11300**	500	11750 10800**	9255 8305**	2495 2495**			
		06-24'	11250 10300**	500	10750 9800**	9255 8305**	1495 1495**			
	24th December 2018 to 26th December 2018	00-24	12250 11300**	500	11750 10800**	9255 8305**	2495 2495**			
	27th December 2018	00-08'	12250 11300**	500	11750 10800**	9255 8305**	2495 2495**			
		08-24'	10750 9800**	500	10250 9300**	9255 8305**	995 995**	-1500	Revised due to planned outage of HVDC Champa - Kurukshetra Bipole.	
	28th December 2018	00-24	10750 9800**	500	10250 9300**	9255 8305**	995 995**			
	29th December 2018 to 31st December 2018	00-24	12250 11300**	500	11750 10800**	9255 8305**	2495 2495**			
	NR-ER*	1st December 2018 to 31st December 2018	00-06	2000	200	1800	193	1607		
			06-18	2000		1800	303	1497		
18-24			2000	1800		193	1607			
ER-NR*	1st December 2018 to 31st December 2018	00-24	5250	300	4950	3867	1083			
W3-ER	1st December 2018 to 31st December 2018	00-24	No limit is being specified.							
ER-W3	1st December 2018 to 31st December 2018	00-24	No limit is being specified.							

National Load Despatch Centre
Total Transfer Capability for December 2018

Issue Date: 25th December 2018

Issue Time: 1730 hrs

Revision No. 10

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
WR-SR	1st December 2018 to 20th December 2018	00-05	5200	500	4700	4535	165			
		05-22	5200		4700		165			
		22-24	5200		4700		165			
	21st December 2018	00-830	5200	500	4700	4535	165			
		830-22	6200		5700		1165			
		22-24	6200		5700		1165			
	22nd December 2018 to 23rd December 2018	00-05	6200	500	5700	4535	1165			
		05-22	6200		5700		1165			
		22-24	6200		5700		1165			
	24th December 2018	00-05	6200	500	5700	4535	1165			
		05-22	6200		5700		1165			
		22-24	6200		5700		1165			
	25th December 2018 to 26th December 2018	00-05	6200	500	5700	4535	1165			
		05-22	6200		5700		1165			
		22-24	6200		5700		1165			
	27th December 2018 to 31st December 2018	00-05	5200	500	4700	4535	165			
		05-22	5200		4700		165			
		22-24	5200		4700		165			
	SR-WR *	1st December 2018 to 31st December 2018	00-24	No limit is being Specified.						
	ER-SR	1st December 2018 to 20th December 2018	00-06	4800	250	4550	2762	1788		
			06-18					2847	1703	
18-24			2762					1788		
21st December 2018		00-06	4800	250	4550	2762	1788			
		06-830					2847	1703		
		830-18	3800		3550	2847	703			
		18-24	3800		3550	2762	788			
22nd December 2018 to 23rd December 2018		00-06	3800	250	3550	2762	788			
		06-18					2847	703		
		18-24					2762	788		
24th December 2018		00-06	3800	250	3550	2762	788			
		06-18					2847	703		
		18-24					2762	788		
25th December 2018 to 26th December 2018		00-06	3800	250	3550	2762	788			
		06-18					2847	703		
		18-24					2762	788		
27th December 2018 to 31st December 2018		00-06	4800	250	4550	2762	1788			
		06-18					2847	1703		
		18-24					2762	1788		

National Load Despatch Centre
Total Transfer Capability for December 2018

Issue Date: 25th December 2018

Issue Time: 1730 hrs

Revision No. 10

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
SR-ER *	1st December 2018 to 31st December 2018	00-24	No limit is being Specified.							
ER-NER	1st December 2018 to 10th December 2018	00-17	1350	45	1305	225	1080			
		17-23	1060		1015		790			
		23-24	1350		1305		1080			
	11th December 2018	00-07	1350	45	1305	225	1080			
		07-17	900		855		630			
		17-23	670		625		400			
	12th December 2018 to 18th December 2018	23-24	900	45	855	225	630			
		00-17	1350		1305		1080			
		17-23	1060		1015		790			
	19th December 2018	23-24	1350	45	1305	225	1080			
		00-07	1350		1305		1080			
		07-17	1220		1175		950			
	20th December 2018	17-23	900	45	855	225	630			
		23-24	1220		1175		950			
		00-07'	1350		1305		1080			
	21st December 2018 to 31st December 2018	07-17'	900	45	855	225	630			
		17-23	670		625		400			
		23-24	900		855		630			
	NER-ER	1st December 2018 to 10th December 2018	00-17	1880	45	1835	0	1835		
			17-23	2070		2025		2025		
			23-24	1880		1835		1835		
11th December 2018		00-07	1880	45	1835	0	1835			
		07-17	1530		1485		1485			
		17-23	1730		1685		1685			
12th December 2018 to 18th December 2018		23-24	1530	45	1485	0	1485			
		00-17	1880		1835		1835			
		17-23	2070		2025		2025			
19th December 2018		23-24	1880	45	1835	0	1835			
		00-07	1880		1835		1835			
		07-17	1700		1655		1655			
20th December 2018		17-23	1860	45	1815	0	1815			
		23-24	1700		1655		1655			
		00-07'	1880		1835		1835			
21st December 2018 to 31st December 2018		07-17'	1530	45	1485	0	1485			
		17-23	1730		1685		1685			
		23-24	1530		1485		1485			
W3 zone Injection		1st December 2018 to 31st December 2018	00-17	1880	45	1835	0	1835		
			17-23	2070		2025		2025		
			23-24	1880		1835		1835		

Note: TTC/ATC of S1-(S2&S3) corridor, Import of S3(Kerala), Import of Punjab and Import of DD & DNH is uploaded on NLDC website under Intra-Regional Section in Monthly ATC.

**National Load Despatch Centre
Total Transfer Capability for December 2018**

Issue Date: 25th December 2018

Issue Time: 1730 hrs

Revision No. 10

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
----------	------	-------------------	---------------------------------	--------------------	-------------------------------------	--	--	-------------------------------------	----------

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

**Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.

1) S1 comprises of Telangana, AP and Karnataka; S2 comprises of Tamil Nadu and Puducherry; S3 comprises Kerala

2) W3 comprises of the following regional entities :

a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak
f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, l)DB Power, m) KWPCCL, n)Vandana Vidyut o)RKM, p)GMR Raikhed, q)Ind Barath and any other regional entity generator in Chhattisgarh

The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/ Fuel shortage/New units being commissioned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis.

In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

In case of TTC Revision due to any shutdown :

1) The TTC value will be revised to normal values after restoration of shutdown.

2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.

Simultaneous Import Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER									
NR	1st December 2018 to 15th December 2018	00-05	16350	800	15550	13147 12197**	2403		
			15400**		14600**		2403**		
		05-18	17500		16700		3553		
			16550**		15750**		3553**		
	18-24	16350	15550	2403					
		15400**	14600**	2403**					
	16th December 2018 to 19th December 2018	00-05	16350	800	15550	13147 12197**	2403		
			15400**		14600**		2403**		
		05-06	17500		16700		3553		
			16550**		15750**		3553**		
	06-18	16050	15250	2103					
		15100**	14300**	2103**					
18-24	15000	14200	1053						
	14050**	13250**	1053**						
20th December 2018	00-05	16350	800	15550	13147 12197**	2403			
		15400**		14600**		2403**			
	05-06	17500		16700		3553			
		16550**		15750**		3553**			
06-18	16050	15250	2103						
	15100**	14300**	2103**						
18-24	15000	14200	1053						
	14050**	13250**	1053**						

NR	21s December 2018 to 23rd December 2018	00-05	16350	800	15550	13147	2403		12197**	
			15400**		14600**		2403**			
		05-06	16350		15550		2403			
			15400**		14600**		2403**			
		06-17	16050		15250		2103			
	15100**		14300**	2103**						
	17-18	14400	13600	453						
		13450**	12650**	453**						
	18-24	14400	13600	453						
		13450**	12650**	453**						
	24th December 2018 to 26th December 2018	00-05	16350	800	15550	13147	2403		12197**	
			15400**		14600**		2403**			
		05-06	16350		15550		2403			
			15400**		14600**		2403**			
		06-17	17500		16700		3553			
16550**	15750**		3553**							
17-18	15700	14900	1753							
	14750**	13950**	1753**							
18-24	15700	14900	1753							
	14750**	13950**	1753**							
27th December 2018	00-05	16350	800	15550	13147	2403		12197**		
		15400**		14600**		2403**				
	05-06	16350		15550		2403				
		15400**		14600**		2403**				
	06-08	17500		16700		3553				
		16550**		15750**		3553**				
08-17	15350	14550	1403	-2150						
	14400**	13600**	1403**							
17-18	13800	13000	0	-1900						
	12850**	12050**	0**							
18-24	13800	13000	0	-1900						
	12850**	12050**	0**							

Revised due to planned outage of HVDC Champa - Kurukshetra Bipole.

NR	28th December 2018	00-05	14350 13400**	800	13550 12600**	13147 12197**	403 403**	-2000	Revised due to planned outage of HVDC Champa - Kurukshetra Bipole.	
		05-06	14350 13400**		13550 12600**		403 403**	-2000		
		06-17	15350 14400**		14550 13600**		1403 1403**	-2150		
		17-18	13800 12850**		13000 12050**		0 0**	-1900		
		18-24	13800 12850**		13000 12050**		0 0**	-1900		
	29th December 2018 to 31st December 2018	00-05	16350 15400**	800	15550 14600**	13147 12197**	2403 2403**			
		05-06	16350 15400**		15550 14600**		2403 2403**			
		06-17	17500 16550**		16700 15750**		3553 3553**			
		17-18	15700 14750**		14900 13950**		1753 1753**			
		18-24	15700 14750**		14900 13950**		1753 1753**			
NER	1st December 2018 to 10th December 2018	00-17	1350	45	1305	225	1080			
		17-23	1060		1015		790			
		23-24	1350		1305		1080			
	11th December 2018	00-07	1350	45	1305	225	1080			
		07-17	900		855		630			
		17-23	670		625		400			
	23-24	23-24	900		855		630			
		12th December 2018 to 18th December 2018	00-17	1350	45	1305	225	1080		
			17-23	1060		1015		790		
	23-24		1350	1305		1080				
	19th December 2018	00-07	1350	45	1305	225	1080			
		07-17	1220		1175		950			
		17-23	900		855		630			
		23-24	1220		1175		950			
	20th December 2018	00-07'	1350	45	1305	225	1080			
		07-17'	900		855		630			
		17-23	670		625		400			
		23-24	900		855		630			
21st December 2018 to 31st December 2018	00-17	1350	45	1305	225	1080				
	17-23	1060		1015		790				
	23-24	1350		1305		1080				

WR								
SR	1st December 2018 to 31st December 2018	06-18	10000	750	9250	7297	1953	
		18-22	10000		9250	7382	1868	
		22-24	10000		9250	7297	1953	

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

**Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.

* For approving STOA Bilateral transactions, margin available in Simultaneous Import of NR would be apportioned on WR-NR Corridor & ER-NR Corridor in the following ratio:

Margin in Simultaneous import of NR = A

WR-NR ATC = B

ER-NR ATC = C

Margin for WR-NR applicants = $A * B / (B+C)$

Margin for ER-NR Applicants = $A * C / (B+C)$

Simultaneous Export Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
NR*	1st December 2018 to 31st December 2018	00-06	4500	700	3800	388	3412			
		06-18			3800	553	3247			
		18-24			3800	388	3412			
NER	1st December 2018 to 10th December 2018	00-17	1880	45	1835	0	1835			
		17-23	2070		2025		2025			
		23-24	1880		1835		1835			
	11th December 2018	00-07	1880	45	1835	0	1835			
		07-17	1530		1485		1485			
		17-23	1730		1685		1685			
		23-24	1530		1485		1485			
	12th December 2018 to 18th December 2018	00-17	1880	45	1835	0	1835			
		17-23	2070		2025		2025			
		23-24	1880		1835		1835			
	19th December 2018	00-07	1880	45	1835	0	1835			
		07-17	1700		1655		1655			
		17-23	1860		1815		1815			
		23-24	1700		1655		1655			
	20th December 2018	00-07	1880	45	1835	0	1835			
		07-17	1530		1485		1485			
		17-23	1730		1685		1685			
		23-24	1530		1485		1485			
	21st December 2018 to 31st December 2018	00-17	1880	45	1835	0	1835			
		17-23	2070		2025		2025			
		23-24	1880		1835		1835			
	WR									
	SR *	1st December 2018 to 31st December 2018	00-24	No limit is being Specified.						

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Limiting Constraints (Corridor wise)

Corridor	Constraint	Applicable Revisions
NR-WR	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak	Rev-0 to 10
WR-NR	(n-1) Contingency of 765kV Aligarh-Jhatikara leads to 2500 MW loading on 765kV Aligarh-Greater Noida.	Rev-0 to 2,8-10
	(n-1) Contingency of 765/400kV ICT-1 at Agra leads to 1500 MW loading on other 765kV ICT at Agra.	Rev-3 to 7
	Frequent tripping of HVDC Champa - Kurukshetra poles	Rev-0 to 5
	RVO operation of HVDC Champa Kurukshetra Poles Reversal of BNC-Agra pole towards BNC & blocking of APD-Agra pole due to lean hydro period in NER	Rev-6-9
NR-ER	(n-1) contingency of 400 kV Saranath-Pusauli	Rev-0 to 10
ER-NR	1. N-1 contingencies of 400 kv Mejia-Maithon A S/c 2. N-1 contingencies of 400 kv Kahalgaon-Banka S/c 3. N-1 contingencies of 400kV MPL- Maithon S/C	Rev-0 to 10
WR-SR and ER-SR	n-1 contingency of 2x1500 MVA, 765/400 kV ICTs at Vemagiri (PG) will lead to overloading of the second ICT	Rev-0 to 9
	n-1 contingency of 2x315 MVA, 400/220 kV ICTs at Maradam will lead to overloading of the second ICT	Rev-1 to 10
	Low Voltage at Gazuwaka (East) Bus.	Rev-0 to 10
ER-NER	a. (n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa b. High loading of 220 kV Balipara-Sonabil line(200 MW)	Rev-0 to 10
NER-ER	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other ICT at Misa	Rev-0 to 10
W3 zone Injection	---	Rev-0 to 10

Limiting Constraints (Simultaneous)

		Applicable Revisions	
NR	Import	1. N-1 contingencies of 400 kv Mejia-Maithon A S/c 2. N-1 contingencies of 400 kv Kahalgaon-Banka S/c 3. N-1 contingencies of 400kV MPL- Maithon S/c	Rev-0 to 10
		(n-1) Contingency of 765kV Aligarh-Jhatikara leads to 2500 MW loading on 765kV Aligarh-Greater Noida.	Rev-0 to 2,8-10
		(n-1) Contingency of 765/400kV ICT-1 at Agra leads to 1500 MW loading on other 765kV ICT at Agra.	Rev-3 to 7
	Export	Frequent tripping of HVDC Champa - Kurukshetra poles	Rev-0 to 5
		RVO operation of HVDC Champa Kurukshetra Poles Reversal of BNC-Agra pole towards BNC & blocking of APD-Agra pole due to lean hydro period in NER	Rev- 6-9
		(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.	Rev-0 to 10
		(n-1) contingency of 400 kV Saranath-Pusauli	
NER	Import	a. (n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa b. High loading of 220 kV Balipara-Sonabil line(200 MW)	Rev-0 to 10
	Export	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other ICT at Misa	Rev-0 to 10
SR	Import	n-1 contingency of 2x1500 MVA, 765/400 kV ICTs at Vemagiri (PG) will lead to overloading of the second ICT	Rev-0 to 9
		n-1 contingency of 2x315 MVA, 400/220 kV ICTs at Maradam will lead to overloading of the second ICT	Rev-1 to 10
		Low Voltage at Gazuwaka (East) Bus.	Rev-1 to 10

**National Load Despatch Centre
Total Transfer Capability for December 2018**

Revision No	Date of Revision	Period of Revision	Reason for Revision/Comment	Corridor Affected
1	26th Nov 2018	Whole month	(i) Revised TTC due to change in: (a) load generation balance and network conditions and (b) change in pattern of inter-regional flow towards NR (ii) Revised STOA margins due to operationalization of : (a) 50 MW LTA from Green Infra Energy Limited to Delhi, (b) 99.9 MW LTA from Green Infra Energy Limited to UP (c) 20 MW LTA from OKWPL to UP discom	WR-NR/ Import of NR
			Revised considering (a) recent commissioning of 765 kV Jharsuguda - Dharamjaygarh 3&4, 765 kV Gadawara - Warora PS D/C, 765 kV Warora PS - Parli D/C, LILO of Kurnool - Thirvualam D/C at Cuddapah, 400 kV Cuddapah-Hindupur D/C, Salem PS - Madhugiri PS S/C, 765 kV Dharamjaigarh - Champa S/C, 765 kV Champa-Raigarh S/C and 765 kV Sipat-Bilaspur ckt-3 and some other 400 kV lines	WR-SR/ER-SR/Import of SR
2	10th Dec 2018	11th Dec 2018	Revised TTC due to day time shutdown of 400/220kV 315MVA ICT-2 at Misa(PG) for annual maintenance	ER-NER/NER-ER/Import/Export of NER
3	14th Dec 2018	16th Dec 2018 to 19th Dec 2018	Revised due to shutdown of HVDC Mundra-Mohindergarh Pole-1	WR-NR/Import of NR
4	18th Dec 2018	19th Dec 2018	Revised TTC due to day time shutdown of 400 kV Bongaigaon - Azara for dismantling the failed Line Reactor at Bongaigaon S/s	ER-NER/NER-ER/Import/Export of NER
5	19th Dec 2018	20th Dec 2018 to 23th Dec 2018	Revised due to shutdown of HVDC Mundra-Mohindergarh Pole-2	WR-NR/Import of NR
		20th Dec 2018	Revised due to shutdown of 400 kV Misa- Balipara ckt I for Replacement of Y-Ph LA at Balipara Substation	ER-NER/NER-ER/Import/Export of NER
6	19th Dec 2018	21st Dec 2018 to 31st Dec 2018	Revised due to change in pattern of inter-regional flow towards NR	WR-NR/Import of NR
7	20th Dec 2018	21st Dec 2018 to 23rd Dec 2018	Revised due to urgent shutdown of 765kV Bus-1 at Srikakulam	ER-SR/WR-SR
8	23rd Dec 2018	24th Dec 2018	Revised due to urgent shutdown of 765kV Bus-1 at Srikakulam	ER-SR/WR-SR
9	24th Dec 2018	25th Dec 2018 and 26th Dec 2018	Revised due to extension in urgent shutdown of 765kV Bus-1 at Srikakulam	ER-SR/WR-SR
10	25th Dec 2018	27th Dec 2018 and 28th Dec 2018	Revised due to planned outage of HVDC Champa - Kurukshetra Bipole.	WR-NR/NR Import

ASSUMPTIONS IN BASECASE					
				Month : December'18	
S.No.	Name of State/Area	Load		Generation	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
I	NORTHERN REGION				
1	Punjab	7121	4573	4602	4217
2	Haryana	7810	5484	2002	2002
3	Rajasthan	11766	12065	7031	6910
4	Delhi	4670	2505	1266	1266
5	Uttar Pradesh	14350	14457	7408	7224
6	Uttarakhand	2083	1622	946	685
7	Himachal Pradesh	1554	739	224	157
8	Jammu & Kashmir	2098	1610	374	306
9	Chandigarh	258	130	0	0
10	ISGS/IPPs	54	53	18132	10730
	Total NR	51764	43237	41985	33497
II	EASTERN REGION				
1	Bihar	3453	2410	247	177
2	Jharkhand	975	812	360	223
3	Damodar Valley Corporation	2946	2756	5213	4002
4	Orissa	3715	2991	2344	2044
5	West Bengal	7102	5253	5189	4516
6	Sikkim	76	82	0	0
7	Bhutan	202	208	643	534
8	ISGS/IPPs	692	643	12290	9301
	Total ER	19160	15155	26285	20796
III	WESTERN REGION				
1	Maharashtra	18572	12992	13651	8562
2	Gujarat	13543	11084	8764	8072
3	Madhya Pradesh	12461	8848	4689	4821
4	Chattisgarh	3918	2719	2751	2152
5	Daman and Diu	329	263	0	0
6	Dadra and Nagar Haveli	815	686	0	0
7	Goa-WR	527	325	0	0
8	ISGS/IPPs	4485	3475	38213	30169
	Total WR	54650	40392	68068	53776

S.No.	Name of State/Area	Load		Generation	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
IV	SOUTHERN REGION				
1	Andhra Pradesh	8873	6394	6225	4712
2	Telangana	10073	8339	4311	3808
3	Karnataka	9928	6077	6500	4842
4	Tamil Nadu	13905	11359	6899	5799
5	Kerala	3745	2119	1524	153
6	Pondy	340	368	0	0
7	Goa-SR	77	83	0	0
8	ISGS/IPPs	0	0	16984	10353
	Total SR	46942	34739	42443	29668
V	NORTH-EASTERN REGION				
1	Arunachal Pradesh	141	88	0	0
2	Assam	1235	1119	185	142
3	Manipur	179	96	0	0
4	Meghalaya	357	230	169	91
5	Mizoram	98	66	8	8
6	Nagaland	121	77	16	0
7	Tripura	194	120	74	74
8	ISGS/IPPs	156	96	2042	1566
	Total NER	2481	1893	2494	1881
	Total All India	174998	135416	181276	139618