

**National Load Despatch Centre**  
**Total Transfer Capability for December 2021**

Issue Date: 28th October, 2021

Issue Time: 1700 hrs

Revision No. 3

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
NR-WR*	1st December 2021 to 31st December 2021	00-06	2500	500	2000	378	1622			
		06-18				956	1044			
		18-24				378	1622			
WR-NR*	1st December 2021 to 31st December 2021	00-06	19500	1000	18500	11412	7088		Revised STOA margin due to a) Operationalization of LTA OF 39 MW from PGLR_SREPL to UPPCL b) Operationalization of LTA OF 11 MW from Tuticorin-BETAMWIND to UPPCL	
		06-18	18550**	1000	17550**	11801	6699			
		18-24	18550**	1000	17550**	11412	7088			
NR-ER*	1st December 2021 to 31st December 2021	00-06	2000	200	1800	93	1707		Revised STOA margin due to operationalization of new LTA of 33 MW from AP41PL_BHDL to ODISHA	
		06-18	2000			1800	1491	309		
		18-24	2000			1800	93	1707		
ER-NR*	1st December 2021 to 31st December 2021	00-24	5900	400	5500	4322	1178		Revised STOA margin due to discontinuation of 50 MW MTOA Arunachal Pradesh to NPCL(UP)	
W3-ER	1st December 2021 to 31st December 2021	00-24	No limit is being specified.							
ER-W3	1st December 2021 to 31st December 2021	00-24	No limit is being specified.							
WR-SR <sup>^</sup>	1st December 2021 to 31st December 2021	00-05	10350	650	9700	3880	5820			
		05-22	10350				9700	5820		
		22-24	10350				9700	5820		
SR-WR *	1st December 2021 to 31st December 2021	00-24	4600	400	4200	913	3287		Revised STOA margin due to a) Operationalization of LTA OF 5 MW from BETAM to UP (NR) b) Operationalization of LTA OF 24 MW from Spring energy to UP (NR)	
ER-SR <sup>^</sup>	1st December 2021 to 31st December 2021	00-06	5800	350	5450	2672	2778			
		06-18				2757	2693			
		18-24				2672	2778			
SR-ER *	1st December 2021 to 31st December 2021	00-24	No limit is being Specified.							
ER-NER*	1st December 2021 to 31st December 2021	00-02	810	45	765	455	310			
		02-07	810				765	455		310
		07-12	805				760	455		305
		12-18	820				775	455		320
		18-22	610				565	455		110
		22-24	810				765	455		310
NER-ER*	1st December 2021 to 31st December 2021	00-02	3280	45	3235	81	3154			
		02-07	3280				3235	81		3154
		07-12	3230				3185	81		3104
		12-18	3270				3225	81		3144
		18-22	3240				3195	81		3114
		22-24	3280				3235	81		3154

**National Load Despatch Centre**  
**Total Transfer Capability for December 2021**

Issue Date: 28th October, 2021

Issue Time: 1700 hrs

Revision No. 3

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
----------	------	-------------------	---------------------------------	--------------------	-------------------------------------	----------------------------------------------------------	----------------------------------------------------	-------------------------------------	----------

<b>W3 zone Injection</b>	1st December 2021 to 31st December 2021	00-24	No limit is being specified (In case of any constraints appearing in the system, W3 zone export would be revised accordingly)						
--------------------------	-----------------------------------------	-------	-------------------------------------------------------------------------------------------------------------------------------	--	--	--	--	--	--

**Note: TTC/ATC of S1-(S2&S3) corridor, Import of S3(Kerala), Import of Punjab and Import of DD & DNH is uploaded on NLDC website under Intra-Regional Section in Monthly ATC.**

\* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

\*\*Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.

1) S1 comprises of Telangana, AP and Karnataka; S2 comprises of Tamil Nadu and Puducherry; S3 comprises Kerala

2) W3 comprises of the following regional entities :

a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak  
 f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPC, n)Vandana Vidut o)RKM, p)GMR Raikhed, q)Ind Barath  
 and any other regional entity generator in Chhattisgarh

# The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/ Fuel shortage/New units being commissioned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

In case of TTC Revision due to any shutdown :

- 1) The TTC value will be revised to normal values after restoration of shutdown.
- 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.

Real Time TTC/ATC revisions are uploaded on POSOCO/NLDC "News Update" (Flasher) Section

^Though 2X315 MVA, 400/220 kV ICTs at Maradam are N-1 non-compliant, the TTC of WR-SR and ER-SR corridor has not been restricted due to the same considering that this aspect will be managed by AP SLDC through appropriate measures like SPS implementation.

^In case of drawl of Karnataka beyond 3800 MW, the voltages in Bengaluru area are observed to be critically low. This issue may be taken care of by Karnataka SLDC by taking appropriate measures.

SR-WR TTC/ATC figures have been calculated considering 01 unit (800 MW) at Kudgi TPS in service. The figures are subject to change with change in generation at Kudgi TPS.

WR-NR/Import of NR TTC has been calculated considering generation at Pariccha TPS as 350 MW. TTC figures are subject to change with significant change in generation at Pariccha TPS.

Simultaneous Import Capability									
Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR	1st December 2021 to 31st December 2021	00-06	25400 24450**	1400	24000 23050**	15734 14784**	8266		a) operationalization of LTA OF 39 MW from PGLR_SREPL to UPPCL b) operationalization of LTA OF 11 MW from Tuticorin-BETAMWIND to UPPCL c) Discontinuation of 50 MW MTOA Arunachal Pradesh to NPCL(UP)
		06-09	25400 24450**		24000 23050**	16123 15173**	7877		
		09-17	25400 24450**		24000 23050**	16123 15173**	7877		
		17-18	25400 24450**		24000 23050**	16123 15173**	7877		
		18-24	25400 24450**		24000 23050**	15734 14784**	8266		
NER*	1st December 2021 to 31st December 2021	00-02	810	45	765	455	310		
		02-07	810		765	455	310		
		07-12	805		760	455	305		
		12-18	820		775	455	320		
		18-22	610		565	455	110		
		22-24	810		765	455	310		
WR*									
SR#	1st December 2021 to 31st December 2021	00-06	16150	1000	15150	6553	8597		
		06-18	16150		15150	6638	8512		
		18-24	16150		15150	6553	8597		
* Fifty Percent (50 % ) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).									
**Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.									
* For approving STOA Bilateral transactions, margin available in Simultaneous Import of NR would be apportioned on WR-NR Corridor & ER-NR Corridor in the following ratio: Margin in Simultaneous import of NR = A WR-NR ATC =B ER-NR ATC = C  Margin for WR-NR applicants = A * B/(B+C) Margin for ER-NR Applicants = A * C/(B+C)									
Real Time TTC/ATC revisions are uploaded on POSOCO/NLDC "News Update" (Flasher) Section									
#Though 2X315 MVA, 400/220 kV ICTs at Maradam are N-1 non-compliant, the TTC of SR Import has not been restricted due to the same considering that this aspect will be managed by AP SLDC through appropriate measures like SPS implementation.									
In case of drawl of Karnataka beyond 3800 MW, the voltages in Bengaluru area are observed to be critically low. This issue may be taken care of by Karnataka by taking appropriate measures.									
WR-NR/Import of NR TTC has been calculated considering generation at Pariccha TPS as 350 MW. TTC figures are subject to change with significant change in generation at Pariccha TPS.									

**Simultaneous Export Capability**

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR*	1st December 2021 to 31st December 2021	00-06	4500	700	3800	471	3329		Revised STOA margin due to operationalization of new LTA of 33 MW from AP41PL_BHDL to ODISHA
		06-18				2447	1353		
		18-24				471	3329		
NER*	1st December 2021 to 31st December 2021	00-02	3280	45	3235	81	3154		
		02-07	3280			81	3154		
		07-12	3230			81	3104		
		12-18	3270			81	3144		
		18-22	3240			81	3114		
		22-24	3280			81	3154		
WR*									
SR*^	1st December 2021 to 31st December 2021	00-24	3700	400	3300	1731	1569		Revised STOA margin due to a) Operationalization of LTA of 24 MW from Spring energy to UP (NR) b) Operationalization of LTA of 5 MW from BETAM to UP (NR) c) Operationalization of LTA of 5 MW from BETAM to Odisha (ER) d) Operationalization of LTA of 21 MW from Hiriyur_Ostrokannada to Bihar (ER)

\* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Real Time TTC/ATC revisions are uploaded on POSOCO/NLDC "News Update" (Flasher) Section

^SR Export TTC/ATC figures have been calculated considering 01 unit (800 MW) at Kudgi TPS in service. The figures are subject to change with change in generation at Kudgi TPS.

<b>Limiting Constraints (Corridor wise)</b>			<b>Applicable Revisions</b>
<b>Corridor</b>	<b>Constraint</b>		
<b>WR-NR</b>	N-1 contingency of one ckt of 765 kV Vindhyachal-Varanasi will overload the other circuit		Rev- 0 to 3
<b>NR-ER</b>	(n-1) contingency of 400 kV Saranath-Pusauli		Rev- 0 to 3
<b>ER-NR</b>	Inter-regional flow pattern towards NR		Rev- 0 to 3
<b>WR-SR and ER-SR</b>	N-1 of one ICT of 765/400 kV, 1500 MVA ICT at Nizamabad will overload the other ICT		Rev- 0
	N-1 of one ckt of 765kV Angul-Srikakulam D/C will overload the other circuit		
	Low Voltage at Gazuwaka (East) Bus.		Rev- 1 to 3
	N-1 of one ICT of 765/400 kV, 1500 MVA ICT at Nizamabad will overload the other ICT		
Low Voltage at Gazuwaka (East) Bus.			
<b>SR-WR</b>	a) N-1 contingency of one ckt of 400 kV Kolhapur-PG - Kolhapur-MS D/C will overload of the other ckt b) N-1 contingency of 500 MVA ICT at 400 kV Kolhapur-MS will overload the other 2x315 MVA ICTs		Rev- 0 to 3
<b>ER-NER</b>	a) N-1 contingency of 400 kV Bongaigaon - Azara line b) High Loading of 220 kV Salakati - BTPS D/C		Rev- 0 to 3
<b>NER-ER</b>	a) N-1 contingency of 220 kV Salakati - Alipurduar I or II b) High Loading of 220 kV Salakati - Alipurduar II or I		Rev- 0 to 3
<b>W3 zone Injection</b>	---		Rev- 0 to 3
<b>Limiting Constraints (Simultaneous)</b>			<b>Applicable Revisions</b>
<b>NR</b>	<b>Import</b>	Inter-regional flow pattern towards NR	Rev- 0 to 3
	<b>Export</b>	(n-1) contingency of one ckt of 765 kV Vindhyachal-Varanasi will overload the other circuit	Rev- 0 to 3
<b>NER</b>	<b>Import</b>	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak. (n-1) contingency of 400 kV Saranath-Pusauli	Rev- 0 to 3
	<b>Export</b>	a) N-1 contingency of 400 kV Bongaigaon - Killing line (0000 hrs to 2400 hrs) b) High Loading of 220 kV Balipara-Sonabil (0000 hrs to 0700 hrs) c) High Loading of 220 kV Salakati - BTPS D/C (0700 hrs to 1200 hrs)	Rev- 0 to 3
<b>SR</b>	<b>Import</b>	a) N-1 contingency of 220 kV Salakati - Alipurduar I or II b) High Loading of 220 kV Salakati - Alipurduar II or I	Rev- 0 to 3
		N-1 of one ICT of 765/400 kV, 1500 MVA ICT at Nizamabad will overload the other ICT	Rev- 0
	N-1 of one ckt of 765kV Angul-Srikakulam D/C will overload the other circuit		
	<b>Export</b>	Low Voltage at Gazuwaka (East) Bus. N-1 of one ICT of 765/400 kV, 1500 MVA ICT at Nizamabad will overload the other ICT	Rev-1 to 3
<b>Export</b>	Low Voltage at Gazuwaka (East) Bus.		Rev- 0 to 3
	N-1 contingency of one ckt of 400 kV Kolhapur-PG - Kolhapur-MS D/C will overload of the other ckt N-1 contingency of 500 MVA ICT at 400 kV Kolhapur-MS will overload the other 2x315 MVA ICTs		

**National Load Despatch Centre**  
**Total Transfer Capability for December 2021**

Revision No	Date of Revision	Period of Revision	Reason for Revision/Comment	Corridor Affected
1	25th September 2021	Whole Month	TTC/ATC revised due to commissioning of HVDC Raigarh-Pugalur Pole-3	WR-SR/ER-SR/SR Import
2	28th September 2021	Whole Month	Revised STOA margin due to a)operationalization of new LTA OF 73 MW from Tuticorin-BETAMWIND to UPPCL b)operationalization of new LTA OF 10 MW from Tuticorin-IWISL to Haryana	WR-NR/NR Import
			Revised STOA margin due to a) Discontinuation of 250 MW MTOA from ACSEPL to Madhya Pradesh b) Operationalization of new LTA of 250 MW from RSWPL3_FTG2 to BSPHCL c) Operationalization of new LTA of 300 MW from AP43PL_BKN to Odisha	ER-NR/WR-NR/NR Export
			Revised STOA margin due to a)operationalization of new LTA of 106 MW from Fatehgarh-II Solar to Telangana b) operationalization of new LTA of 176 MW from Bhadla-II Solar to Telangana	WR-SR/SR Import
			Revised STOA margin due to a) Increase LTA by 6 MW from BETAM to UP (NR) b) Increase LTA by 15 MW from Spring Energy,Pugalur to UP (NR) c) Operationalization of 63 MW LTA fromHIRIYUR_OSTROKANNADA to Bihar, ER	SR-WR/SR Export
			Revised STOA margin due to discontinuation of 50 MW MTOA Arunachal Pradesh to NPCL(UP)	NER-ER/NER Export
5	28th October 2021	Whole Month	Revised STOA margin due to a) Operationalization of LTA OF 39 MW from PGLR_SREPL to UPPCL b) Operationalization of LTA OF 11 MW from Tuticorin-BETAMWIND to UPPCL c) Discontinuation of 50 MW MTOA Arunachal Pradesh to NPCL(UP)	WR-NR/ER-NR/NR Import
			Revised STOA margin due to operationalization of new LTA of 33 MW from AP41PL_BHDL to ODISHA	NR-ER/NR Export
			Revised STOA margin due to a) Operationalization of LTA of 24 MW from Spring energy to UP (NR) b) Operationalization of LTA of 5 MW from BETAM to UP (NR) c) Operationalization of LTA of 5 MW from BETAM to Odisha (ER) d) Operationalization of LTA of 21 MW from HiriYur_Ostrokannada to Bihar (ER)	SR-WR/SR-ER/SR Export

ASSUMPTIONS IN BASECASE					
				Month : December 2021	
S.No.	Name of State/Area	Load		Generation	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
I	<b>NORTHERN REGION</b>				
1	Punjab	10744	10867	3971	3971
2	Haryana	9492	9088	2701	2701
3	Rajasthan	10485	9635	8259	8259
4	Delhi	5321	5152	796	795
5	Uttar Pradesh	20631	20099	10623	10689
6	Uttarakhand	2124	1886	928	939
7	Himachal Pradesh	1354	1114	783	769
8	Jammu & Kashmir	2363	1962	884	883
9	Chandigarh	313	249	0	0
10	ISGS/IPPs	48	48	21958	20013
	<b>Total NR</b>	<b>62875</b>	<b>60100</b>	<b>50903</b>	<b>49019</b>
II	<b>EASTERN REGION</b>				
1	Bihar	6537	5617	356	349
2	Jharkhand	1958	1503	511	501
3	Damodar Valley Corporation	2985	2723	5856	4190
4	Orissa	4513	4310	3998	3798
5	West Bengal	9704	8401	7033	6210
6	Sikkim	119	116	0	0
7	Bhutan	181	181	2325	2325
8	ISGS/IPPs	810	810	15771	11533
	<b>Total ER</b>	<b>26808</b>	<b>23662</b>	<b>35850</b>	<b>28906</b>
III	<b>WESTERN REGION</b>				
1	Maharashtra	17405	16509	11624	10789
2	Gujarat	13918	11320	8601	7246
3	Madhya Pradesh	9254	8534	3596	3845
4	Chattisgarh	4309	3965	2531	2835
5	Daman and Diu	276	236	0	0
6	Dadra and Nagar Haveli	744	870	0	0
7	Goa-WR	534	420	0	0
8	ISGS/IPPs	1784	3263	36712	32338
	<b>Total WR</b>	<b>48224</b>	<b>45117</b>	<b>63064</b>	<b>57053</b>
IV	<b>SOUTHERN REGION</b>				
1	Andhra Pradesh	8024	7220	6268	5204
2	Telangana	9100	8117	5196	5078
3	Karnataka	8396	6654	6023	4850
4	Tamil Nadu	15210	13068	7256	6376
5	Kerala	3778	2349	1614	961
6	Pondy	264	264	0	0
7	Goa-SR	82	82	0	0
8	ISGS/IPPs	37	37	14805	14794
	<b>Total SR</b>	<b>44891</b>	<b>37791</b>	<b>41162</b>	<b>37263</b>
V	<b>NORTH-EASTERN REGION</b>				
1	Arunachal Pradesh	140	95	118	118
2	Assam	1849	1588	615	574
3	Manipur	207	86	105	103
4	Meghalaya	315	255	302	229
5	Mizoram	150	55	60	60
6	Nagaland	173	155	96	93
7	Tripura	435	260	300	300
8	ISGS/IPPs	0	0	2371	2370
	<b>Total NER</b>	<b>3269</b>	<b>2494</b>	<b>3967</b>	<b>3847</b>
	<b>Total All India</b>	<b>186067</b>	<b>169164</b>	<b>194946</b>	<b>176088</b>