

National Load Despatch Centre
Total Transfer Capability for January 2016

Issue Date: 31/12/2015

Issue Time: 0215 hrs

Revision No. 2

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR-WR *	1st Jan 2016 to 31st Jan 2016	00-24	2500	500	2000	706	1294		
WR-NR*	1st Jan 2016 to 31st Jan 2016	00-24	7700	500	7200	6103	1097		
NR-ER*	1st Jan 2016 to 31st Jan 2016	00-06	2000	200	1800	293	1507		
		06-18'	2000		1800	358	1442		
		18-24	2000		1800	293	1507		
ER-NR*	1st Jan 2016 to 31st Jan 2016	00-24	3800	300	3500	2431	1069		
W3-ER ^{\$}	1st Jan 2016 to 31st Jan 2016	00-24	No limit is being specified. No Re-routing is allowed via W3-ER-NR.						
ER-W3	1st Jan 2016 to 31st Jan 2016	00-24	No limit is being specified.						
WR-SR	1st Jan 2016 to 5th Jan 2016	00-24	3500	750	2750	3250	0	-500	Revised due to shutdown of HVDC Bhadrawati pole 1
	6th Jan 2016 to 31st Jan 2016	00-24	4000	750	3250	3250	0		
SR-WR *	1st Jan 2016 to 31st Jan 2016	00-24	No limit is being Specified.						
ER-SR	1st Jan 2016 to 31st Jan 2016	00-06	2650	0	2650	2585	65		
		18-24				2650	0		
		06-18'							
SR-ER *	1st Jan 2016 to 31st Jan 2016	00-24	No limit is being Specified.						

National Load Despatch Centre
Total Transfer Capability for January 2016

Issue Date: 31/12/2015

Issue Time: 0215 hrs

Revision No. 2

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER-NER	1st Jan 2016 to 31st Jan 2016	00-17	1160	45	1115	210	905	260	Revised considering new new lines commissioned and outage of 220 kV Balipara - Samaguri
		23-24	1100		1055		845	300	
NER-ER	1st Jan 2016 to 31st Jan 2016	00-17	1110	45	1065	0	1065	-360	
		23-24	950		905		905	-680	
W3 zone Injection	1st Jan 2016 to 31st Jan 2016	00-24	No limit is being specified (in case of skewed inter-regional flows or any constraints appearing in the system, W3 zone export would be revised accordingly)						
Note: TTC/ATC of S1-S2 corridor, Import of Punjab and Import of DD & DNH is uploaded on NLDC website under Intra-Regional Section in Monthly ATC.									

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

National Load Despatch Centre
Total Transfer Capability for January 2016

Issue Date: 31/12/2015

Issue Time: 0215 hrs

Revision No. 2

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
----------	------	-------------------	---------------------------------	--------------------	-------------------------------------	--	--	-------------------------------------	----------

\$ As per Simulations, predominant direction of flow is on West to North Corridor. Hence, in case injection point is in Western Region (W1,W2,W3), STOA/PX transactions from West to North on West-East-North corridor shall not be allowed as such transaction increases congestion in the West to North Corridor.

1) S1 comprises of Telangana, AP and Karnataka; S2 comprises of Tamil Nadu, Kerala and Puducherry

2) W3 comprises of the following regional entities :

- a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak
 f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPCCL, n)Vandana Vidyut

The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/ Fuel shortage/New units being commissioned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

In case of TTC Revision due to any shutdown :

- 1) The TTC value will be revised to normal values after restoration of shutdown.
 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.

Limiting Constraints

Corridor	Constraint
NR-WR	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.
WR-NR	1. (n-1) Contingency of 765kV Gwalior-Agra one ckt leads to 2750 MW loading on second circuit. 2.High Loading of 400kV Singrauli-Anpara S/C.
NR-ER	(n-1) contingency of 400 kV Saranath-Pusaui
ER-NR	1. n-1 contingency of one circuit of 400 kV Biharshariff- Lakhisarai leads to high loading on the other circuit
WR-SR & ER-SR	(n-1) contingency of one circuit of 765 kV Raichur - Sholapur will lead to 2500 MW loading on the other circuit Low Voltage at Gazuwaka (East) Bus.
ER-NER	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other 400/220 kV, 315 MVA ICT at Misa. n-1 contingency of 400/132 kV, 2 x 200 MVA ICTs at Silchar
NER-ER	
W3 zone Injection	---

Simultaneous Import Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER									
NR	1st Jan 2016 to 31st Jan 2016	00-05	11000	800	10200	8534	1666		
		05-08'	11100		10300		1766		
		08-19'	11000		10200		1666		
		19-24	10250		9450		916		
NER	1st Jan 2016 to 31st Jan 2016	00-17 23-24	1160	45	1115	210	905	260	Revised considering new lines commissioned and outage of 220 kV Balipara - Samaguri
		17-23	1100		1055		845	300	
WR									
SR	1st Jan 2016 to 5th Jan 2016	00-06	6150	750	5400	5835	0	-500	Revised due to shutdown of HVDC Bhadrawati pole 1
		06-18'	6150		5400	5900	0		
		18-24	6150		5400	5835	0		
	6th Jan 2016 to 31st Jan 2016	00-06	6650	750	5900	5835	65		
		06-18'	6650		5900	5900	0		
		18-24	6650		5900	5835	65		

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

* For approving STOA Bilateral transactions, margin available in Simultaneous Import of NR would be apportioned on WR-NR Corridor & ER-NR Corridor in the following ratio:
 Margin in Simultaneous import of NR = A
 WR-NR ATC =B
 ER-NR ATC = C

 Margin for WR-NR applicants = $A * B/(B+C)$
 Margin for ER-NR Applicants = $A * C/(B+C)$

Simultaneous Export Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR*	1st Jan 2016 to 31st Jan 2016	00-06	4500	700	3800	999	2801		
		06-18'			3800	1064	2736		
		18-24	4500		3800	999	2801		
NER	1st Jan 2016 to 31st Jan 2016	00-17 23-24	1110	45	1065	0	1065	-360	Revised considering new new lines commissioned and outage of 220 kV Balipara - Samaguri
		17-23	950		905		905	-680	
WR									
SR *	1st Jan 2016 to 31st Jan 2016	00-24	No limit is being Specified.						

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Limiting Constraints

NR	Import	(n-1) contingency of 400 kV Biharshariff- Lakhisarai S/C 1. (n-1) Contingency of 765kV Gwalior-Agra one ckt leads to 2750 MW loading on second circuit.
	Export	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak. (n-1) contingency of 400 kV Saranath-Pusauli
NER	Import	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other 400/220 kV, 315 MVA ICT at Misa. n-1 contingency of 400/132 kV, 2 x 200 MVA ICTs at Silchar
	Export	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other 400/220 kV, 315 MVA ICT at Misa.
SR	Import	(n-1) contingency of one circuit of 765 kV Raichur - Sholapur will lead to 2500 MW loading on the other circuit Low Voltage at Gazuwaka (East) Bus.

**National Load Despatch Centre
Total Transfer Capability for January 2016**

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor Affected
1	22/12/2015	Whole month of January 2016	STOA margin revised due to change in LTA/MTOA towards NR	WR-NR / import of NR
			Revised due to commissioning of 765 kV Aurangabad - Sholapur D/C, 400 kV Kolhapur - Kudgi D/C and 765 kV Raichur - Kurnool ckt 1	WR-SR
			Revised due commissioning of new transmission elements	ER-NR
			Revised due commissioning of 765 kV Aurangabad-Sholapur D/C, 765 kV Dharamjaigarh - Jabalpur D/C and considering the present inter regional power flow pattern	W3 Zone injection
2	31/12/2105	1/12/2015 to 5/12/2015	Revised due to shutdown of HVDC Bhadrawati pole 1	WR-SR/Import of SR
		Whole month of January 2016	Revised considering new new lines commissioned and outage of 220 kV Balipara - Samaguri	ER-NER/NER-ER

ASSUMPTIONS IN BASECASE					
				Month : January '16	
S.No	Name of State/Area	Load		Generation	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
I	NORTHERN REGION				
1	Punjab	5199	3202	2642	2259
2	Haryana	5948	3423	3088	3088
3	Rajasthan	9489	8509	5784	5708
4	Delhi	3966	2030	905	905
5	Uttar Pradesh	12457	12419	5395	5351
6	Uttarakhand	1665	1402	614	350
7	Himachal Pradesh	1392	1023	219	76
8	Jammu & Kashmir	2184	2517	379	155
9	Chandigarh	234	116	0	0
10	ISGS/IPPs	0	0	18010	10990
	Total NR	42534	34642	37036	28882
II	EASTERN REGION				
1	Bihar	2642	1775	180	100
2	Jharkhand	1121	739	455	215
3	Damodar Valley Corporation	2466	1899	3485	2815
4	Orissa	3449	2379	2390	1576
5	West Bengal	6671	4388	4796	3378
6	Sikkim	98	64	0	0
7	Bhutan	245	245	352	0
8	ISGS/IPPs	602	599	10700	9171
	Total ER	17293	12089	22359	17255
III	WESTERN REGION				
1	Maharashtra	20219	10937	14007	7706
2	Gujarat	12105	8961	8303	5316
3	Madhya Pradesh	9578	3649	5550	1333
4	Chattisgarh	3568	2205	2661	1570
5	Daman and Diu	283	203	0	0
6	Dadra and Nagar Haveli	798	562	0	0
7	Goa-WR	469	302	0	0
8	ISGS/IPPs	835	837	26803	19253
	Total WR	47856	27657	57324	35178

IV	SOUTHERN REGION				
1	Andhra Pradesh	6017	5521	5699	5264
2	Telangana	7012	5973	2713	2190
3	Karnataka	8161	7225	6446	5250
4	Tamil Nadu	13147	11563	7036	4865
5	Kerala	3409	2427	1687	701
6	Pondy	383	383	0	0
7	Goa-SR	89	89	0	0
8	ISGS/IPPs	0	0	12143	12143
	Total SR	38218	33181	35724	30413
V	NORTH-EASTERN REGION				
1	Arunachal Pradesh	95	43	0	0
2	Assam	877	636	192	122
3	Manipur	98	58	0	0
4	Meghalaya	292	181	147	86
5	Mizoram	68	43	4	4
6	Nagaland	80	65	8	6
7	Tripura	190	88	85	85
8	ISGS/IPPs	0	0	1272	867
	Total NER	1700	1114	1708	1170
	Total All India	147602	108682	154151	112899