

**National Load Despatch Centre
Total Transfer Capability for January 2020**

Issue Date: 19th January 2020

Issue Time: 1210 hrs

Revision No. 10

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR-WR*	1st January 2020 to 31st January 2020	00-06	2500	500	2000	195	1805		
		06-18				250	1750		
		18-24				195	1805		
WR-NR*	1st January 2020 to 2nd January 2020	00-06	14900	500	14400	10231	4169		
			13950**		13450**	9281**	4169**		
		06-18	14900	500	14400	10420	3980		
			13950**		13450**	9470**	3980**		
		18-24	14900	500	14400	10231	4169		
			13950**		13450**	9281**	4169**		
	3rd January 2020 to 4th January 2020	00-06	14900	500	14400	10231	4169		
			13950**		13450**	9281**	4169**		
		06-0830	14900	500	14400	10420	3980		
			13950**		13450**	9470**	3980**		
		0830-18	13800	500	13300	10420	2880		
			12850**		12350**	9470**	2880**		
	5th January 2020 to 6th January 2020	18-24	13800	500	13300	10231	3069		
			12850**		12350**	9281**	3069**		
		00-06	14900	500	14400	10231	4169		
			13950**		13450**	9281**	4169**		
		06-0830	14900	500	14400	10420	3980		
			13950**		13450**	9470**	3980**		
	7th January 2020	0830-18	13800	500	13300	10420	2880		
			12850**		12350**	9470**	2880**		
		18-24	13800	500	13300	10231	3069		
			12850**		12350**	9281**	3069**		
		00-06	14900	500	14400	10231	4169		
			13950**		13450**	9281**	4169**		
8th January 2020 to 13th January 2020	06-0830	14900	500	14400	10420	3980			
		13950**		13450**	9470**	3980**			
	0830-18	14400	500	13900	10420	3480			
		13450**		12950**	9470**	3480**			
	18-24	14400	500	13900	10231	3669			
		13450**		12950**	9281**	3669**			
8th January 2020 to 13th January 2020	00-06	14900	500	14400	10231	4169			
		13950**		13450**	9281**	4169**			
	06-18	14900	500	14400	10420	3980			
8th January 2020 to 13th January 2020		13950**		13450**	9470**	3980**			
	18-24	14900	500	14400	10231	4169			
		13950**		13450**	9281**	4169**			

National Load Despatch Centre
Total Transfer Capability for January 2020

Issue Date: 19th January 2020

Issue Time: 1210 hrs

Revision No. 10

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
WR-NR*	14th January 2020 to 15th January 2020	00-06	14900	500	14400	10231	4169		
			13950**		13450**	9281**	4169**		
		06-0730	14900	500	14400	10420	3980		
			13950**		13450**	9470**	3980**		
		0730-18	13900	500	13400	10420	2980		
			12950**		12450**	9470**	2980**		
	18-24	13900	500	13400	10231	3169			
		12950**		12450**	9281**	3169**			
	16th January 2020 to 31st January 2020	00-06	14900	500	14400	10231	4169		
			13950**		13450**	9281**	4169**		
		06-18	14900	500	14400	10420	3980		
			13950**		13450**	9470**	3980**		
18-24		14900	500	14400	10231	4169			
		13950**		13450**	9281**	4169**			
NR-ER*	1st January 2020 to 31st January 2020	00-06	2000	200	1800	193	1607		
		06-18	2000		1800	303	1497		
		18-24	2000		1800	193	1607		
ER-NR*	1st January 2020 to 31st January 2020	00-24	5250	300	4950	4050	900		
W3-ER	1st January 2020 to 31st January 2020	00-24	No limit is being specified.						
ER-W3	1st January 2020 to 31st January 2020	00-24	No limit is being specified.						
WR-SR	1st January 2020 to 6th January 2020	00-05	5050	500	4550	4035	515		
			5050		4550		515		
		22-24	5050		4550		515		
	7th January 2020 to 19th January 2020	00-05	5550	500	5050	4035	1015		
			5550		5050		1015		
		22-24	5550		5050		1015		
	20th January 2020	00-05	5050	500	4550	4035	515	-500	Revised due to forced outage of HVDC Pole-1 at Bhadravathi
			5050		4550		515		
		22-24	5050		4550		515		
	21st January 2020 to 31st January 2020	00-05	5550	500	5050	4035	1015		
			5550		5050		1015		
		22-24	5550		5050		1015		
SR-WR *	1st January 2020 to 31st January 2020	00-24	No limit is being Specified.						
ER-SR	1st January 2020 to 9th January 2020	00-06	4950	250	4700	2663	2037		
						2748	1952		
		18-24				2663	2037		
	10th January 2020	00-05	4950	250	4700	2663	2037		
			3950		3700	2663	1037		
		06-18	2950		2700	2748	0		
	11th January 2020 to 12th January 2020	18-24				2663	37		
		00-06	2950	250	2700	2663	37		
		06-18				2748	0		
	13th January 2020	18-24				2663	37		
		00-06	3950	250	3700	2663	1037		
		06-18				2748	952		
	14th January 2020	18-24				2663	1037		
		00-06	3950	250	3700	2663	1037		
		06-18				2748	952		
	15th January 2020 to 31st January 2020	18-24				2663	1037		
		00-06	4950	250	4700	2663	2037		
		06-18				2748	1952		
	18-24					2663	2037		
		00-06	4950	250	4700	2663	2037		
		06-18				2748	1952		
	18-24					2663	2037		
		00-06	4950	250	4700	2663	2037		
		06-18				2748	1952		
18-24					2663	2037			
	00-06	4950	250	4700	2663	2037			
	06-18				2748	1952			
18-24					2663	2037			
	00-06	4950	250	4700	2663	2037			
	06-18				2748	1952			
18-24					2663	2037			
	00-06	4950	250	4700	2663	2037			
	06-18				2748	1952			
18-24					2663	2037			
	00-06	4950	250	4700	2663	2037			
	06-18				2748	1952			
SR-ER *	1st January 2020 to 31st January 2020	00-24	No limit is being Specified.						

National Load Despatch Centre
Total Transfer Capability for January 2020

Issue Date: 19th January 2020

Issue Time: 1210 hrs

Revision No. 10

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER-NER	1st January 2020 to 15th January 2020	00-17	1300	45	1255	334	921		
		17-23	1000		955		621		
		23-24	1300		1255		921		
	16th January 2020	00-10	1300	45	1255	334	921		
		10-17	960		915		581		
		17-23	740		695		361		
		23-24	960		915		581		
	17th January 2020 to 31st January 2020	00-17	1300	45	1255	334	921		
		17-23	1000		955		621		
23-24		1300	1255		921				
NER-ER	1st January 2020 to 15th January 2020	00-17	2650	45	2605	0	2605		
		17-23	2610		2565		2565		
		23-24	2650		2605		2605		
	16th January 2020	00-10	2650	45	2605	0	2605		
		10-17	2350		2305		2305		
		17-23	2230		2185		2185		
		23-24	2350		2305		2305		
	17th January 2020 to 31st January 2020	00-17	2650	45	2605	0	2605		
		17-23	2610		2565		2565		
23-24		2650	2605		2605				
W3 zone Injection	1st January 2020 to 31st January 2020	00-24	No limit is being specified (In case of any constraints appearing in the system, W3 zone export would be revised accordingly)						

Note: TTC/ATC of S1-(S2&S3) corridor, Import of S3(Kerala), Import of Punjab and Import of DD & DNH is uploaded on NLDC website under Intra-Regional Section in Monthly ATC.

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

**Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.

1) S1 comprises of Telangana, AP and Karnataka; S2 comprises of Tamil Nadu and Puducherry; S3 comprises Kerala

2) W3 comprises of the following regional entities :

- a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) Lanco Amarkantak
f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPC, n)Vandana Vidut o)RKM, p)GMR Raikheda, q)Ind Barath
and any other regional entity generator in Chhattisgarh

The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/ Fuel shortage/New units being commissioned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

In case of TTC Revision due to any shutdown :

- 1) The TTC value will be revised to normal values after restoration of shutdown.
- 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.

Simultaneous Import Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR	1st January 2020 to 2nd January 2020	00-06	20400	800	19600	14281	5319		
			19450**		18650**	13331**			
		06-09	21900		21100	14470	6630		
			20950**		20150**	13520**			
		09-17	20400		19600	14470	5130		
			19450**		18650**	13520**			
	17-18	19850	19050	14470	4580				
		18900**	18100**	13520**					
	18-24	19850	19050	14281	4769				
		18900**	18100**	13331**					
	3rd January 2020 to 4th January 2020	00-06	20400	800	19600	14281	5319		
			19450**		18650**	13331**			
		06-0830	21900		21100	14470	6630		
			20950**		20150**	13520**			
		0830-09	20300		19500	14470	5030		
			19350**		18550**	13520**			
	09-17	18900	18100	14470	3630				
		17950**	17150**	13520**					
17-18	18400	17600	14470	3130					
	17450**	16650**	13520**						
18-24	18400	17600	14281	3319					
	17450**	16650**	13331**						
5th January 2020 to 6th January 2020	00-06	20400	800	19600	14281	5319			
		19450**		18650**	13331**				
	06-0830	21900		21100	14470	6630			
		20950**		20150**	13520**				
	0830-09	20300		19500	14470	5030			
		19350**		18550**	13520**				
09-17	18900	18100	14470	3630					
	17950**	17150**	13520**						
17-18	18400	17600	14470	3130					
	17450**	16650**	13520**						
18-24	18400	17600	14281	3319					
	17450**	16650**	13331**						

NR	7th January 2020	00-06	20400	800	19600	14281	5319	
			19450**		18650**	13331**		
		06-0830	21900		21100	14470	6630	
			20950**		20150**	13520**		
		0830-09	21200		20400	14470	5930	
			20250**		19450**	13520**		
		09-17	19750		18950	14470	4480	
	18800**		18000**	13520**				
	17-18	19200	18400	14470	3930			
		18250**	17450**	13520**				
	18-24	19200	18400	14281	4119			
		18250**	17450**	13331**				
	8th January 2020 to 13th January 2020	00-06	20400	800	19600	14281	5319	
			19450**		18650**	13331**		
		06-09	21900		21100	14470	6630	
			20950**		20150**	13520**		
		09-17	20400		19600	14470	5130	
			19450**		18650**	13520**		
		17-18	19850		19050	14470	4580	
	18900**		18100**	13520**				
	18-24	19850	19050	14281	4769			
		18900**	18100**	13331**				
	14th January 2020 to 15th January 2020	00-06	20400	800	19600	14281	5319	
			19450**		18650**	13331**		
06-0730		21900	21100		14470	6630		
		20950**	20150**		13520**			
0730-09		20450	19650		14470	5180		
		19500**	18700**		13520**			
09-17		19000	18200		14470	3730		
	18050**	17250**	13520**					
17-18	18500	17700	14470	3230				
	17550**	16750**	13520**					
18-24	18500	17700	14281	3419				
	17550**	16750**	13331**					
16th January 2020 to 31st January 2020	00-06	20400	800	19600	14281	5319		
		19450**		18650**	13331**			
	06-09	21900		21100	14470	6630		
		20950**		20150**	13520**			
	09-17	20400		19600	14470	5130		
		19450**		18650**	13520**			
	17-18	19850		19050	14470	4580		
18900**		18100**	13520**					
18-24	19850	19050	14281	4769				
	18900**	18100**	13331**					

NER	1st January 2020 to 15th January 2020	00-17	1300	45	1255	334	921		
		17-23	1000		955		621		
		23-24	1300		1255		921		
	16th January 2020	00-10	1300	45	1255	334	921		
		10-17	960		915		581		
		17-23	740		695		361		
		23-24	960		915		581		
	17th January 2020 to 31st January 2020	00-17	1300	45	1255	334	921		
		17-23	1000		955		621		
		23-24	1300		1255		921		
	WR								
	SR	1st January 2020 to 6th January 2020	00-06	10000	750	9250	6698	2552	
06-18			10000	9250		6783	2467		
18-24			10000	9250		6698	2552		
7th January 2020 to 9th January 2020		00-06	10500	750	9750	6698	3052		
		06-18	10500		9750	6783	2967		
		18-24	10500		9750	6698	3052		
10th January 2020		00-05	10500	750	9750	6698	3052		
		05-06	9500		8750	6698	2052		
		06-18	8500		7750	6783	967		
		18-24	8500		7750	6698	1052		
11th January 2020 to 12th January 2020		00-06	8500	750	7750	6698	1052		
		06-18	8500		7750	6783	967		
		18-24	8500		7750	6698	1052		
13th January 2020		00-06	9500	750	8750	6698	2052		
		06-18	9500		8750	6783	1967		
		18-24	9500		8750	6698	2052		
14th January 2020		00-06	9500	750	8750	6698	2052		
		06-18	9500		8750	6783	1967		
		18-24	9500		8750	6698	2052		
15th January 2020 to 19th January 2020		00-06	10500	750	9750	6698	3052		
		06-18	10500		9750	6783	2967		
		18-24	10500		9750	6698	3052		
20th January 2020		00-06	10000	750	9250	6698	2552	-500	Revised due to forced outage of HVDC Pole-1 at Bhadravathi
		06-18	10000		9250	6783	2467		
		18-24	10000		9250	6698	2552		
21st January 2020 to 31st January 2020		00-06	10500	750	9750	6698	3052		
		06-18	10500		9750	6783	2967		
	18-24	10500	9750		6698	3052			

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

**Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.

* For approving STOA Bilateral transactions, margin available in Simultaneous Import of NR would be apportioned on WR-NR Corridor & ER-NR Corridor in the following ratio:

Margin in Simultaneous import of NR = A

WR-NR ATC =B

ER-NR ATC = C

Margin for WR-NR applicants = A * B/(B+C)

Margin for ER-NR Applicants = A * C/(B+C)

Simultaneous Export Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR*	1st January 2020 to 31st January 2020	00-06	4500	700	3800	388	3412		
		06-18			3800	553	3247		
		18-24			3800	388	3412		
NER	1st January 2020 to 15th January 2020	00-17	2650	45	2605	0	2605		
		17-23	2610		2565		2565		
		23-24	2650		2605		2605		
	16th January 2020	00-10	2650	45	2605	0	2605		
		10-17	2350		2305		2305		
		17-23	2230		2185		2185		
	17th January 2020 to 31st January 2020	23-24	2350	45	2305	0	2305		
		00-17	2650		2605		2605		
		17-23	2610		2565		2565		
WR									
SR *	1st January 2020 to 31st January 2020	00-24	No limit is being Specified.						

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Limiting Constraints (Corridor wise)

Corridor	Constraint	Applicable Revisions
WR-NR	N-1 contingency of 765 kV Aligarh - Jhatikara Line will lead to overloading of 765 kV Aligarh - Gr. Noida Line	Rev- 0 to 3, 6 to 10
	N-1 contingency of 765/400 kV, 1500 MVA ICT at Agra-PG will overload the other ICT	Rev- 4,5
NR-ER	(n-1) contingency of 400 kV Saranath-Pusauli	Rev- 0 to 10
ER-NR	1. N-1 contingencies of 400 kv Mejia-Maithon A S/C 2. N-1 contingencies of 400 kv Kahalgaon-Banka S/C 3. N-1 contingencies of 400kV MPL- Maithon S/C	Rev- 0 to 10
WR-SR and ER-SR	n-1 contingency of 2x315 MVA, 400/220 kV ICTs at Mardam will lead to overloading of the second ICT	Rev- 0 to 10
	n-1 contingency of 2x1500 MVA, 765/400 kV ICTs at Vemagiri (PG) will lead to overloading of the second ICT	Rev- 0 to 10
	Low Voltage at Gazuwaka (East) Bus.	Rev- 0 to 10
ER-NER	a. N-1 contingency of 400 kV Bongaigaon - Azara line b. High Loading of 220 kV Salakati-BTPS Double circuit (200 MW)	Rev- 0 to 8,10
	N-1 contingency of 400 kV Byrnihat - Bongaigaon will lead to high Loading of 220 kV Samaguri - Sonabil line	Rev-9
NER-ER	a. N-1 contingency of 400 kV Silchar- Azara Line b. High Loading of 400 kV Bongaigaon-Killing line	Rev- 0 to 2
	a. N-1 contingency of 400 kV Silchar- Azara Line b. High Loading of 400 kV Silchar-Killing line	Rev- 3-8,10
	N-1 contingency of 400 kV Byrnihat - Bongaigaon will lead to high Loading of 220 kV Samaguri - Sonabil line	Rev-9
	---	Rev- 0 to 10
W3 zone Injection	---	Rev- 0 to 10

Limiting Constraints (Simultaneous)

		Applicable Revisions	
NR	Import	1. N-1 contingencies of 400 kv Mejia-Maithon A S/C 2. N-1 contingencies of 400 kv Kahalgaon-Banka S/C 3. N-1 contingencies of 400kV MPL- Maithon S/C	Rev- 0 to 10
		N-1 contingency of 765 kV Aligarh - Jhatikara Line will lead to overloading of 765 kV Aligarh - Gr. Noida Line	Rev- 0 to 3, 6 to 10
	Export	N-1 contingency of 765/400 kV, 1500 MVA ICT at Agra-PG will overload the other ICT	Rev- 4, 5
NER	Import	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.	Rev- 0 to 10
		(n-1) contingency of 400 kV Saranath-Pusauli	Rev- 0 to 10
	a. N-1 contingency of 400 kV Bongaigaon - Azara line b. High Loading of 220 kV Salakati-BTPS Double circuit (200 MW)	Rev- 0 to 8,10	
	N-1 contingency of 400 kV Byrnihat - Bongaigaon will lead to high Loading of 220 kV Samaguri - Sonabil line	Rev-9	
	Export	a. N-1 contingency of 400 kV Silchar- Azara Line b. High Loading of 400 kV Bongaigaon-Killing line	Rev- 0 to 2
a. N-1 contingency of 400 kV Silchar- Azara Line b. High Loading of 400 kV Silchar-Killing line		Rev- 3-8,10	
N-1 contingency of 400 kV Byrnihat - Bongaigaon will lead to high Loading of 220 kV Samaguri - Sonabil line		Rev-9	
SR	Import	n-1 contingency of 2x315 MVA, 400/220 kV ICTs at Mardam will lead to overloading of the second ICT	Rev- 0 to 10
		n-1 contingency of 2x1500 MVA, 765/400 kV ICTs at Vemagiri (PG) will lead to overloading of the second ICT	Rev- 0 to 10
		Low Voltage at Gazuwaka (East) Bus.	Rev- 0 to 10

**National Load Despatch Centre
Total Transfer Capability for January 2019**

Revision No	Date of Revision	Period of Revision	Reason for Revision/Comment	Corridor Affected
1	18th November 2019	Whole Month	Revised STOA margin due to 4.2 MW LTA and 19.76 MW MTOA to Assam from GIWEL	ER-NER/Import of NER
2	29th November 2019	Whole Month	Revised STOA margin due to the following. Operationalization of following LTAs:- a) AGEMPL to UPPCL – 40 MW b) GIWEL_SECI-III_RE to Punjab – 112 MW c) SEISPPL_MP to TPDDL – 90 MW Revision in LTA quantum of following:- a) INOX to UPPCL – 100 MW to 50 MW b) RPL-SECI-II-RE to UPPCL – 34.5 MW to 73.8 MW c) RPL-SECI-II-RE to Punjab – 73.8 MW to 100 MW d) Mahindra - Rewa UMSP to DMRC – 7.75 MW to 33 MW	WR-NR/Import of NR
			Revised STOA margin due to allocation of 100 MW quantum from NTPC-WR to Andhra Pradesh.	WR-SR/Import of SR
3	31st December 2019	Whole Month	Revised STOA margin due to the following:- a) Operationalization of 10 MW LTA from AGEMPL (Wind, Bhuj) to Noida Power Company Limited (UP) b) Change in LTA quantum from GIWEL_SECI-III_RE (Wind, Bhuj) to Punjab from 112 MW to 117.6 MW Revision in TTC/ATC due to the following:- a) Non availability of 220 kV Misa-Kopili and 132 kV Khandong- Kopili link b) Long outage of Kopili generation due to bursting of Penstock at Kopili c) Forced outage of Palatana Module-1 d) Change in Load-Generation of NER	WR-NR/Import of NR
			01st Jan 2020 to 04th Jan 2020	Reduction in TTC/ATC due to forced outage of HVDC Bhadravathi Block-I
4	2nd January 2020	3rd Jan 2020 to 4th Jan 2020	Reduction in TTC/ATC due to planned outage of 765 kV Phagi - Gwalior - I	WR-NR/Import of NR
5	4th Jan 2020	5th Jan 2020 to 6th Jan 2020	Reduction in TTC/ATC due to planned outage of 765 kV Phagi - Gwalior - II	WR-NR/Import of NR
		05th Jan 2020 to 06th Jan 2020	Reduction in TTC/ATC due to forced outage of HVDC Bhadravathi Block-I	WR-SR/Import of SR
6	6th Jan 2020	7th Jan 2020	Reduction in TTC/ATC due to planned outage of 765 kV Gwalior - Orai S/C	WR-NR/Import of NR
7	09th Jan 2020	10 th Jan to 13th Jan 2020	Reduction in TTC/ATC due to shutdown of Talchar Kolar Bipole/Unipole	ER-SR/Import of SR
8	13th Jan 2020	14th Jan 2020	Reduction in TTC/ATC due to extension of shutdown of Talcher Kolar Pole - 1	ER-SR/Import of SR
		14th Jan to 15th Jan 2020	Reduction in TTC/ATC due to shutdown of 765 kV Gr. Noida - Mainpuri Line	WR-NR/Import of NR
9	14th Jan 2020	16th Jan 2020	Revised TTC due to shutdown of 400 kV Bongaigaon - Azara S/C for installation of new GCD in Line Reactor	ER-NER/NER-ER corridor & Import/Export of NER
10	19th Jan 2020	20th Jan 2020	Revised due to forced outage of HVDC Pole-1 at Bhadravathi	WR-SR/Import of SR

ASSUMPTIONS IN BASECASE					
				Month : January'20	
S.No.	Name of State/Area	Load		Generation	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
I	NORTHERN REGION				
1	Punjab	7620	5837	3839	3687
2	Haryana	7609	6313	1734	1734
3	Rajasthan	11864	11880	7595	7674
4	Delhi	4955	2966	718	718
5	Uttar Pradesh	13788	12963	6160	6142
6	Uttarakhand	1851	1394	703	461
7	Himachal Pradesh	1168	892	145	75
8	Jammu & Kashmir	1971	2079	421	421
9	Chandigarh	293	170	0	0
10	ISGS/IPPs	27	27	17739	11795
	Total NR	51144	44520	39053	32706
II	EASTERN REGION				
1	Bihar	4565	3383	165	165
2	Jharkhand	1140	989	362	327
3	Damodar Valley Corporation	2600	2971	4562	3873
4	Orissa	4054	3098	3268	2234
5	West Bengal	7013	5688	4926	3921
6	Sikkim	225	311	0	0
7	Bhutan	178	347	336	281
8	ISGS/IPPs	-178	-347	12627	9543
	Total ER	19596	16440	26244	20344
III	WESTERN REGION				
1	Maharashtra	19414	11587	15086	10205
2	Gujarat	15089	11817	10252	8665
3	Madhya Pradesh	10715	8841	3652	4046
4	Chattisgarh	4390	2701	2460	2390
5	Daman and Diu	334	214	0	0
6	Dadra and Nagar Haveli	836	637	0	0
7	Goa-WR	551	295	0	0
8	ISGS/IPPs	5331	4036	43289	31372
	Total WR	56660	40129	74740	56677

S.No.	Name of State/Area	Load		Generation	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
IV	SOUTHERN REGION				
1	Andhra Pradesh	9440	7721	7006	5245
2	Telangana	10136	7870	4948	4648
3	Karnataka	9838	6400	7796	4125
4	Tamil Nadu	13865	11313	6747	5897
5	Kerala	3836	2263	1484	189
6	Pondy	304	304	0	0
7	Goa-SR	59	59	0	0
8	ISGS/IPPs	0	0	14019	12129
	Total SR	47477	35931	42000	32233
V	NORTH-EASTERN REGION				
1	Arunachal Pradesh	123	69	0	0
2	Assam	1466	1082	234	206
3	Manipur	193	115	0	0
4	Meghalaya	349	261	112	58
5	Mizoram	99	68	34	23
6	Nagaland	124	81	12	4
7	Tripura	211	133	99	99
8	ISGS/IPPs	133	79	2071	1680
	Total NER	2698	1887	2562	2069
	Total All India	177575	138907	184600	144031