

**National Load Despatch Centre
Total Transfer Capability for Jan 2026**

Issue Date:Jan 28 2025

Issue Time:18:41:03

Revision No :1

| Corridor | Date | Time Period(hrs) | Total Transfer Capability(TTC) | Reliability Margin(RM) | Available Transfer Capability(ATC) | Approved GNA(MW) | Margin for T-GNA (MW) | Changes w.r.t. Previous Revision | Comment |
|--------------|------------------|------------------|--------------------------------|------------------------|------------------------------------|------------------|-----------------------|----------------------------------|---------|
| ER-NER | 01 Jan to 31 Jan | 00:00 to 07:00 | 1340 | 60 | 1280 | NA | | 0 | |
| | | 07:00 to 12:00 | 1270 | 60 | 1210 | NA | | 0 | |
| | | 12:00 to 17:00 | 1165 | 60 | 1105 | NA | | 0 | |
| | | 17:00 to 21:00 | 920 | 60 | 860 | NA | | 0 | |
| | | 21:00 to 24:00 | 1340 | 60 | 1280 | NA | | 0 | |
| ER-NR | 01 Jan to 31 Jan | 00:00 to 24:00 | 6700 | 400 | 6300 | NA | | 0 | |
| ER-SR | 01 Jan to 31 Jan | 00:00 to 24:00 | 6200 | 350 | 5850 | NA | | 0 | |
| ER-W3 | 01 Jan to 31 Jan | 00:00 to 24:00 | No limit is being specified. | | | | | | |
| ER-WR | 01 Jan to 31 Jan | 00:00 to 24:00 | NA | NA | | NA | | 0 | |
| NER-ER | 01 Jan to 31 Jan | 00:00 to 24:00 | 3480 | 60 | 3420 | NA | | 0 | |
| NR-ER | 01 Jan to 31 Jan | 00:00 to 24:00 | 4000 | 300 | 3700 | NA | | 0 | |
| NR-WR | 01 Jan to 31 Jan | 00:00 to 24:00 | 6000 | 500 | 5500 | NA | | 0 | |
| SR-ER | 01 Jan to 31 Jan | 00:00 to 24:00 | No limit is being specified. | | | | | | |
| SR-WR | 01 Jan to 31 Jan | 00:00 to 06:00 | 7200 | 650 | 6550 | NA | | 0 | |
| | | 06:00 to 18:00 | 7100 | 650 | 6450 | NA | | 0 | |
| | | 18:00 to 24:00 | 7200 | 650 | 6550 | NA | | 0 | |
| W3 Injection | 01 Jan to 31 Jan | 00:00 to 24:00 | NA | NA | | NA | | 0 | |
| W3-ER | 01 Jan to 31 Jan | 00:00 to 24:00 | No limit is being specified. | | | | | | |
| WR-ER | 01 Jan to 31 Jan | 00:00 to 24:00 | 5500 | 300 | 5200 | NA | | 0 | |
| WR-NR | 01 Jan to 31 Jan | 00:00 to 09:00 | 22350 | 1000 | 21350 | NA | | 0 | |
| | | 09:00 to 16:00 | 19050 | 1000 | 18050 | NA | | 0 | |
| | | 16:00 to 24:00 | 22350 | 1000 | 21350 | NA | | 0 | |
| WR-SR | 01 Jan to 31 Jan | 00:00 to 24:00 | 16100 | 650 | 15450 | NA | | 0 | |

Simultaneous Import Capability

| Corridor | Date | Time Period(hrs) | Total Transfer Capability(TTC) | Reliability Margin(RM) | Available Transfer Capability(ATC) | Approved GNA(MW) | Margin for T-GNA (MW) | Changes w.r.t. Previous Revision | Comment |
|----------|------------------|------------------|--------------------------------|------------------------|------------------------------------|------------------|-----------------------|----------------------------------|---------|
| ER | 01 Jan to 31 Jan | 00:00 to 24:00 | NA | NA | | NA | | 0 | |
| NER | 01 Jan to 31 Jan | 00:00 to 07:00 | 1340 | 60 | 1280 | 824 | 456 | 0 | |
| | | 07:00 to 12:00 | 1270 | 60 | 1210 | 824 | 386 | 0 | |
| | | 12:00 to 17:00 | 1165 | 60 | 1105 | 824 | 281 | 0 | |
| | | 17:00 to 21:00 | 920 | 60 | 860 | 824 | 36 | 0 | |
| | | 21:00 to 24:00 | 1340 | 60 | 1280 | 824 | 456 | 0 | |
| NR | 01 Jan to 31 Jan | 00:00 to 09:00 | 25700 | 1400 | 24300 | 17344 | 6956 | 0 | |
| | | 09:00 to 16:00 | 20250 | 1400 | 18850 | 17344 | 1506 | 0 | |
| | | 16:00 to 24:00 | 25700 | 1400 | 24300 | 17344 | 6956 | 0 | |
| SR | 01 Jan to 31 Jan | 00:00 to 24:00 | 22300 | 1000 | 21300 | 7601 | 13699 | 0 | |
| WR | 01 Jan to 31 Jan | 00:00 to 24:00 | NA | NA | | | NA | 0 | |

Simultaneous Export Capability

| Corridor | Date | Time Period(hrs) | Total Transfer Capability(TTC) | Reliability Margin(RM) | Available Transfer Capability(ATC) | Approved GNA(MW) | Margin for T-GNA (MW) | Changes w.r.t. Previous Revision | Comment |
|----------|------------------|------------------|--------------------------------|------------------------|------------------------------------|------------------|-----------------------|----------------------------------|---------|
| ER | 01 Jan to 31 Jan | 00:00 to 24:00 | NA | NA | | NA | | 0 | |
| NER | 01 Jan to 31 Jan | 00:00 to 24:00 | 3480 | 60 | 3420 | NA | | 0 | |
| NR | 01 Jan to 31 Jan | 00:00 to 24:00 | 6000 | 500 | 5500 | NA | | 0 | |
| SR | 01 Jan to 31 Jan | 00:00 to 24:00 | 6400 | 650 | 5750 | NA | | 0 | |
| WR | 01 Jan to 31 Jan | 00:00 to 24:00 | NA | NA | | NA | | 0 | |

Limiting Constraints

| Corridor | Constraints | Revisions |
|------------|---|-----------|
| WR-NR | 1. N-1 contingency of one ckt of 765 kV Vindhyachal-Varanasi will overload the other circuit 2. Low Voltages in major load Centres in the northern region during solar hours. 3. High loading of 765 KV Aligarh-Gr. Noida under N-1 contingency of 765 KV Bara-Mainpuri ckt | 1 |
| NR-ER | 1. Overloading of one circuit of 400 kV New Ranchi – New PPSP D/C on the tripping of the other circuit 2. Overloading of one circuit of 400 kV Kahalgaon – Farakka D/C on the tripping of the other circuit 3. Overloading of 400 kV Farakka –Sagardighi – 1 on the tripping of 400 kV Farakka – Sagardighi - 2 | 1 |
| WR-ER | 1. Overloading of one circuit of 400 kV New Ranchi – New PPSP D/C on the tripping of the other circuit 2. Overloading of one circuit of 400 kV Kahalgaon – Farakka D/C on the tripping of the other circuit 3. Overloading of 400 kV Farakka –Sagardighi – 1 on the tripping of 400 kV Farakka – Sagardighi - 2 | 1 |
| ER-NR | - | 1 |
| WR-SR | Outage of any one of the 2x1500 MVA, 765/400 kV ICTs at Maheswaram overloads the other ICT | 1 |
| ER-SR | 1. Low Voltage at Gazuwaka (East) Bus. | 1 |
| SR-WR | a) Angular separation between Kudgi & Kolhapur (PG) under N-1 touches 30 deg. b) N-1 Contingency of 765/400 kV, 1500 MVA ICTs at Raichur - PG will overload the other circuit. c) N-1 Contingency of 400 kV Kolhapur – Karad D/C will overload the other circuit. d) N-1 non-compliance of 2*1500 MVA, 765/400 kV ICTs at Section– B at Raigarh – PS (Kotra) with operation of HVDC Raigarh – Pugalur Bipole – 1 in SR-WR direction | 1 |
| ER-NER | N-1 contingency of 400 kV Bongaigaon - Azara line will lead to high Loading of 220 kV BTPS - Agia D/C | 1 |
| NER-ER | N-1 contingency of 400 kV Bongaigaon-Alipurduar DC will lead to the High Loading of the other circuit | 1 |
| NR_IMPORT | 1. N-1 contingency of one ckt of 765 kV Vindhyachal-Varanasi will overload the other circuit 2. Low Voltages in major load Centres in the northern region during solar hours. 3. High loading of 765 KV Aligarh-Gr. Noida under N-1 contingency of 765 KV Bara-Mainpuri ckt | 1 |
| NR_EXPORT | Outage of any one of 765 kV Chittorgarh - Banaskantha D/C will overload 400 kV Zerda - Kankroli - 1 (Direct Line) | 1 |
| NER_IMPORT | N-1 contingency of 400 kV Bongaigaon - Azara line will lead to high Loading of 220 kV BTPS - Agia D/C | 1 |
| NER_EXPORT | N-1 contingency of 400 kV Bongaigaon-Alipurduar DC will lead to the High Loading of the other circuit | 1 |
| SR_IMPORT | 1. Outage of any one of the 2x1500 MVA, 765/400 kV ICTs at Maheswaram overloads the other ICT 2. Low Voltage at Gazuwaka (East) Bus | 1 |
| SR_EXPORT | a) Angular separation between Kudgi & Kolhapur (PG) under N-1 touches 30 deg. b) N-1 Contingency of 765/400 kV, 1500 MVA ICTs at Raichur - PG will overload the other ICT. c) N-1 Contingency of 400 kV Kolhapur – Karad D/C will overload the other circuit. d) N-1 non-compliance of 2*1500 MVA, 765/400 kV ICTs at Section– B at Raigarh – PS (Kotra) with operation of HVDC Raigarh – Pugalur Bipole – 1 in SR-WR direction | 1 |

| | | | | |
|--|--|--|--|--|
| | | | | |
| | | | | |