National Load Despatch Centre Total Transfer Capability for July 2014

| Corridor | Date | Time Period (hrs) | Total Transfer Capability (TTC) | Reliability Margin | Available Transfer Capability (ATC) | Long Term Access (LTA)/ Medium Term Open Access (MTOA) # | Margin Available for Short Term Open Access (STOA) | Changes in TTC w.r.t. Last Revision | Comments |
|-------------------------------|-------------------------------------|-------------------------|--|-----------------------|--|--|--|---|---|
| NR-WR * | 1st July 2014 to 31st July 2014 | 00-24 | 2500 | 500 | 2000 | 361 | 1639 | | |
| WR-NR | 1st July 2014 to 31st July 2014 | 00-17 23-24 17-23 | 4200 4200 | 500 | 3700 3700 | 3656 | 44 | | |
| | | 00-17 | | | | | | ı | I |
| NR-ER* | 1st July 2014 to 31st July 2014 | 23-24 | 1000 | 200 | 900 | 200 | 700 | | |
| ER-NR | 1st July 2014 to | 00-17 23-24 | 4400 | 300 | 4100 | 2789 | 1311 | | |
| | 31st July 2014 | 17-23 | | | | 2,0, | 1311 | | |
| | 1st July 2014 to | | | | | | | | |
| W3-ER | 31st July 2014 | 00-24 | 1900 | 300 | 1600 | 0 | 1600 | | |
| ER-W3 | 1st July 2014 to 31st July 2014 | 00-24 | 1000 | 300 | 700 | 700 | 0 | | |
| WR-SR | 1st July 2014 to 31st July 2014 | 00-24 | 1000 | 0 | 1000 | 1000 | 0 | | |
| SR-WR * | 1st July 2014 to 31st July 2014 | 00-24 | 1000 | 0 | 1000 | 0 | 1000 | | |
| | orse vary 201. | | | | | | | | |
| ER-SR | 1st July 2014 to 31st July 2014 | 00-05 10-19 | | 0 | 750 | 518 | 232 | | Margin revised due to grant of 69 MW LTA to Jindal Power |
| EK-5K | | | | | 750 | 310 | 232 | | Limited Tamnar |
| | 1st July 2014 to 7th July 2014 | | | | | 148 | 1052 | | |
| SR-ER * | 8th July 2014 to 9th July 2014 | 00-24 | 1200 | 0 | 1200 | 197 | 1003 | | |
| | 10th July 2014 to 31st July 2014 | | | | | 148 | 1052 | | |
| | | 00-17 | | | | | | | |
| ER-NER | 1st July 2014 to 31st July 2014 | 23-24 | 520 | 50 | 470 | 230 | 240 | | |
| | 31st July 2014 | 17-23 | 520 | | 470 | | 240 | | |
| NER-ER | 1st July 2014 to | 00-17 23-24 | 450 | 100 | 350 | 0 | 350 | | |
| IVER ER | 31st July 2014 | 17-23 | 550 | 100 | 450 | Ů | 450 | | |
| | 1st July 2014 to | | | | | | | | |
| | 7th July 2014 | | | | | 5150 | 550 | | |
| S1-S2 | 8th July 2014 to 9th July 2014 | 00-24 | 6200 | 500 | 5700 | 5300 | 400 | | |
| | 10th July 2014 to 31st July 2014 | | | | | 5050 | 650 | | |
| Import of Punjab | 1st July 2014 to 31st July 2014 | 00-24 | 5600 | 300 | 5300 | 3800 | 1500 | | |
| Import TTC for DD & DNH | 1st July 2014 to 31st July 2014 | 00-24 | 980 | 0 | 980 | LTA and MTO | | | |
| W3 zone | 1st July 2014 to | 00-17 23-24 | 9000 | 200 | 8800 | 6884 | 1916 | | Margin revised due to grant of 69 MW LTA to Jindal Power |
| Injection | 31st July 2014 | 17-23 | 9500 | 200 | 9300 | 0001 | 2416 | | Limited Tamnar |

^{*} Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

¹⁾ ER-SR TTC declared at Talcher Interconnector and Gazuwaka HVDC B/B seam

²⁾ S1 comprises of AP and Karnataka: S2 comprises of Tamil Nadu, Kerala and Pondicherry

³⁾ W3 comprises of the following regional entities:

a) Chattisgarh, b) Jindal Power Limited (JPL), c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak

f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPCL

National Load Despatch Centre Total Transfer Capability for July 2014

| Corridor | Date | Time Period (hrs) | Total Transfer Capability (TTC) | Reliability Margin | Available Transfer Capability (ATC) | Long Term Access (LTA)/ Medium Term Open Access (MTOA) # | | Changes in TTC w.r.t. Last Revision | Comments |
|----------|------|-------------------------|--|-----------------------|--|--|--|---|----------|
|----------|------|-------------------------|--|-----------------------|--|--|--|---|----------|

[#] The figure is based on LTA/MTOA approved by CTU. In actual Operation, due to Units being on Maintenance/ Fuel shortage the LTA/MTOA utilized would be les. RLDC/ \Box NLDC would factor this situation while issuing STOA approvals

Limiting Constraints

| Corridor | Constraint |
|----------------------|---|
| NR-WR | (n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak. |
| WR-NR | High loading of 765 kV Agra-Gwalior (1000 MW SPS setting on each circuit of 765 kV Gwalior-Agra) |
| NR-ER | (n-1) contingency of 400 kV Allahabad-Pusauli |
| ER-NR | (n-1) contingency of one circuit of 400kV Farakka –Malda S/C |
| W3-ER | (n-1) contingency of 400kV Sterilte-Rourkela S/C |
| ER-W3 | (n-1) contingency of 400kV Raigarh-Jharsuguda-Rourkela |
| WR-SR & ER-SR | Commissioning of 765kV Raichur-Sholapur S/C Based on the operational experience after the synchronization of SR grid with NEW grid and due to inadvertent variation of 765kV Raichur-Sholapur line flow, observation of Low Frequency Oscillations(LFO) Considering transfer capability assessment by CTU on NEW-SR corridor. |
| SR-WR | Bhadrawati HVDC B/B link capacity |
| SR-ER | (n-1) and (n-1-1) contingencies of 400kV Talcher-Rourkela D/C |
| ER-NER | (n-1) contingency of one circuit of 400 kV Balipara – Bongaigaon D/C |
| NER-ER | (n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa |
| S1-S2 | (n-1) contingency of 400 kV Kolar-Hosur D/C line, 400kV Hosur-Salem S/C and 400kV Somanahalli-Salem S/C line. |
| Import of Punjab | (n-1) contingency of ICT at Patiala/Moga |
| W3 zone Injection | (n-1-1) contingency of 400 kV Raipur-Bhadrawati D/C section |

^{*}Primary constraints

Simultaneous Import Capability

| Corridor | Date | Time Period (hrs) | Total Transfer Capability (TTC) | Reliability Margin | Available Transfer Capability (ATC) | Long Term Access (LTA)/ Medium Term Open Access (MTOA) | Margin Available for Short Term Open Access (STOA) | Changes in TTC w.r.t. Last Revision | Comments |
|----------|------------------------------------|-------------------------|--|-----------------------|--|--|--|---|--|
| ER | | | | | | | | | |
| NR | 1st July 2014 to 31st July 2014 | 00-17 23-24 | 8600 | 800 | 7800 | 6445 | 1355 | | |
| NK | | 17-23 | 8600 | | 7800 | | 1355 | | |
| NER | 1st July 2014 to | 00-17 23-24 | 520 | 50 | 470 | 230 | 240 | | |
| | 31st July 2014 | 17-23 | 520 | | 470 | | 240 | | |
| WR | | | | | | | | | |
| | | 00.05 | | | | | | | N/ 11 . |
| SR | 1st July 2014 to | 00-05 10-19 | 1750 | 0 | 1750 | 1518 | 232 | | Margin revised due to grant of 69 MW LTA to Jindal Power Limited Tamnar |
| SIX. | 31st July 2014 | 05-10 19-24 | 1750 | 0 | 1750 | | 232 | | |

Simultaneous Export Capability

| Corridor | Date | Time Period (hrs) | Total Transfer Capability (TTC) | Reliability Margin | Available Transfer Capability (ATC) | Long Term Access (LTA)/ Medium Term Open Access (MTOA) | Margin Available for Short Term Open Access (STOA) | Changes in TTC w.r.t. Last Revision | Comments |
|----------|-------------------------------------|-------------------------|--|-----------------------|--|--|--|---|----------|
| NR* | 1st July 2014 to 31st July 2014 | 00-17 23-24 | 3500 | 700 | 2800 | 561 | 2239 | | |
| | 51st July 2014 | 17-23 | 3600 | | 2900 | | 2339 | | |
| NER | 1st July 2014 to 31st July 2014 | 00-17 23-24 | 450 | 100 | 350 | 0 | 350 | | |
| | | 17-23 | 550 | | 450 | | 450 | | |
| WR | | | | | | | | | |
| WK | | | | | | | | | |
| | 1st July 2014 to 7th July 2014 | | | | | 148 | 2052 | | |
| SR-ER * | 8th July 2014 to 9th July 2014 | 00-24 | 2200 | 0 | 2200 | 197 | 2003 | | |
| | 10th July 2014 to 31st July 2014 | | | | | 148 | 2052 | | |

^{*} Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Limiting Constraints

| | Import | (n-1) contingency of one circuit of 400kV Farakka –Malda D/C |
|-----|----------|--|
| NR | F | High loading of 765 kV Agra-Gwalior (1000 MW SPS setting on each circuit of 765 kV Gwalior-Agra) |
| 111 | Export | (n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak. |
| | Export | (n-1) contingency of 400 kV Allahabad-Pusauli |
| NER | Import | (n-1) contingency of one circuit of 400 kV Balipara – Bongaigaon D/C |
| NEK | Export | (n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa |
| | | 1. Commissioning of 765kV Raichur-Sholapur S/C |
| | Impaut | 2. Based on the operational experience after the synchronization of SR grid with NEW grid and due to inadvertent |
| SR | Import | variation of 765kV Raichur-Sholapur line flow, observation of Low Frequency Oscillations(LFO). |
| | | Considering transfer capability assessment by CTU on NEW-SR corridor. |
| | Export | (n-1) and (n-1-1) contingencies of 400kV Talcher-Rourkela D/C |

^{*}Primary constraints

National Load Despatch Centre Total Transfer Capability for June 2014

| Revision No | Date of Revision | Period of Revision | Reason for Revision | Corridor Affected |
|----------------|---------------------|--------------------|--|----------------------|
| 1 | 04-04-2014 | 1 | Margin revised due to grant of 69 MW LTA to Jindal | W3/ |
| 1 | 04-04-2014 | 1 | Power Limited Tamnar | ER-SR |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

ASSUMPTIONS IN BASECASE

Month: June '14

| | | | World : Suite 14 | | | | |
|-------|----------------------------|-------------------|--------------------------|------------|------------------|--|--|
| | | Loa | ad | Generation | | | |
| S.No. | Name of State/Area | Peak Load (MW) | Off Peak Load (MW) | Peak (MW) | Off Peak (MW) | | |
| ı | NORTHERN REGION | | | | | | |
| 1 | Punjab | 8807 | 8517 | 3164 | 3203 | | |
| 2 | Haryana | 6743 | 6353 | 3958 | 3958 | | |
| 3 | Rajasthan | 7803 | 7383 | 5144 | 5134 | | |
| 4 | Delhi | 5199 | 5053 | 1382 | 1382 | | |
| 5 | Uttar Pradesh | 12165 | 12581 | 6115 | 6128 | | |
| 6 | Jammu & Kashmir | 1954 | 1798 | 546 | 564 | | |
| 7 | Uttarakhand | 1656 | 1509 | 496 | 491 | | |
| 8 | Himachal Pradesh | 1503 | 1361 | 852 | 821 | | |
| 9 | Chandigarh | 294 | 225 | 0 | 0 | | |
| 10 | ISGS/IPPs | | | 19790 | 17328 | | |
| | Total NR | 46124 | 44780 | 41447 | 39009 | | |
| | | | | | | | |
| II | EASTERN REGION | | | | | | |
| 1 | West Bengal | 7059 | 4711 | 5170 | 4021 | | |
| 2 | Jharkhand | 1108 | 808 | 590 | 590 | | |
| 3 | Orissa | 3640 | 2570 | 3181 | 2432 | | |
| 4 | Bihar | 2030 | 1500 | 70.5 | 70.5 | | |
| 5 | Damodar Valley Corporation | 2460 | 2030 | 3179 | 2989 | | |
| 6 | Sikkim | 86 | 40 | | | | |
| 7 | Bhutan | 109 | 109 | 1235 | 1235 | | |
| 8 | ISGS/IPPs | 245 | 245 | 8845 | 8315 | | |
| | Total ER | 16737 | 12013 | 22270.5 | 19652.5 | | |
| | | | | | | | |
| III | WESTERN REGION | | | | | | |
| 1 | Chattisgarh | | | | | | |
| 2 | Madhya Pradesh | | | | | | |
| 3 | Maharashtra | | | | | | |
| 4 | Gujarat | | | | | | |
| 5 | Goa | | | | | | |
| 6 | Daman and Diu | | | | | | |
| 7 | Dadra and Nagar Haveli | | | | | | |
| 8 | ISGS/IPPs | | | | | | |
| | Total WR | 0 | 0 | 0 | 0 | | |
| | | | | | | | |
| _ | | | | | | | |

| IV | SOUTHERN REGION | | | | |
|----|----------------------|--------|-------|-------|-------|
| 1 | Andhra Pradesh | 10848 | 9446 | 6571 | 5881 |
| 2 | Tamil Nadu | 12152 | 10588 | 8026 | 7002 |
| 3 | Karnataka | 8397 | 7303 | 6100 | 4619 |
| 4 | Kerala | 3390 | 2595 | 1781 | 863 |
| 5 | Pondy | 329 | 278 | | |
| 6 | Goa | 83 | 83 | | |
| 7 | ISGS/IPPs | | | 11027 | 10260 |
| | Total SR | 35199 | 30293 | 33505 | 28625 |
| | | | | | |
| V | NORTH-EASTERN REGION | | | | |
| 1 | Arunachal Pradesh | 120 | 84 | 0 | 0 |
| 2 | Assam | 1380 | 990 | 250 | 225 |
| 3 | Manipur | 125 | 88 | 0 | 0 |
| 4 | Meghalaya | 300 | 210 | 60 | 55 |
| 5 | Mizoram | 75 | 53 | 4 | 4 |
| 6 | Nagaland | 110 | 77 | 12 | 12 |
| 7 | Tripura | 230 | 130 | 110 | 110 |
| 8 | ISGS/IPPs | | | 1592 | 1262 |
| | Total NER | 2340 | 1632 | 2028 | 1668 |
| | Total All India | 100100 | 00740 | 00050 | 20055 |
| | Total All India | 100400 | 88718 | 99250 | 88955 |