

**National Load Despatch Centre  
Total Transfer Capability for July 2015**

Issue Date: 28/03/2015

Issue Time: 1900 hrs

Revision No. 0

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
NR-WR *	1st Jul 2015 to 31st Jul 2015	00-24	2500	500	2000	706	1294			
WR-NR	1st Jul 2015 to 31st Jul 2015	00-17	5100	500	4600	5157	0			
		23-24	5100		4600		0			
NR-ER*	1st Jul 2015 to 31st Jul 2015	00-06	2000	200	1800	293	1507			
		06-18'	2000		1800		358			1442
		18-24	2000		1800		293			1507
ER-NR	1st Jul 2015 to 31st Jul 2015	00-17	4400	300	4100	2431	1669			
		23-24	4400		4100		1669			
W3-ER <sup>s</sup>	1st Jul 2015 to 31st Jul 2015	00-24	No limit is being specified. No Re-routing is allowed via W3-ER-NR.							
ER-W3	1st Jul 2015 to 31st Jul 2015	00-24	1000	300	700	874	0			
WR-SR	1st Jul 2015 to 31st Jul 2015	00-24	2300	750	1550	1350	200			
SR-WR *	1st Jul 2015 to 31st Jul 2015	00-24	No limit is being Specified.							
ER-SR	1st Jul 2015 to 31st Jul 2015	00-06	2650	0	2650	2585	65			
		18-24					2650			0
SR-ER *	1st Jul 2015 to 31st Jul 2015	00-24	No limit is being Specified.							
ER-NER	1st Jul 2015 to 31st Jul 2015	00-17	720	40	680	210	470			
		23-24	720		680		470			
NER-ER	1st Jul 2015 to 31st Jul 2015	00-17	1040	30	1010	0	1010			
		23-24	1250		1210		1210			
S1-S2	1st Jul 2015 to 9th Jul 2015	00-24	3145	335	2810	2908	0			
	10th Jul 2015 to 11th Jul 2015	00-24	3145	335	2810	2709	101			
	12th Jul 2015 to 19th Jul 2015	00-24	3145	335	2810	2789	21			
	20th Jul 2015	00-24	3145	335	2810	2878	0			
	21st Jul 2015 to 31st Jul 2015	00-24	2845	335	2510	2769	0			
Import of Punjab	1st Jul 2015 to 31st Jul 2015	00-24	5700	300	5400	3790	1610			
Import TTC for DD & DNH	1st Jul 2015 to 31st Jul 2015	00-24	1200	0	1200	LTA and MTOA as per ex-pp schedule				
W3 zone Injection	1st Jul 2015 to 31st Jul 2015	00-17	9400	200	9200	7094	2106			
		23-24	9400		9200		2606			
		17-23	9900		9700					

\* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

**National Load Despatch Centre  
Total Transfer Capability for July 2015**

Issue Date: 28/03/2015

Issue Time: 1900 hrs

Revision No. 0

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
----------	------	-------------------	---------------------------------	--------------------	-------------------------------------	--	--	-------------------------------------	----------

\$ As per Simulations, predominant direction of flow is on West to North Corridor. Hence, in case injection point is in Western Region (W1,W2,W3), STOA/PX transactions from West to North on West-East-North corridor shall not be allowed as such transaction increases congestion in the West to North Corridor.

1) S1 comprises of Telangana, AP and Karnataka; S2 comprises of Tamil Nadu, Kerala and Puducherry

2) W3 comprises of the following regional entities :

a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak  
f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, l) DB Power, m) KWPCCL, n) Vandana Vidyut

# The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/ Fuel shortage/New units being commissioned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

In case of TTC Revision due to any shutdown :

- 1) The TTC value will be revised to normal values after restoration of shutdown.
- 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.

**Limiting Constraints**

Corridor	Constraint
NR-WR	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.
WR-NR	High Loading of 400kV Singrauli-Anpara & High loading of 765 kV Agra-Gwalior (1250 MW SPS setting on each circuit of 765 kV Gwalior-Agra) and Loop flows on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda (power flowing from WR to NR on 765kV Gwalior-Agra D/C and from NR to WR on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda).
NR-ER	(n-1) contingency of 400 kV Saranath-Pusauli
ER-NR	(n-1) contingency of 400 kV Farakka-Malda D/C
W3-ER	i. (n-1) Contingency of 400 kV MPL-Maithon S/C ii. (n-1) contingency of 400kV Sterlite-Rourkela S/C
ER-W3	1. n-1 of 400 kV Wardha – Parli will lead to 30 degrees angular separation between Wardha and Parli. 2. (n-1) contingency of one circuit of 400kV Parli(PG)-Sholapur(PG)
WR-SR & ER-SR	1. n-1 of 400 kV Wardha – Parli will lead to 30 degrees angular separation between Wardha and Parli. 2. (n-1) contingency of one circuit of 400kV Parli(PG)-Sholapur(PG) 2. ER-SR TTC has been declared assuming more than 1100 MW generation at Talcher Stage-2. In case Talcher Stage-2 generation goes below 1100 MW, then the ER-SR TTC would be revised downward as constraints within ER would emerge.
ER-NER	(n-1) contingency of 400 kV Farakka-Malda D/C
NER-ER	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other 400/220 kV, 315 MVA ICT at Misa
S1-S2	(n-1) contingency of one circuit of 400 kV Kolar-Hosur D/C
Import of DD & DNH	(n-1) contingency of 400/220kV 315MVA ICT at VAPI
Import of Punjab	(n-1) contingency of ICT at Dhuri and (n-1) contingency of 220kV Moga(PG)-Moga(PSTCL)
W3 zone Injection	1. n-1 of 400 kV Wardha – Parli will lead to 30 degrees angular separation between Wardha and Parli. 2. (n-1) contingency of one circuit of 400kV Parli(PG)-Sholapur(PG)

\*Primary constraints