

**National Load Despatch Centre
Total Transfer Capability for June 2020**

Issue Date: 17th June 2020

Issue Time: 1800 hrs

Revision No. 18

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR-WR*	1st June 2020 to 30th June 2020	00-06	2500	500	2000	195	1805		
		06-18				1223	777		
		18-24				195	1805		
WR-NR*	1st June 2020 to 2nd June 2020	00-06	17200	500	16700	10219	6481		
			16250**		15750**	9269**			
		06-18	17200	500	16700	10608	6092		
			16250**		15750**	9658**			
		18-24	17200	500	16700	10219	6481		
			16250**		15750**	9269**			
	3rd June 2020	00-06	17200	500	16700	10219	6481		
			16250**		15750**	9269**			
		06-08	17200	500	16700	10608	6092		
			16250**		15750**	9658**			
		08-18	17100	500	16600	10608	5992		
			16150**		15650**	9658**			
	18-24	17100	500	16600	10219	6381			
		16150**		15650**	9269**				
	4th June 2020	00-06	17200	500	16700	10219	6481		
			16250**		15750**	9269**			
		06-08	17200	500	16700	10608	6092		
			16250**		15750**	9658**			
		08-18	17150	500	16650	10608	6042		
			16200**		15700**	9658**			
	18-24	17150	500	16650	10219	6431			
		16200**		15700**	9269**				
	5th June 2020	00-06	17150	500	16650	10219	6431		
			16200**		15700**	9269**			
06-08		17150	500	16650	10608	6042			
		16200**		15700**	9658**				
08-18		17000	500	16500	10608	5892			
		16050**		15550**	9658**				
18-24	17000	500	16500	10219	6281				
	16050**		15550**	9269**					
6th June 2020 to 11th June 2020	00-06	17200	500	16700	10219	6481			
		16250**		15750**	9269**				
	06-08	17200	500	16700	10608	6092			
		16250**		15750**	9658**				
	08-18	17000	500	16500	10608	5892			
		16050**		15550**	9658**				
18-24	17000	500	16500	10219	6281				
	16050**		15550**	9269**					

**National Load Despatch Centre
Total Transfer Capability for June 2020**

Issue Date: 17th June 2020

Issue Time: 1800 hrs

Revision No. 18

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
WR-NR*	12th June 2020	00-06	17200	500	16700	10219	6481		
			16250**		15750**	9269**			
		06-08	17200	500	16700	10608	6092		
			16250**		15750**	9658**			
		08-09	17000	500	16500	10608	5892		
	16050**		15550**		9658**				
	09-18	16850	500	16350	10608	5742			
		15900**		15400**	9658**				
	18-24	16850	500	16350	10219	6131			
		15900**		15400**	9269**				
	13th June 2020	00-06	17200	500	16700	10219	6481		
			16250**		15750**	9269**			
		06-08	17200	500	16700	10608	6092		
			16250**		15750**	9658**			
	08-18	16950	500	16450	10608	5842			
		16000**		15500**	9658**				
	18-24	16950	500	16450	10219	6231			
		16000**		15500**	9269**				
	14th June 2020 to 15th June 2020	00-06	17200	500	16700	10219	6481		
			16250**		15750**	9269**			
06-08		17200	500	16700	10608	6092			
		16250**		15750**	9658**				
08-18	16950	500	16450	10608	5842				
	16000**		15500**	9658**					
18-24	16950	500	16450	10219	6231				
	16000**		15500**	9269**					
WR-NR*	16th June 2020	00-06	17200	500	16700	10219	6481		
			16250**		15750**	9269**			
		06-08	17200	500	16700	10608	6092		
			16250**		15750**	9658**			
		08-18	17000	500	16500	10608	5892		
16050**	15550**		9658**						
18-24	17000	500	16500	10219	6281				
	16050**		15550**	9269**					

**National Load Despatch Centre
Total Transfer Capability for June 2020**

Issue Date: 17th June 2020

Issue Time: 1800 hrs

Revision No. 18

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments		
WR-NR*	17th June 2020	00-06	17200 16250**	500	16700 15750**	10219 9269**	6481				
		06-08	17200 16250**	500	16700 15750**	10608 9658**	6092				
		08-18	17150 16200**	500	16650 15700**	10608 9658**	6042				
		18-24	17150 16200**	500	16650 15700**	10219 9269**	6431				
	18th June 2020	00-06	17200 16250**	500	16700 15750**	10219 9269**	6481				
		06-08	17200 16250**	500	16700 15750**	10608 9658**	6092				
		08-09	17150 16200**	500	16650 15700**	10608 9658**	6042				
		09-18	17000 16050**	500	16500 15550**	10608 9658**	5892				
		18-24	17000 16050**	500	16500 15550**	10219 9269**	6281				
		19th June 2020	00-06	17200 16250**	500	16700 15750**	10219 9269**	6481			
	19th June 2020	06-08	17200 16250**	500	16700 15750**	10608 9658**	6092			Revised TTC due to S/D of 765 kV Ajmer-Bikaner-1, 765 kV Gaya-Varanasi-1, 765/400 kV Jhatikara ICT, 765 kV Meerut-Bhiwani-1, 400 kV RAPP-Sujalpur-2 and 765 kV Vindhyachal-Jabalpur-1 along with ongoing one circuit of 400 kV Patna-Balia	
		08-18	16850 15900**	500	16350 15400**	10608 9658**	5742	-300			
		18-24	16850 15900**	500	16350 15400**	10219 9269**	6131	-300			
		20th June 2020 to 30th June 2020	00-06	17200 16250**	500	16700 15750**	10219 9269**	6481			
	20th June 2020 to 30th June 2020	06-18	17200 16250**	500	16700 15750**	10608 9658**	6092				
		18-24	17200 16250**	500	16700 15750**	10219 9269**	6481				
		Summary for NR-ER*									
		NR-ER*	1st June 2020 to 30th June 2020	00-06	2000	200	1800	193		1607	
	06-18			2000	1800		303	1497			
	18-24			2000	1800		193	1607			
	ER-NR*	1st June 2020 to 2nd June 2020	00-24	5250	300	4950	4050	900			
		3rd June 2020	00-08	5250	300	4950	4050	900			
			08-24	5050	300	4750	4050	700			
		4th June 2020	00-08	5250	300	4950	4050	900			
08-24			5050	300	4750	4050	700				
5th June 2020		00-08	5050	300	4750	4050	700				
		08-24	5050	300	4750	4050	700				
6th June 2020 to 7th June 2020		00-08	5250	300	4950	4050	900				
		08-24	5050	300	4750	4050	700				

**National Load Despatch Centre
Total Transfer Capability for June 2020**

Issue Date: 17th June 2020

Issue Time: 1800 hrs

Revision No. 18

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER-NR*	8th June 2020 to 10th June 2020	00-08	5250	300	4950	4050	900		
		08-09	5050	300	4750	4050	700		
		09-24	5000	300	4700	4050	650		
	11th June 2020	00-08	5250	300	4950	4050	900		
		08-09	5050	300	4750	4050	700		
		09-24	4950	300	4650	4050	600		
	12th June 2020	00-08	5250	300	4950	4050	900		
		08-09	5050	300	4750	4050	700		
		09-24	4950	300	4650	4050	600		
	13th June 2020	00-08	5250	300	4950	4050	900		
		08-09	5050	300	4750	4050	700		
		09-24	4950	300	4650	4050	600		
	14th June 2020 to 15th June 2020	00-08	5250	300	4950	4050	900		
		08-09	5050	300	4750	4050	700		
		09-24	4950	300	4650	4050	600		
	16th June 2020	00-08	5250	300	4950	4050	900		
		08-09	5050	300	4750	4050	700		
		09-24	5050	300	4750	4050	700		
	17th June 2020 to 18th June 2020	00-09	5250	300	4950	4050	900		
		09-24	5100	300	4800	4050	750		
	19th June 2020	00-08	5250	300	4950	4050	900		
08-09		4950	300	4650	4050	600	-300		
09-24		4950	300	4650	4050	600	-150	Revised TTC due to S/D of 765 kV Ajmer-Bikaner-1, 765 kV Gaya-Varanasi-1, 765/400 kV Jhatikara ICT, 765 kV Meerut-Bhiwani-1, 400 kV RAPP-Sujalpur-2 and 765 kV Vindhyachal-Jabalpur-1 along with ongoing one circuit of 400 kV Patna-Balia	
20th June 2020 to 30th June 2020	00-24	5250	300	4950	4050	900			
W3-ER	1st June 2020 to 30th June 2020	00-24	No limit is being specified.						
ER-W3	1st June 2020 to 30th June 2020	00-24	No limit is being specified.						

**National Load Despatch Centre
Total Transfer Capability for June 2020**

Issue Date: 17th June 2020

Issue Time: 1800 hrs

Revision No. 18

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
WR-SR	1st June 2020 to 3rd June 2020	00-08	6950	500	6450	4035	2415			
		08-22	6950		6450		2415			
		22-24	6950		6450		2415			
	4th June 2020	00-0730	6950	500	6450	4035	2415			
		0730-22	6950		6450		2415			
		22-24	6950		6450		2415			
	5th June 2020 to 16th June 2020	00-05	6950	500	6450	4035	2415			
		05-22	6950		6450		2415			
		22-24	6950		6450		2415			
	17th June 2020	00-05	6950	500	6450	4035	2415			
		05-09	6950		6450		2415			
		09-22	5800		5300		1265			
		22-24	5800		5300		1265			
	18th June 2020	00-09	6950	500	6450	4035	2415			
		09-22	6350		5850		1815			
		22-24	6350		5850		1815			
	19th June 2020 to 30th June 2020	00-05	6950	500	6450	4035	2415			
		05-22	6950		6450		2415			
		22-24	6950		6450		2415			
	SR-WR *	1st June 2020 to 30th June 2020	00-24	4600	400	4200	550	3650		
	ER-SR	1st June 2020 to 3rd June 2020	00-06	5650	250	5400	2663	2737		
06-18			5650	5400		2748	2652			
18-24			5650	5400		2663	2737			
4th June 2020		00-06	5650	250	5400	2663	2737			
		06-0730	5650		5400	2748	2652			
		0730-18	4550		4300	2748	1552			
5th June 2020 to 11th June 2020		18-24	4550	250	4300	2663	1637			
		00-06	5650		5400	2663	2737			
		06-18	5650			2748	2652			
12th June 2020		18-24	5650	250		2663	2737			
		00-06	5650		5400	2663	2737			
		06-0730	5650			5400	2748	2652		
13th June 2020 to 15th June 2020		0730-18	4550	250		4300	2748	1552		
		18-24	4550		4300	2663	1637			
		00-06	5650		5400	2663	2737			
16th June 2020		06-18	5650	250		5400	2748	2652		
		18-24	5650			2663	2737			
		00-06	5650		250	5400	2663	2737		
17th June 2020		06-09	5650	5400		2663	2737			
		09-18	5450			5200	2748	2452		
		18-24	5450		5200	2663	2537			
18th June 2020		00-06	5650	250	5400	2663	2737			
		06-09	5650		5400	2748	2652			
		09-18	5600		5350	2748	2652			
		18-24	5600		5350	2663	2737			
19th June 2020 to 30th June 2020		00-06	5650	250	5400	2663	2737			
		06-18	5650		5400	2663	2737			
	18-24	5650	5400			2748	2652			
SR-ER *	1st June 2020 to 30th June 2020	00-24					No limit is being Specified.			

**National Load Despatch Centre
Total Transfer Capability for June 2020**

Issue Date: 17th June 2020

Issue Time: 1800 hrs

Revision No. 18

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER-NER	1st June 2020	00-02	1320	45	1275	289	986		
		02-07	1320		1275	289	986		
		07-12	1320		1275	334	941		
		12-17	1320		1275	334	941		
		17-18	1320		1275	289	986		
		18-22	1050		1005	289	716		
		22-23	1320		1275	289	986		
		23-24	1320		1275	289	986		
ER-NER	2nd June 2020 to 3rd June 2020	00-02	1320	45	1275	289	986		
		02-07	1320		1275	289	986		
		07-0730	1320		1275	334	941		
		0730-12	1050		1005	334	671		
		12-17	1050		1005	334	671		
		17-18	1050		1005	289	716		
		18-22	750		705	289	416		
		22-23	1050		1005	289	716		
23-24	1050	1005	289	716					
ER-NER	4th June 2020 to 30th June 2020	00-02	1320	45	1275	289	986		
		02-07	1320		1275	289	986		
		07-12	1320		1275	334	941		
		12-17	1320		1275	334	941		
		17-18	1320		1275	289	986		
		18-22	1050		1005	289	716		
		22-23	1320		1275	289	986		
		23-24	1320		1275	289	986		
NER-ER	1st June 2020	00-02	1870	45	1825	0	1825		
		02-07	1870		1825		1825		
		07-12	1870		1825		1825		
		12-17	1870		1825		1825		
		17-18	1870		1825		1825		
		18-22	2040		1995		1995		
		22-23	1870		1825		1825		
		23-24	1870		1825		1825		
	2nd June 2020 to 3rd June 2020	00-02	1870	45	1825	0	1825		
		02-07	1870		1825		1825		
		07-0730	1870		1825		1825		
		0730-12	1700		1655		1655		
		12-17	1700		1655		1655		
		17-18	1700		1655		1655		
		18-22	1780		1735		1735		
		22-23	1700		1655		1655		
23-24	1700	1655	1655						

**National Load Despatch Centre
Total Transfer Capability for June 2020**

Issue Date: 17th June 2020

Issue Time: 1800 hrs

Revision No. 18

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
	4th June 2020 to 30th June 2020	00-02	1870	45	1825	0	1825		
		02-07	1870		1825		1825		
		07-12	1870		1825		1825		
		12-17	1870		1825		1825		
		17-18	1870		1825		1825		
		18-22	2040		1995		1995		
		22-23	1870		1825		1825		
		23-24	1870		1825		1825		

W3 zone Injection	1st June 2020 to 30th June 2020	00-24	No limit is being specified (In case of any constraints appearing in the system, W3 zone export would be revised accordingly)						
--------------------------	---------------------------------	-------	---	--	--	--	--	--	--

Note: TTC/ATC of S1-(S2&S3) corridor, Import of S3(Kerala), Import of Punjab and Import of DD & DNH is uploaded on NLDC website under Intra-Regional Section in Monthly ATC.

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

**Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.

1) S1 comprises of Telangana, AP and Karnataka; S2 comprises of Tamil Nadu and Puducherry; S3 comprises Kerala

2) W3 comprises of the following regional entities :

a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak
f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPCCL, n)Vandana Vidyut o)RKM, p)GMR Raikheda, q)Ind Barath and any other regional entity generator in Chhattisgarh

The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/ Fuel shortage/New units being commissioned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

In case of TTC Revision due to any shutdown :

- 1) The TTC value will be revised to normal values after restoration of shutdown.
- 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.

Real Time TTC/ATC revisions are uploaded on POSOCO/NLDC "News Update" (Flasher) Section

Though 2X315 MVA, 400/220 kV ICTs at Maradam are N-1 non-compliant, the TTC of WR-SR and ER-SR corridor has not been restricted due to the same considering that this aspect will be managed by AP SLDC through appropriate measures like SPS implemetation.

In case of drawl of Karnataka beyond 3800 MW, the voltages in Bengaluru area are observed to be critically low. This issue may be taken care of by Karnataka SLDC by taking appropriate measures.

WR-NR/Import of NR TTC has been calculated considering generation at Pariccha TPS as 350 MW. TTC figures are subject to change with significant change in generation at Pariccha TPS.

Simultaneous Import Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR	1st June 2020 to 2nd June 2020	00-06	22450	800	21650	14269	7381		
			21500**		20700**	13319**			
		06-09	22450		21650	14658	6992		
			21500**		20700**	13708**			
		09-17	22450		21650	14658	6992		
			21500**		20700**	13708**			
17-18	22450	21650	14658	6992					
	21500**	20700**	13708**						
18-24	22450	21650	14269	7381					
	21500**	20700**	13319**						
NR	3rd June 2020	00-06	22450	800	21650	14269	7381		
			21500**		20700**	13319**			
		06-08	22450		21650	14658	6992		
			21500**		20700**	13708**			
		08-09	22150		21350	14658	6692		
			21200**		20400**	13708**			
09-17	22150	21350	14658	6692					
	21200**	20400**	13708**						
17-18	22150	21350	14658	6692					
	21200**	20400**	13708**						
18-24	22150	21350	14269	7081					
	21200**	20400**	13319**						
NR	4th June 2020	00-06	22450	800	21650	14269	7381		
			21500**		20700**	13319**			
		06-08	22450		21650	14658	6992		
			21500**		20700**	13708**			
		08-09	22200		21400	14658	6742		
			21250**		20450**	13708**			
09-17	22200	21400	14658	6742					
	21250**	20450**	13708**						
17-18	22200	21400	14658	6742					
	21250**	20450**	13708**						
18-24	22200	21400	14269	7131					
	21250**	20450**	13319**						

NR	5th June 2020	00-06	22200	800	21400	14269	7131		
			21250**		20450**	13319**			
		06-08	22200		21400	14658	6742		
			21250**		20450**	13708**			
		08-09	22050		21250	14658	6592		
			21100**		20300**	13708**			
		09-17	22050		21250	14658	6592		
21100**	20300**		13708**						
17-18	22050	21250	14658	6592					
	21100**	20300**	13708**						
18-24	22050	21250	14269	6981					
	21100**	20300**	13319**						
NR	6th June 2020 to 7th June 2020	00-06	22450	800	21650	14269	7381		
			21500**		20700**	13319**			
		06-08	22450		21650	14658	6992		
			21500**		20700**	13708**			
		08-09	22050		21250	14658	6592		
			21100**		20300**	13708**			
		09-17	22050		21250	14658	6592		
21100**	20300**		13708**						
17-18	22050	21250	14658	6592					
	21100**	20300**	13708**						
18-24	22050	21250	14269	6981					
	21100**	20300**	13319**						
NR	8th June 2020 to 10th June 2020	00-06	22450	800	21650	14269	7381		
			21500**		20700**	13319**			
		06-08	22450		21650	14658	6992		
			21500**		20700**	13708**			
		08-09	22050		21250	14658	6592		
			21100**		20300**	13708**			
		09-17	22000		21200	14658	6542		
21050**	20250**		13708**						
17-18	22000	21200	14658	6542					
	21050**	20250**	13708**						
18-24	22000	21200	14269	6931					
	21050**	20250**	13319**						

NR	11th June 2020	00-06	22450	800	21650	14269	7381						
			21500**		20700**	13319**							
		06-08	22450		21650	14658	6992						
			21500**		20700**	13708**							
		08-09	22050		21250	14658	6592						
			21100**		20300**	13708**							
		09-17	21950		21150	14658	6492						
21000**	20200**		13708**										
17-18	21950	21150	14658	6492									
	21000**	20200**	13708**										
18-24	21950	21150	14269	6881									
	21000**	20200**	13319**										
NR	12th June 2020	00-06	22450	800					21650	14269	7381		
			21500**						20700**	13319**			
		06-08	22450						21650	14658	6992		
			21500**		20700**	13708**							
		08-09	22050		21250	14658			6592				
			21100**		20300**	13708**							
		09-17	21800		21000	14658	6342						
20850**	20050**		13708**										
17-18	21800	21000	14658	6342									
	20850**	20050**	13708**										
18-24	21800	21000	14269	6731									
	20850**	20050**	13319**										
NR	13th June 2020	00-06	22450	800						21650	14269		7381
			21500**					20700**	13319**				
		06-08	22450					21650	14658	6992			
			21500**		20700**	13708**							
		08-09	22000		21200	14658		6542					
			21050**		20250**	13708**							
		09-17	21900		21100	14658	6442						
20950**	20150**		13708**										
17-18	21900	21100	14658	6442									
	20950**	20150**	13708**										
18-24	21900	21100	14269	6831									
	20950**	20150**	13319**										

		00-06	22450 21500**		21650 20700**	14269 13319**	7381		
	18th June 2020	06-08	22450 21500**	800	21650 20700**	14658 13708**	6992		
		08-09	22400 21450**		21600 20650**	14658 13708**	6942		
		09-17	22100 21150**		21300 20350**	14658 13708**	6642		
		17-18	22100 21150**		21300 20350**	14658 13708**	6642		
		18-24	22100 21150**		21300 20350**	14269 13319**	7031		
NR	19th June 2020	00-06	22450 21500**	800	21650 20700**	14269 13319**	7381		Revised TTC due to S/D of 765 kV Ajmer-Bikaner-1, 765 kV Gaya-Varanasi-1, 765/400 kV Jhatikara ICT, 765 kV Meerut-Bhiwani-1, 400 kV RAPP-Sujalpur-2 and 765 kV Vindhyachal-Jabalpur-1 along with ongoing one circuit of 400 kV Patna-Balia
		06-08	22450 21500**		21650 20700**	14658 13708**	6992		
		08-09	21800 20850**		21000 20050**	14658 13708**	6342	-600	
		09-17	21800 20850**		21000 20050**	14658 13708**	6342	-450	
		17-18	21800 20850**		21000 20050**	14658 13708**	6342	-450	
		18-24	21800 20850**		21000 20050**	14269 13319**	6731	-450	
NR	20th June 2020 to 30th June 2020	00-06	22450 21500**	800	21650 20700**	14269 13319**	7381		
		06-09	22450 21500**		21650 20700**	14658 13708**	6992		
		09-17	22450 21500**		21650 20700**	14658 13708**	6992		
		17-18	22450 21500**		21650 20700**	14658 13708**	6992		
		18-24	22450 21500**		21650 20700**	14269 13319**	7381		
NER	1st June 2020	00-02	1320	45	1275	289	986		
		02-07	1320		1275	289	986		
		07-12	1320		1275	334	941		
		12-17	1320		1275	334	941		
		17-18	1320		1275	289	986		
		18-22	1050		1005	289	716		
		22-23	1320		1275	289	986		
		23-24	1320		1275	289	986		

NER	2nd June 2020 to 3rd June 2020	00-02	1320	45	1275	289	986	
		02-07	1320		1275	289	986	
		07-0730	1320		1275	334	941	
		0730-12	1050		1005	334	671	
		12-17	1050		1005	334	671	
		17-18	1050		1005	289	716	
		18-22	750		705	289	416	
		22-23	1050		1005	289	716	
		23-24	1050		1005	289	716	
NER	4th June 2020 to 30th June 2020	00-02	1320	45	1275	289	986	
		02-07	1320		1275	289	986	
		07-12	1320		1275	334	941	
		12-17	1320		1275	334	941	
		17-18	1320		1275	289	986	
		18-22	1050		1005	289	716	
		22-23	1320		1275	289	986	
		23-24	1320		1275	289	986	
		WR						
SR	1st June 2020 to 3rd June 2020	00-06	12600	750	11850	6698	5152	
		06-18	12600		11850	6783	5067	
		18-24	12600		11850	6698	5152	
	4th June 2020	00-06	12600	750	11850	6698	5152	
		06-0730	12600		11850	6783	5067	
		0730-18	11500		10750	6783	3967	
		18-24	11500		10750	6698	4052	
	5th June 2020 to 11th June 2020	00-06	12600	750	11850	6698	5152	
		06-18	12600		11850	6783	5067	
		18-24	12600		11850	6698	5152	
	12th June 2020	00-06	12600	750	11850	6698	5152	
		06-0730	12600		11850	6783	5067	
		0730-18	11500		10750	6783	3967	
		18-24	11500		10750	6698	4052	
	13th June 2020 to 15th June 2020	00-06	12600	750	11850	6698	5152	
		06-18	12600		11850	6783	5067	
		18-24	12600		11850	6698	5152	
	16th June 2020	00-06	12600	750	11850	6698	5152	
		06-18	12600		11850	6783	5067	
		18-24	12600		11850	6698	5152	
	17th June 2020	00-06	12600	750	11850	6698	5152	
		06-09	12600		11850	6783	5067	
		09-18	11250		10500	6783	3717	
		18-24	11250		10500	6698	3802	
	18th June 2020	00-06	12600	750	11850	6698	5152	
		06-09	12600		11850	6783	5067	
		09-18	11950		11200	6783	4417	
18-24		11950	11200		6698	4502		
19th June 2020 to 30th June 2020	00-06	12600	750	11850	6698	5152		
	06-18	12600		11850	6783	5067		
	18-24	12600		11850	6698	5152		

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

**Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.

* For approving STOA Bilateral transactions, margin available in Simultaneous Import of NR would be apportioned on WR-NR Corridor & ER-NR Corridor in the following ratio:

Margin in Simultaneous import of NR = A

WR-NR ATC =B

ER-NR ATC = C

Margin for WR-NR applicants = $A * B/(B+C)$

Margin for ER-NR Applicants = $A * C/(B+C)$

Real Time TTC/ATC revisions are uploaded on POSOCO/NLDC "News Update" (Flasher) Section.

Though 2X315 MVA, 400/220 kV ICTs at Maradam are N-1 non-compliant, the TTC of SR Import has not been restricted due to the same considering that this aspect will be managed by AP SLDC through appropriate measures like SPS implementation.

In case of drawl of Karnataka beyond 3800 MW, the voltages in Bengaluru area are observed to be critically low. This issue may be taken care of by Karnataka by taking appropriate measures.

WR-NR/Import of NR TTC has been calculated considering generation at Pariccha TPS as 350 MW. TTC figures are subject to change with significant change in generation at Pariccha TPS.

Simultaneous Export Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR*	1st June 2020 to 30th June 2020	00-06	4500	700	3800	388	3412		
		06-18			3800	1526	2274		
		18-24			3800	388	3412		
NER	1st June 2020	00-02	1870	45	1825	0	1825		
		02-07	1870		1825		1825		
		07-12	1870		1825		1825		
		12-17	1870		1825		1825		
		17-18	1870		1825		1825		
		18-22	2040		1995		1995		
		22-23	1870		1825		1825		
		23-24	1870		1825		1825		
NER	2nd June 2020 to 3rd June 2020	00-02	1870	45	1825	0	1825		
		02-07	1870		1825		1825		
		07-0730	1870		1825		1825		
		0730-12	1700		1655		1655		
		12-17	1700		1655		1655		
		17-18	1700		1655		1655		
		18-22	1780		1735		1735		
		22-23	1700		1655		1655		
23-24	1700	1655	1655						
NER	4th June 2020 to 30th June 2020	00-02	1870	45	1825	0	1825		
		02-07	1870		1825		1825		
		07-12	1870		1825		1825		
		12-17	1870		1825		1825		
		17-18	1870		1825		1825		
		18-22	2040		1995		1995		
		22-23	1870		1825		1825		
		23-24	1870		1825		1825		
WR									
SR *	1st June 2020 to 30th June 2020	00-24	3700	400	3300	1150	2150		

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Real Time TTC/ATC revisions are uploaded on POSOCO/NLDC "News Update" (Flasher) Section

Limiting Constraints (Corridor wise)		Applicable Revisions	
Corridor	Constraint		
WR-NR	n-1 contingency of 765 kV Aligarh - Jhatikara Line will lead to overloading of 765 kV Aligarh - Gr. Noida Line	Rev- 0 to 1	
	N-1 contingency of 1000 MVA, 765/400 kV ICT at Orai will overload the other ICT	Rev- 2 to 18	
NR-ER	(n-1) contingency of 400 kV Saranath-Pusauli	Rev- 0 to 18	
ER-NR	1. N-1 contingency of 400 kV Mejia-Maithon A line will overload the other ckt. 2. N-1 contingency of 400 kV Kahalgaon-Banka line will overload the other ckt. 3. N-1 contingency of 400kV MPL- Maithon line will overload the other ckt.	Rev- 0 to 18	
WR-SR and ER-SR	n-1 contingency of one ckt of 765 kV Wardha - Nizamabad D/C will overload of the other ckt	Rev- 0 to 15	
	n-1 contingency of one ckt of 765 kV Angul - Srikakulam D/C will overload of the other ckt		
	Low Voltage at Gazuwaka (East) Bus.		
	n-1 contingency of 765/400 kV Nizamabad ICTs will overload of the other ICT	Rev- 16, 18	
	Low Voltage at Gazuwaka (East) Bus.		
	n-1 contingency of one 765/400 kV Nizamabad ICT will overload of ICT-I at Maheshwaram	Rev- 17	
	Low Voltage at Gazuwaka (East) Bus.		
ER-NER	a) N-1 contingency of 400 kV Bongaigaon - Azara line b) High Loading of 220 kV Salakati-BTPS Double circuit (200 MW)	Rev- 0 to 3, 5 to 18	
	a) N-1 contingency of 400 kV Bongaigaon - Byrnihat line b) High Loading of 220 kV Salakati-BTPS Double circuit (200 MW)	Rev- 4	
NER-ER	a) N-1 contingency of 400 kV Silchar- Azara line b) High Loading in Meghalya Internal Power System	Rev- 0 to 2, 4	
	a) N-1 contingency of 400 kV Silchar- Azara line b) High Loading of 400 kV Silchar - Killing line	Rev- 3, 5 to 18	
W3 zone Injection	---	Rev- 0 to 18	
Limiting Constraints (Simultaneous)			
		Applicable Revisions	
NR	Import	1. N-1 contingency of 400 kV Mejia-Maithon A line will overload the other ckt. 2. N-1 contingency of 400 kV Kahalgaon-Banka line will overload the other ckt. 3. N-1 contingency of 400kV MPL- Maithon line will overload the other ckt.	Rev- 0 to 18
		n-1 contingency of 765 kV Aligarh - Jhatikara Line will lead to overloading of 765 kV Aligarh - Gr. Noida Line	Rev- 0 to 1
		N-1 contingency of 1000 MVA, 765/400 kV ICT at Orai will overload the other ICT	Rev- 2 to 18
	Export	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak. (n-1) contingency of 400 kV Saranath-Pusauli	Rev- 0 to 18
	Import	a) N-1 contingency of 400 kV Bongaigaon - Azara line b) High Loading of 220 kV Salakati-BTPS Double circuit (200 MW)	Rev- 0 to 3, 5 to 18
NER		a) N-1 contingency of 400 kV Bongaigaon - Byrnihat line b) High Loading of 220 kV Salakati-BTPS Double circuit (200 MW)	Rev- 4
	Export	a) N-1 contingency of 400 kV Silchar- Azara line b) High Loading in Meghalya Internal Power System	Rev- 0 to 2, 4
		a) N-1 contingency of 400 kV Silchar- Azara line b) High Loading of 400 kV Silchar - Killing line	Rev- 3, 5 to 18
SR	Import	n-1 contingency of one ckt of 765 kV Wardha - Nizamabad D/C will overload of the other ckt	Rev- 0 to 15
		n-1 contingency of one ckt of 765 kV Angul - Srikakulam D/C will overload of the other ckt	
		Low Voltage at Gazuwaka (East) Bus	
		n-1 contingency of 765/400 kV Nizamabad ICTs will overload of the other ICT	Rev-16, 18
		Low Voltage at Gazuwaka (East) Bus	
		n-1 contingency of 765/400 kV Nizamabad ICTs will overload of the other ICT	Rev-17
Low Voltage at Gazuwaka (East) Bus			

**National Load Despatch Centre
Total Transfer Capability for June 2020**

Revision No	Date of Revision	Period of Revision	Reason for Revision/Comment	Corridor Affected
1	29th March 2020	Whole Month	1) Revision in STOA margin due to the following:- a) Operationalization of 50 MW LTA from AGEMPL (Wind, Bhuj) to Punjab b) Completion of 108 MW MTOA from SKS to NPCL (UP) 2) Revision in TTC/ATC due to change in inter-regional flow pattern towards NR.	WR-NR/NR Import
2	29th April 2020	Whole Month	Revision in TTC/ATC after after commissioning of 400 kV Aligarh (PG) - Prithala - Kadarapur - Sohna Road link and 765 kV Bikaner - Moga D/C	WR-NR/Import of NR
3	29th May 2020	Whole Month	Revision in STOA margin due to operationalization of MTOA from Rajasthan Solar to Maharashtra and MP a) Change in Load-Generation of NER b) Reconfiguration of 132 kV Pavoi- Sonabil S/C and 132 kV Sonabil - Gohpur S/C as 132 kV Pavoi - Gohpur 2nd line	NR-WR/Export of NR ER-NER/NER-ER/Import and Export of NER
		1st June 2020 - 15th June 2020	Revision in TTC/ATC due to forced outage of 400/220 kV ICT-II at Jeypore	ER-SR/Import of SR
4	31st May 2020	2nd June 2020 to 3rd June 2020	Revision in TTC/ATC due to planned outage of 400 kV Bongaigaon - Azara line	ER-NER/NER-ER/Import and Export of NER
5	1st June 2020	3rd June 2020	Revised TTC due to shutdown of 765 kV Gaya Varanasi-I & 765 kV Ajmer Chittorhgarh	ER-NR/WR-NR/Import of NR
		4th June 2020 to 15th June 2020	Revised TTC due to shutdown of 765 kV Gaya Varanasi-I	ER-NR/WR-NR/Import of NR
6	2nd June 2020	4th June 2020	Revised TTC due to shutdown of 765 kV Ajmer Chittorhgarh-I Revised TTC due to shutdown of 765 kV Bus - I at Srikakulam and Parli-PG	ER-NR/WR-NR/Import of NR ER-SR/WR-SR/Import of SR
		3rd June 2020	Revised TTC due to not availing shutdown of 765 kV Ajmer Chittorhgarh-I	WR-NR/Import of NR
8	3rd June 2020	5th June 2020	Revised TTC due to shutdown of 765 kV Agra-Jhatikara and 400 kV Biharshariff Varanasi D/C	WR-NR/ER-NR/Import of NR
9	4th June 2020	6th June 2020 to 13th June 2020	Revision in TTC/ATC due to outage of 765 kV Agra - Jhatikara line along with ongoing continuous outage of 765 kV Gaya - Varanasi - I	WR-NR/ER-NR/Import of NR
10	6th June 2020	8th June 2020	Revision in TTC/ATC due to outage of 400 kV Patna- Balia - I along with ongoing continuous outage of 765 kV Gaya - Varanasi - I and 765 kV Agra - Jhatikara line	ER-NR/Import of NR
11	7th June 2020	8th June 2020 to 19th June 2020	Revision in TTC/ATC due to outage of one circuit of 400 kV Patna- Balia section	ER-NR/Import of NR
12	9th June 2020	11th June 2020 to 13th June 2020	Revision in TTC/ATC due to outage of 765 kV Ajmer-Bikaner alongwith ongoing shutdown of one ckt of 400 kV Patna-Balia, 765 kV Agra-Jhatikara & 765 kV Gaya-Varanasi-1	ER-NR/Import of NR
13	10th June 2020	12th June 2020	Revised TTC due to shutdown of 765 kV Bus - II at Srikakulam	ER-SR/Import of SR
		12th June 2020	Revision in TTC/ATC due to the following: - a) Deferment of outage of 765 kV Ajmer-Bikaner - I b) Outage of 765 kV Bhopal - Jabalpur line alongwith ongoing shutdown of one ckt of 400 kV Patna-Balia, 765 kV Agra-Jhatikara & 765 kV Gaya-Varanasi-1 lines	WR-NR/ER-NR/Import of NR
		13th June 2020	Revision in TTC/ATC due to deferment of outage of 765 kV Ajmer-Bikaner - I	ER-NR/Import of NR
14	11th June 2020	13th June 2020	Revised TTC due to shutdown of 765 kV Aligarh-Jhatikara & deferment of 765 kV Agra-Jhatikara S/C	WR-NR/ER-NR/Import of NR
		14th June 2020 to 16th June 2020	Revised TTC due to shutdown of 765 kV Aligarh-Jhatikara	WR-NR/ER-NR/Import of NR
15	13th June 2020	16th June to 30th June	TTC Revised due to forced outage of 400/220 kV Jeypore ICT-II	ER-SR/Import of SR
16	15th June 2020	17th June to 19th June	Revised due to shutdown of 765 kV Ajmer-Bikaner alongwith ongoing shutdown of one circuit of 400 kV Patna-Balia	WR-NR/ER-NR/Import of NR
		17th June 2020	Revised TTC due to Simultaneous shutdown of 400 kV Bhadravati-Ramagundam-I and 765/400 kV Maheshwaram ICT	ER-SR/WR-SR/Import of SR
17	16th June 2020	18th June 2020	Revised due to shutdown of 400 kv RAPP-Shujalpur-1 along with ongoing shutdown of one circuit of 400 kV Patna-Balia and 765 kV Ajmer-Bikaner line.	WR-NR/ER-NR/Import of NR
		18th June 2020	Revised TTC due to S/D of 765/400 kV Maheshwaram ICT - II along with ongoing forced outage of 400/220 kV ICT-II at Jeypore	WR-SR/ER-SR/Import of SR
18	17th June 2020	19th June 2020	Revised TTC due to S/D of 765 kV Ajmer-Bikaner-1, 765 kV Gaya-Varanasi-1, 765/400 kV Jhatikara ICT, 765 kV Meerut-Bhiwani-1, 400 kV RAPP-Sujalpur-2 and 765 kV Vindhychal-Jabalpur-1 along with ongoing one circuit of 400 kV Patna-Balia	WR-NR/ER-NR/Import of NR

ASSUMPTIONS IN BASECASE					
				Month : June'2020	
S.No.	Name of State/Area	Load		Generation	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
I	NORTHERN REGION				
1	Punjab	10067	9726	5031	5107
2	Haryana	8695	8519	2953	2953
3	Rajasthan	11103	11509	7197	7197
4	Delhi	5675	6190	675	675
5	Uttar Pradesh	17079	15541	9239	9284
6	Uttarakhand	2148	1875	1185	1164
7	Himachal Pradesh	1519	1293	709	627
8	Jammu & Kashmir	2948	2295	1114	1113
9	Chandigarh	328	304	0	0
10	ISGS/PPs	25	25	21665	19179
	Total NR	59587	57276	49768	47299
II	EASTERN REGION				
1	Bihar	5009	4587	110	110
2	Jharkhand	1278	1057	425	421
3	Damodar Valley Corporation	3015	2593	5201	4318
4	Orissa	4039	4140	3508	2655
5	West Bengal	8514	7270	5621	5053
6	Sikkim	114	45	0	0
7	Bhutan	171	164	766	621
8	ISGS/PPs	-171	-164	12531	11066
	Total ER	21969	19691	28162	24243
III	WESTERN REGION				
1	Maharashtra	18737	16633	12295	11747
2	Gujarat	15902	12455	10497	8468
3	Madhya Pradesh	9628	7772	5051	3670
4	Chattisgarh	4024	3560	1908	2133
5	Daman and Diu	311	282	0	0
6	Dadra and Nagar Haveli	761	709	0	0
7	Goa-WR	524	498	0	0
8	ISGS/PPs	4774	3644	37337	31485
	Total WR	54661	45553	67088	57504

S.No.	Name of State/Area	Load		Generation	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
IV	SOUTHERN REGION				
1	Andhra Pradesh	9605	6730	8327	6053
2	Telangana	7763	7848	4598	4644
3	Karnataka	9884	8330	7755	5857
4	Tamil Nadu	15780	13783	9577	8276
5	Kerala	3667	2269	1637	235
6	Pondy	314	265	0	0
7	Goa-SR	61	52	0	0
8	ISGS/IPPs	0	0	12710	12179
	Total SR	47074	39278	44605	37244
V	NORTH-EASTERN REGION				
1	Arunachal Pradesh	121	76	8	8
2	Assam	1774	1188	284	244
3	Manipur	179	82	0	0
4	Meghalaya	276	208	215	154
5	Mizoram	100	66	8	8
6	Nagaland	126	91	16	8
7	Tripura	245	149	75	75
8	ISGS/IPPs	153	82	2392	2083
	Total NER	2975	1943	2998	2580
	Total All India	186264	163742	192620	168870