

**National Load Despatch Centre
Total Transfer Capability for March 2013**

Issue Date: 06/03/2013

Issue Time: 1300 hrs

Revision No. 9

| Corridor | Date | Time Period (hrs) | Total Transfer Capability (TTC) | Reliability Margin | Available Transfer Capability (ATC) | Long Term Access (LTA)/ Medium Term Open Access (MTOA) | Margin Available for Short Term Open Access (STOA) | Comments | |
|-----------------------------------|-----------------------------------|-------------------|---------------------------------|--------------------|-------------------------------------|--|--|---|-----|
| NR-WR# | 1st March 2013 to 5th March 2013 | 00-24 | 1500 | 200 | 1300 | 286 | 1014 | | |
| | 6th March 2013 | 00-07, 19-24 | 1500 | 200 | 1300 | 286 | 1014 | Revised due to shutdown of 400 kV Zerda-Kankroli on 06.03.13. | |
| | | 07-19' | 1300 | | 1100 | | 814 | | |
| | 7th March 2013 to 31st March 2013 | 00-24 | 1500 | 200 | 1300 | 286 | 1014 | Revised due to Cancellation of 400 kV Zerda-Bhinmal shutdown on 07.03.13. | |
| WR-NR# | 1st March 2013 to 5th March 2013 | 00-24 | 2000 | 200 | 1800 | 1040 | 760 | Review and dynamic studies carried out to reassess transfer capability | |
| | 6th March 2013 | 00-07, 19-24 | 2000 | 200 | 1800 | 1040 | 760 | Revised due to shutdown of 400 kV Zerda-Kankroli on 06.03.13. | |
| | | 07-19' | 1800 | | 1600 | | 560 | | |
| | 7th March 2013 to 31st March 2013 | 00-24 | 2000 | 200 | 1800 | 1040 | 760 | Revised due to Cancellation of 400 kV Zerda-Bhinmal shutdown on 07.03.13. | |
| NR-ER | 1st March 2013 to 31st March 2013 | 00-17 | 800 | 200 | 600 | 0 | 600 | | |
| | | 23-24 | | | 700 | | 700 | | |
| ER-NR | 1st March 2013 to 4th March 2013 | 00-17 | 2500 | 300 | 2200 | 1900 | 300 | | |
| | | 23-24 | | | | | 1900 | | 300 |
| | | 17-23 | | | | | 1900 | | 300 |
| | 5th March 2013 | 00-09 | 2500 | 300 | 2200 | 1900 | 300 | | |
| | | 09-24' | 2200 | | 1900 | | 0 | | |
| | 6th March 2013 | 00-24 | 2200 | 300 | 1900 | 1900 | 0 | Revised due to shutdown of 400 kV Kahalgaon-Biharsharif I | |
| | 7th March 2013 | 00-18 | 2200 | 300 | 1900 | 1900 | 0 | | |
| | 18-24 | 2500 | 2200 | | 300 | | | | |
| 8th March 2013 to 31st March 2013 | 00-17 | 2500 | 300 | 2200 | 1900 | 300 | | | |
| | 23-24 | | | | | 1900 | | 300 | |
| | 17-23 | | | | 1900 | 300 | | | |
| W3-ER | 1st March 2013 to 31st March 2013 | 00-24 | 1400 | 300 | 1100 | 0 | 1100 | | |
| ER-W3 | 1st March 2013 to 31st March 2013 | 00-24 | 1000 | 300 | 700 | 650 | 50 | | |
| WR-SR | 1st March 2013 to 31st March 2013 | 00-24 | 1000 | 0 | 1000 | 992 | 8 | | |
| SR-WR | 1st March 2013 to 31st March 2013 | 00-24 | 1000 | 0 | 1000 | 0 | 1000 | | |
| ER-SR | 1st March 2013 to 31st March 2013 | 00-05 | 950 | 0 | 950 | 170 | 780 | Review of TTC due to change in load generation scenario | |
| | | 10-19 | | | | | 780* | | |
| SR-ER | 1st March 2013 to 31st March 2013 | 00-17 | 700 | 0 | 700 | 197 | 503 | | |
| | | 23-24 | | | | | 700 | | 503 |
| ER-NER | 1st March 2013 to 31st March 2013 | 00-17 | 400 | 35 | 365 | 228 | 137 | | |
| | | 23-24 | | | | | 365 | | 137 |
| NER-ER | 1st March 2013 to 31st March 2013 | 00-17 | 510 | 100 | 410 | 0 | 410 | | |
| | | 23-24 | | | | | 180 | | 180 |
| | | 17-23 | 280 | | | | | | |

**National Load Despatch Centre
Total Transfer Capability for March 2013**

Issue Date: 06/03/2013

Issue Time: 1300 hrs

Revision No. 9

| Corridor | Date | Time Period (hrs) | Total Transfer Capability (TTC) | Reliability Margin | Available Transfer Capability (ATC) | Long Term Access (LTA)/ Medium Term Open Access (MTOA) | Margin Available for Short Term Open Access (STOA) | Comments |
|------------------------------------|-----------------------------------|-------------------|---------------------------------|--------------------|-------------------------------------|--|--|---|
| S1-S2 | 1st March 2013 to 31st March 2013 | 00-24 | 5800 | 200 | 5600 | 4400 | 1200 | |
| Import of Punjab | 1st March 2013 to 31st March 2013 | 00-24 | 5400 | 300 | 5100 | 3243 | 1857 | |
| Import TTC for DD & DNH | 1st March 2013 to 31st March 2013 | 00-24 | 980 | 0 | 980 | LTA and MTOA as per ex-pp schedule | | |
| W3 zone Injection | 1st March 2013 to 31st March 2013 | 00-17, 23-24 | 8000 | 200 | 7800 | 6413 | 1387 | 6413 MW corresponds to maximum effective LTA from W3. Export Margin from W3 would vary as per the maintenance schedule of generators in the zone. |
| | | 17-23 | 8500 | | 8300 | | 1887 | |

1) ER-SR TTC declared at Talcher Interconnector and Gazuwaka HVDC B/B seam

2) ^ S1 comprises of AP and Karnataka: S2 comprises of Tamil Nadu, Kerala and Pondicherry

3) W3 comprises of the following regional entities and would be operational wef 0000 hrs of 18th September 2012

a) Chattisgarh, b) Jindal Power Limited (JPL), c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak

f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat

* additional 250 MW can be transferred to SR if injection point is South Odisha

Limiting Constraints

| Corridor | Constraint |
|---------------------------|--|
| NR-WR | (n-1) contingency of 400kV Bina(PG)-Bina(MP) |
| WR-NR | (n-1) contingency of 400 kV Bina-Satna leading to high loading of 765/ 400 kV Bina transformer |
| NR-ER | (n-1) contingency of 400 kV Pusauli-Biharsharif |
| ER-NR | (n-1) contingency of 400 kV Farakka-Malda |
| W3-ER | (n-1) contingency of 400 kV Sterlite-Rourkela |
| ER-W3 | High loading of 400 kV Raipur-Wardha, Raipur-Bhadrawati T/C, Bhilai-Bhadrawati S/C, Bhilai-Koradi and Bhilai-Seoni* (n-1) contingency of 400kV Rourkela-Raigarh |
| WR-SR | Bhadrawati HVDC B/B link capacity |
| SR-WR | Bhadrawati HVDC B/B link capacity |
| ER-SR | (n-1) contingency of 400 kV Vijaywada-Nellore* Low Voltage in Chennai Area (n-1) contingency of 400 kV Rourkela-Talcher* |
| SR-ER | (n-1) contingency of 400 kV Farakka-Malda* (n-1) contingency of 400 kV Kadappa-Kolar and Neyveli- Sriperumbudur |
| ER-NER | (n-1) contingency of 400 kV Farakka-Malda* High Loading of 220 kV BTPS-Agia (n-1) contingency of 400 kV Balipara – Bongaigaon-I |
| NER-ER | (n-1) contingency of 400 kV Balipara-Bongaigaon-I (n-1) contingency of 220 kV Samaguri – Saruajai I* |
| S1-S2 | (n-1) contingency of 400 kV Hosur-Salem D/C line |
| Import of Punjab | (n-1) contingency of ICT at Moga |
| W3 zone export TTC | (n-1) contingency of 400 kV Raipur-Wardha and High loading of 400 kV Bhilai-Koradi |

*Primary constraints

Simultaneous Import Capability

| Corridor | Date | Time Period (hrs) | Total Transfer Capability (TTC) | Reliability Margin | Available Transfer Capability (ATC) | Long Term Access (LTA)/ Medium Term Open Access (MTOA) | Margin Available for Short Term Open Access (STOA) | Comments |
|------------|-----------------------------------|-------------------|---------------------------------|--------------------|-------------------------------------|--|--|--|
| ER | | | | | | | | |
| NR# | 1st March 2013 to 4th March 2013 | 00-17 | 4500 | 500 | 4000 | 2940 | 1060 | Review and dynamic studies carried out to reassess transfer capability 1. Revised due to shutdown of 400 kV Kahalgaon-Biharsharif I. 2.Shutdown of 400 kV Zerda-Kankroli on 06.03.13. 3.Revised due to Cancellation of 400 kV Zerda-Bhinmal shutdown on 07.03.13. Review and dynamic studies carried out to reassess transfer capability |
| | | 23-24 | | | 4000 | | | |
| | 5th March 2013 | 00-09 | 4500 | 500 | 4000 | 2940 | 1060 | |
| | | 09-24' | 4200 | | 3700 | | 760 | |
| | 6th March 2013 | 00-07, 19-24 | 4200 | 500 | 3700 | 2940 | 760 | |
| | | 07-19' | 4000 | | 3500 | | 560 | |
| | 7th March 2013 | 00-18' | 4200 | 500 | 3700 | 2940 | 760 | |
| | | 18-24' | 4500 | | 4000 | | 1060 | |
| | 8th March 2013 to 31st March 2013 | 00-17 | 4500 | 500 | 4000 | 2940 | 1060 | |
| | | 23-24 | | | 4000 | | 1060 | |
| NER | 1st March 2013 to 31st March 2013 | 00-17 | 400 | 35 | 365 | 228 | 137 | |
| | | 23-24 | | | 365 | | 137 | |
| | | 17-23 | | | 400 | | 228 | 137 |
| WR | | | | | | | | |
| SR | 1st March 2013 to 31st March 2013 | 00-05 | 1950 | 0 | 1950 | 1162 | 788 | |
| | | 10-19 | | | 1950* | | 788* | |
| | | 05-10 | 1950* | | 1950* | | 788* | |

Simultaneous Export Capability

| Corridor | Date | Time Period (hrs) | Total Transfer Capability (TTC) | Reliability Margin | Available Transfer Capability (ATC) | Long Term Access (LTA)/ Medium Term Open Access (MTOA) | Margin Available for Short Term Open Access (STOA) | Comments | |
|-----------------------|-----------------------------------|-----------------------------------|---------------------------------|--------------------|-------------------------------------|--|--|--|-----|
| ER-NR + ER-NER | 1st March 2013 to 31st March 2013 | 00-17 23-24 | 2700 | 350 | 2350 | 2132 | 218 | | |
| | | 17-23 | 2700 | | 2350 | 2132 | 218 | | |
| NR# | 1st March 2013 to 31st March 2013 | 00-17 23-24 | 2300 | 200 | 2100 | 286 | 1814 | Revised due to Shutdown of 400 kV Zerda-Kankroli on 06.03.13 & 400 kV Zerda-Bhinmal on 7.03.13. Revised due to Cancellation of 400 kV Zerda-Bhinmal shutdown on 07.03.13. | |
| | | 17-23 | 2400 | | 2200 | | 1914 | | |
| | 6th March 2013 | 00-07 23-24 | 2300 | 200 | 2100 | 286 | 1814 | | |
| | | 07-17 | 2100 | | 1900 | | 1614 | | |
| | | 17-19 | 2200 | | 2000 | | 1714 | | |
| | | 19-23 | 2400 | | 2200 | | 1914 | | |
| | 7th March 2013 to 31st March 2013 | 00-17 23-24 | 2300 | 200 | 2100 | 286 | 1814 | | |
| | | 17-23 | 2400 | | 2200 | | 1914 | | |
| | NER | 1st March 2013 to 31st March 2013 | 00-17 23-24 | 510 | 100 | 410 | 0 | | 410 |
| | | | 17-23 | 280 | | 180 | | | 180 |
| | | | | | | | | | |
| WR | | | | | | | | | |
| SR | 1st March 2013 to 31st March 2013 | 00-17 23-24 | 1700 | 0 | 1700 | 197 | 1503 | | |
| | | 17-23 | 1700 | | 1700 | | 1503 | | |

* additional 250 MW can be transferred to SR if injection point is South Odisha

Limiting Constraints

| | | |
|---------------------------|---------------|--|
| NR | Import | (n-1) contingency of 400 kV Farakka-Malda* |
| | Export | (n-1) contingency of 400 kV Bina-Satna leading to high loading of 765/ 400 kV Bina transformers* (n-1) contingency of 400kV Bina(PG)-Bina(MP) (n-1) contingency of 400 kV Pusauli-Biharsharif |
| NER | Import | High Loading of 220 kV BTPS-Agia (n-1) contingency of 400 kV Balipara – Bongaigaon-I (n-1) contingency of 400 kV Farakka-Malda* |
| | Export | (n-1) contingency of 220 kV Samaguri – Saruajai I* (n-1) contingency of 400 kV Balipara-Bongaigaon-I |
| SR | Import | (n-1) Coningency of 400kV Gooty-Somanhalli & 400kV Gooty-Nelamangala line (n-1) contingency of 400 kV Rourkela-Talcher* Bhadrawati HVDC B/B link capacity (n-1) contingency of 400 kV Vijaywada-Nellore |
| | Export | (n-1) contingency of 400 kV Farakka-Malda (n-1) contingency of 400 kV Maithon-Kahalgaon (n-1) contingency of 400 kV Kadappa-Kolar and Neyvelli- Sriperumbudur |
| ER-NR + ER-NER | Export | (n-1) contingency of 400 kV Farakka-Malda* |

ASSUMPTIONS IN BASECASE

| S.No. | Name of State/Area | Load | | Generation | |
|------------|-----------------------------|----------------|--------------------|---------------|---------------|
| | | Peak Load (MW) | Off Peak Load (MW) | Peak (MW) | Off Peak (MW) |
| I | NORTHERN REGION | | | | |
| 1 | Punjab | 5678 | 4250 | 2437 | 2318 |
| 2 | Haryana | 5592 | 4591 | 3623 | 3623 |
| 3 | Rajasthan | 7243 | 6793 | 4084 | 4089 |
| 4 | Delhi | 4090 | 3299 | 1206 | 1206 |
| 5 | Uttar Pradesh | 10774 | 9516 | 6020 | 5839 |
| 6 | Jammu & Kashmir | 1800 | 1359 | 333 | 339 |
| 7 | Uttarakhand | 1365 | 1100 | 523 | 302 |
| 8 | Himachal Pradesh | 1043 | 959 | 218 | 131 |
| 9 | Chandigarh | 188 | 86 | 0 | 0 |
| 10 | ISGS | | | 16384 | 11062 |
| | Total NR | 37773 | 31952 | 34828 | 28910 |
| II | EASTERN REGION | | | | |
| 1 | West Bengal | 6457 | 5456 | 4744 | 4088 |
| 2 | Jharkhand | 964 | 650 | 354 | 354 |
| 3 | Orissa | 3009 | 2300 | 1710 | 1611 |
| 4 | Bihar | 1805 | 1450 | 101 | 101 |
| 5 | Damodar Valley Corporation | 2303 | 2000 | 2954 | 2954 |
| 6 | Sikkim | 44 | 44 | 0 | 0 |
| 7 | Bhutan | 112 | 112 | 245 | 245 |
| 8 | ISGS | | | 6505 | 5995 |
| | Total ER | 14694 | 12012 | 16613 | 15348 |
| III | WESTERN REGION | | | | |
| 1 | Chattisgarh | 3153 | 2242 | 2518 | 2025 |
| 2 | Madhya Pradesh | 7200 | 5146 | 3443 | 2802 |
| 3 | Maharashtra | 15717 | 13582 | 13113 | 9454 |
| 4 | Gujarat | 10497 | 8800 | 9933 | 7564 |
| 5 | Goa | 420 | 280 | | |
| 6 | Daman and Diu | 252 | 190 | | |
| 7 | Dadra and Nagar Haveli | 602 | 504 | | |
| 8 | ISGS | | | 11920 | 11796 |
| | Total WR | 37841 | 30744 | 40927 | 33641 |
| IV | SOUTHERN REGION | | | | |
| 1 | Andhra Pradesh | 10835 | 9993 | 8217 | 6817 |
| 2 | Tamil Nadu | 10456 | 8310 | 5148 | 4619 |
| 3 | Karnataka | 8521 | 7469 | 5482 | 4397 |
| 4 | Kerala | 3314 | 2209 | 2248 | 645 |
| 5 | Pondy | 320 | 231 | | |
| 6 | Goa | 84 | 84 | | |
| 7 | ISGS | | | 10955 | 10772 |
| | Total SR | 33530 | 28296 | 32050 | 27250 |
| V | NORTH-EASTERN REGION | | | | |
| 1 | Manipur | 100 | 70 | 0 | 0 |
| 2 | Meghalaya | 280 | 196 | 99 | 71 |
| 3 | Mizoram | 70 | 49 | 4 | 3 |
| 4 | Nagaland | 110 | 77 | 11 | 10 |
| 5 | Assam | 1230 | 840 | 222 | 203 |
| 6 | Tripura | 221 | 155 | 94 | 91 |
| 7 | Arunachal Pradesh | 105 | 74 | 0 | 0 |
| 8 | ISGS | 0 | 0 | 934 | 499 |
| | Total NER | 2116 | 1461 | 1364 | 877 |
| | Total All India | 125954 | 104465 | 125782 | 106026 |