

National Load Despatch Centre
Total Transfer Capability for March 2018

Issue Date: 28th November 2017

Issue Time: 1700 hrs

Revision No. 0

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR-WR*	1st March 2018 to 31st March 2018	00-06	2500	500	2000	55	1945		
		06-18				65	1935		
		18-24				55	1945		
WR-NR*	1st March 2018 to 31st March 2018	00-24	10050	500	9550	9322	228		
NR-ER*	1st March 2018 to 31st March 2018	00-06	2000	200	1800	193	1607		
		06-18	2000		1800	303	1497		
		18-24	2000		1800	193	1607		
ER-NR*	1st March 2018 to 31st March 2018	00-24	4500	300	4200	3030	1170		
W3-ER	1st March 2018 to 31st March 2018	00-24	No limit is being specified.						
ER-W3	1st March 2018 to 31st March 2018	00-24	No limit is being specified.						
WR-SR	1st March 2018 to 31st March 2018	00-05	5700	500	5200	3675	1525		
		05-22	5700		5200		1525		
		22-24	5700		5200		1525		
SR-WR *	1st March 2018 to 31st March 2018	00-24	No limit is being Specified.						
ER-SR	1st March 2018 to 31st March 2018	00-06	3800	250	3550	3289	261		
		06-18'				3374	176		
		18-24				3289	261		
SR-ER *	1st March 2018 to 31st March 2018	00-24	No limit is being Specified.						
ER-NER	1st March 2018 to 31st March 2018	00-17	1370	45	1325	225	1100		
		17-23	1310		1265		1040		
		23-24	1370		1325		1100		
NER-ER	1st March 2018 to 31st March 2018	00-17	1460	45	1415	0	1415		
		17-23	1420		1375		1375		
		23-24	1460		1415		1415		
W3 zone Injection	1st March 2018 to 31st March 2018	00-24	No limit is being specified (In case of any constraints appearing in the system, W3 zone export would be revised accordingly)						
Note: TTC/ATC of S1-(S2&S3) corridor, Import of S3(Kerala), Import of Punjab and Import of DD & DNH is uploaded on NLDC website under Intra-Regional Section in Monthly ATC.									

**National Load Despatch Centre
Total Transfer Capability for March 2018**

Issue Date: 28th November 2017

Issue Time: 1700 hrs

Revision No. 0

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
----------	------	-------------------	---------------------------------	--------------------	-------------------------------------	--	--	-------------------------------------	----------

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

1) S1 comprises of Telangana, AP and Karnataka; S2 comprises of Tamil Nadu and Puducherry; S3 comprises Kerala

2) W3 comprises of the following regional entities :

a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPCCL, n)Vandana Vidyut o)RKM, p)GMR Raikheda, q)Ind Barath and any other regional entity generator in Chhattisgarh

The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/ Fuel shortage/New units being commissioned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

In case of TTC Revision due to any shutdown :

- 1) The TTC value will be revised to normal values after restoration of shutdown.
- 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.

Simultaneous Import Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER									
NR	1st March 2018 to 31st March 2018	00-05	14350	800	13550	12352	1198		
		05-08	14350		13550		1198		
		08-18	14350		13550		1198		
		18-23	13050		12250		0		
		23-24	14350		13550		1198		
NER	1st March 2018 to 31st March 2018	00-17	1370	45	1325	225	1100		
		17-23	1310		1265		1040		
		23-24	1370		1325		1100		
WR									
SR	1st March 2018 to 31st March 2018	00-05	9500	750	8750	6963	1787		
		05-06	9500		8750	6963	1787		
		06-18	9500		8750	7048	1702		
		18-22	9500		8750	6963	1787		
		22-24	9500		8750	6963	1787		

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

* For approving STOA Bilateral transactions, margin available in Simultaneous Import of NR would be apportioned on WR-NR Corridor & ER-NR Corridor in the following ratio:
 Margin in Simultaneous import of NR = A
 WR-NR ATC =B
 ER-NR ATC = C

 Margin for WR-NR applicants = $A * B/(B+C)$
 Margin for ER-NR Applicants = $A * C/(B+C)$

Simultaneous Export Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR*	1st March 2018 to 31st March 2018	00-06	4500	700	3800	248	3552		
		06-18			3800	368	3432		
		18-24			3800	248	3552		
NER	1st March 2018 to 31st March 2018	00-17	1460	45	1415	0	1415		
		17-23	1420		1375				
		23-24	1460		1415				
WR									
SR *	1st March 2018 to 31st March 2018	00-24	No limit is being Specified.						

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Limiting Constraints (Corridor wise)

		Applicable Revisions
Corridor	Constraint	
NR-WR	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak	Rev-0
WR-NR	1. (n-1) Contingency of 765kV Gwalior-Agra one ckt leads to 2750 MW loading on second circuit. Loading of 400kV Singrauli-Anpara S/C. 2.High	Rev-0
NR-ER	(n-1) contingency of 400 kV Saranath-Pusauli	Rev-0
ER-NR	(n-1) contingencies of N.Ranchi - Chandawa S/c & (n-1) contingencies of 400kV MPL- Maithon S/c	Rev-0
WR-SR and ER-SR	a. (n-1) contingency of one ckt of 765 kV Wardha-Nizamabad D/C will lead to 874 MW loading on 400kV Vemagiri(PG)-Gazuwaka (When 400kV Vemagiri(PG)-Nunna S/C is not in service) b.	Rev-0
	(n-1) contingency of 400 kV Vemagiri - Vijaywada S/C will lead to high loading (874 MW) on 400 kV Vemagiri - Gazuwaka S/C (When 400 kV Vemagiri(PG) - Nunna S/C in kept in service)	
	Low Voltage at Gazuwaka (East) Bus.	Rev-0
ER-NER	a. (n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa High loading of 220 kV Balipara-Sonabil line(200 MW) b.	Rev-0
NER-ER	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of 220 kV Samaguri - Sonabil line	Rev-0
W3 zone Injection	---	Rev-0

Limiting Constraints (Simultaneous)

		Applicable Revisions
NR	Import	(n-1) contingencies of N.Ranchi - Chandawa S/c & (n-1) contingencies of 400kV MPL- Maithon S/c. 1. (n-1) Contingency of 765kV Gwalior-Agra one ckt leads to 2750 MW loading on second circuit. 2.High Loading of 400kV Singrauli-Anpara S/C.
	Export	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak. (n-1) contingency of 400 kV Saranath-Pusauli
NER	Import	a. (n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa High loading of 220 kV Balipara-Sonabil line(200 MW) b.
	Export	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of 220 kV Samaguri - Sonabil line
SR	Import	a. (n-1) contingency of one ckt of 765 kV Wardha-Nizamabad D/C will lead to 874 MW loading on 400kV Vemagiri(PG)-Gazuwaka (When 400kV Vemagiri(PG)-Nunna S/C is not in service) b.
		(n-1) contingency of 400 kV Vemagiri - Vijaywada S/C will lead to high loading (874 MW) on 400 kV Vemagiri - Gazuwaka S/C (When 400 kV Vemagiri(PG) - Nunna S/C in kept in service)
		Low Voltage at Gazuwaka (East) Bus.

**National Load Despatch Centre
Total Transfer Capability for March 2018**

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor Affected

ASSUMPTIONS IN BASECASE					
					Month : March'18
S.No.	Name of State/Area	Load			Generation
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
I	NORTHERN REGION				
1	Punjab	7186	4990	2745	2813
2	Haryana	6952	4672	1422	1422
3	Rajasthan	9419	9770	5155	5114
4	Delhi	4024	2446	664	664
5	Uttar Pradesh	14272	14173	7165	7079
6	Uttarakhand	1744	1296	653	552
7	Himachal Pradesh	1458	570	81	37
8	Jammu & Kashmir	2273	1624	553	389
9	Chandigarh	232	124	0	0
10	ISGS/IPPs	25	25	19234	11503
	Total NR	47586	39691	37673	29574
II	EASTERN REGION				
1	Bihar	4230	2466	285	288
2	Jharkhand	1105	828	271	268
3	Damodar Valley Corporation	2905	2541	4866	3959
4	Orissa	3847	2922	3131	2322
5	West Bengal	6930	4968	5220	3618
6	Sikkim	84	48	0	0
7	Bhutan	209	219	424	290
8	ISGS/IPPs	268	259	11868	8503
	Total ER	19576	14251	26064	19248
III	WESTERN REGION				
1	Maharashtra	19088	15285	12588	10688
2	Gujarat	14117	11798	9142	8468
3	Madhya Pradesh	9214	6421	4157	3406
4	Chattisgarh	4186	3206	2727	2148
5	Daman and Diu	330	287	0	0
6	Dadra and Nagar Haveli	715	688	0	0
7	Goa-WR	590	347	0	0
8	ISGS/IPPs	3899	3487	37780	31971
	Total WR	52139	41519	66394	56682

S.No.	Name of State/Area	Load		Generation	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
IV	SOUTHERN REGION				
1	Andhra Pradesh	8498	6093	6374	4557
2	Telangana	9517	7745	5247	3940
3	Karnataka	10027	8135	6395	4394
4	Tamil Nadu	14819	13215	7450	5600
5	Kerala	4055	2500	1614	194
6	Pondy	372	376	0	0
7	Goa-SR	84	85	0	0
8	ISGS/IPPs	0	0	15618	13858
	Total SR	47372	38149	42697	32543
V	NORTH-EASTERN REGION				
1	Arunachal Pradesh	116	61	0	0
2	Assam	1115	921	234	123
3	Manipur	151	87	0	0
4	Meghalaya	250	184	84	34
5	Mizoram	93	69	8	8
6	Nagaland	101	79	12	12
7	Tripura	183	125	72	78
8	ISGS/IPPs	158	100	1756	1495
	Total NER	2167	1626	2166	1750
	Total All India	169216	135629	175472	140126