National Load Despatch Centre Total Transfer Capability for May 2014

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR-WR *	1st May 2014 to 31st May 2014	00-24	2500	500	2000	297	1703		Margin revised due to incorporation of existing Power Allocation.
WR-NR	1st May 2014 to 31st May 2014	00-17 23-24 17-23	4200 4200	500	3700 3700	3992	0		Margin revised due to Commissioning of Sasan Unit-4.
							I		
		00-06	1000		800	293	507		Margin revised due to incorporation of
ND ED*	1st August 2014 to	06-17'		200	800	423	377		existing Solar Power Allocation to SR,
NR-ER*	31st August 2014	17-18'	1100	200	900	423	477		ER, NER constituents between 6 hrs - 18 hrs in LTA figures and allocation
		18-23	1000		900	293	607		data avialable on RPCs RTA/REA.
		23-24	1000		800	293	507		Manain naviand anneidaring the
ER-NR ^{\$}	1st May 2014 to	23-24	3800	300	3500	2431	1069		Margin revised considering the LTA/MTOA allocation avialable in
EK-MK	31st May 2014	17-23	3000	300	3300	2131	1069		RPCs RTA/REA.
						<u> </u>	<u> </u>		
W3-ER	1st May 2014 to 31st May 2014	00-24	1800	300	1500	551	949		Margin revised due to incorporation of existing LTA/MTOA allocation avialable in RPCs RTA/REA and Rerouting of existing MTOA granted by CTU.
ER-W3	1st May 2014 to 31st May 2014	00-24	1000	300	700	874	0		Margin revised due to incorporation of existing LTA/MTOA allocation avialable in RPCs RTA/REA
WR-SR	1st May 2014 to 31st May 2014	00-24	1000	0	1000	1000	0		
SR-WR *	1st May 2014 to 31st May 2014	00-24	1000	0	1000	0	1000		
ER-SR	1st May 2014 to 31st May 2014	00-06 18-24 06-18'	750	0	750	593 638	157 112		Margin revised due to incorporation of existing Solar Power Allocation to Karnataka between 6 hrs-18 hrs in LTA figures.
		00-18				038			inguies.
SR-ER *	1st May 2014 to	23-24	1100	0	1100	197	903		
	31st May 2014	17-23	1100		1100		903		
		00-06							Margin revised considering the
	1-4 M - 2014	23-24	720		670	205	465		LTA/MTOA allocation avialable in
ER-NER ²	1st May 2014 to 31st May 2014	06-17'	720	50	670	210	460		RPCs RTA/REA and due to
	515t Way 2014	17-18	640		590	210	380		incorporation of existing Solar
		18-23 00-17	640		590	205	385		Power Allocation to Assam.
NER-ER	1st May 2014 to	23-24	530	100	430	0	430		
	31st May 2014	17-23	550		450		450		
									Margin revised due to Non-
S1-S2	1st May 2014 to 31st May 2014	00-24	5650	400	5250	5150	100	-550	Margin revised due to Non- Commissioning of Kudankulam U- I,Vallur U-3 unit and NLC-2 EXP units and Allocation of 150 MW to TANGEDCO.
Import of	1st May 2014 to	00-24	5600	300	5300	3800	1500		
Punjab Import TTC for DD & DNH	31st May 2014 1st May 2014 to 31st May 2014	00-24	980	0	980	LTA and MTO	A as per ex-pp		
	1st May 2014 to	00-17	0000		9900		1000		
W3 zone Injection	1st May 2014 to 31st May 2014	23-24	9000	200	8800	6901	1899		
_	(50 %) Counter flor	17-23	9500		9300		2399		advanced transactions (Bilatoral &

^{*} Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

National Load Despatch Centre Total Transfer Capability for May 2014

Issue Date: 29/04/2014 Issue Time: 1830 hrs Revision No. 6

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
----------	------	-------------------------	--	-----------------------	--	--	--	---	----------

- \$ As per Simulations, predominant direction of flow is on West to North Corridor. Hence, in case injection point is in Western Region (W1,W2,W3), STOA/PX transactions from West to North on West-East-North corridor shall not be allowed as such transaction increases congestion in the West to North Corridor.
- 1) ER-SR TTC declared at Talcher Interconnector and Gazuwaka HVDC B/B seam
- 2) S1 comprises of AP and Karnataka: S2 comprises of Tamil Nadu, Kerala and Pondicherry
- 3) W3 comprises of the following regional entities:
- a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak
- f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPCL, n) Vandana Vidyut
- # The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/Fuel shortage/New units being commissionned the LTA/MTOA utilized would be vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

In case of TTC Revision due to any shutdown:

- 1) The TTC value will be revised to normal values after restoration of shutdown.
- 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.

2. ER-NER Total Transfer capability will be reduced to 450 MW in case of outage of any one of the 400kV Purnea-Biharshariff circuit.

Limiting Constraints

Corridor	Constraint						
NR-WR	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.						
WR-NR	$High \ loading \ of \ 765 \ kV \ Agra-Gwalior \ (1250 \ MW \ SPS \ setting \ on \ each \ circuit \ of \ 765 \ kV \ Gwalior-Agra) \\ and \ high \ loop \ flows \ on \ 400 kV \ Kankroli-Zerda \ and \ 400 kV \ Bhinmal-Zerda.$						
NR-ER	(n-1) contingency of 400 kV Allahabad-Pusauli						
ER-NR	(n-1) contingency of 400 kV Kahalgaon-Biharshariff						
W3-ER	(n-1) contingency of 400kV Sterilte-Rourkela S/C						
ER-W3	High loading of 400 kV Raipur-Bhadrawati T/C, Bhilai-Bhadrawati S/C, Bhilai-Koradi and Bhilai-Seoni* (n-1) contingency of 400kV Raigarh-Sterlite						
WR-SR & ER-SR	Commissioning of 765kV Raichur-Sholapur S/C Based on the operational experience after the synchronization of SR grid with NEW grid and due to inadvertent variation of 765kV Raichur-Sholapur line flow, observation of Low Frequency Oscillations(LFO) Considering transfer capability assessment by CTU on NEW-SR corridor.						
SR-WR	Bhadrawati HVDC B/B link capacity						
SR-ER	· ·						
ER-NER	(n-1) contingency of 400 kV Kahalgaon-Biharshariff (during Off-Peak Hours) (n-1) contingency of one circuit of 400 kV Balipara – Bongaigaon D/C (during Peak Hours)						
NER-ER	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa						
S1-S2	(n-1) contingency of 400 kV Kolar-Hosur D/C line, 400kV Hosur-Salem S/C and 400kV Somanahalli-Salem S/C line.						
Import of Punjab	(n-1) contingency of ICT at Patiala/Moga						
W3 zone Injection	(n-1) contingency of 400 kV Raipur-Wardha-Parli Section						
	*Daine and a second sec						

^{*}Primary constraints

Simultaneous Import Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER									
NR	1st May 2014 to 31st May 2014	00-17 23-24	8000	800	7200	6423	777 Commissio 4 & Consid		Margin revised due to Commissioning of Sasan Unit- 4 & Considering the
	313011111111111111111111111111111111111	17-23	8000		7200		777		LTA/MTOA allocation avialable on RPCs website.
		00-06 23-24	720	50	670	205	465		Margin revised considering the
N===2	1st May 2014 to	06-17'	720		670	210	460		LTA/MTOA allocation avialable in RPCs
NER ²	31st May 2014	17-18	640		590	210	380		RTA/REA and due to incorporation of existing
		18-23	640		590	205	385		Solar Power Allocation to
WR									
CD	1st May 2014 to 31st May 2014	00-06 18-24	1750	0	1750	1593	157		Margin revised due to incorporation of existing Solar Power Allocation to Karnataka between 6 hrs-18 hrs in LTA figures.
SR		06-18'	1750	0	1750	1638	112		

2. ER-NER Total Transfer capability will be reduced to 450 MW in case of outage of any one of the 400kV Purnea-Biharshariff circuit.

Simultaneous Export Capability

297

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
		00-06	3500		2800	590	2210		Margin revised due to incorporation of existing Solar Power Allocation to SR, ER, NER constituents between 6 hrs -18 hrs in LTA figures and allocation data avialable on RPCs RTA/REA.
	1st May 2014 to 31st May 2014	06-17'	3500		2800	720	2080		
NR*		17-18	3600	700	2900	720	2180		
		18-23	3600		2900	590	2310		
		23-24	3500		2800	590	2210		
NER	1st May 2014 to	00-17 23-24	530	100	430	0	430		
	31st May 2014	17-23	550		450		450		
WR									
SR*	1st May 2014 to 31st May 2014	00-17 23-24	2100	0	2100	197	1903		
t Fig. B		17-23	2100		2100		1903		

^{*} Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Limiting Constraints

		(n-1) contingency of 400 kV Kahalgaon-Biharshariff
	Import	High loading of 765 kV Agra-Gwalior (1250 MW SPS setting on each circuit of 765 kV Gwalior-Agra) and high loop
NR		flows on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda.
	Ermont	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.
	Export	(n-1) contingency of 400 kV Allahabad-Pusauli
	Import	(n-1) contingency of 400 kV Kahalgaon-Biharshariff (during Off-Peak hours) and (n-1) contingency of one circuit of
NER		400 kV Balipara – Bongaigaon D/C (during Peak Hours)
	Export	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa
		1. Commissioning of 765kV Raichur-Sholapur S/C
	Import	2. Based on the operational experience after the synchronization of SR grid with NEW grid and due to inadvertent
SR	Import	variation of 765kV Raichur-Sholapur line flow, observation of Low Frequency Oscillations(LFO).
		Considering transfer capability assessment by CTU on NEW-SR corridor.
	Export	

^{*}Primary constraints

National Load Despatch Centre Total Transfer Capability for May 2014

Revision	Date of	Period of	Reason for Revision	Corridor
No	Revision	Revision	D. '. 11 1 ' T 10	Affected
			Revised due to change in Inter-regional flow pattern & COD of Sasan UMPP Unit-2	ER-NR/ WR-NR
		Whole		ER-SR/ WR-
1	19-02-2014	Month	Revised considering operational experience and margins on HVDC	SR
		Wionth	Review of flow pattern due to network topology change	W3 Zone
			and Load Generation Balance.	Injection
2	05-03-2014	Whole Month	Re-Routing of transactions on West-East-North Corridor discontinued on account of Inter-Regional Loop flows leading to physical congestion on WR-NR.	WR-NR/ ER-NR
3	13-03-2014	Whole Month	Margin revised due to withdrawal/cancellation of 150MW MTOA from Corporate Power Limited	ER-SR
4	25-03-2014	Whole Month	Margin revised due to correction in LTA/MTOA figure.	NR-WR
5	29-03-2014	Whole Month	Margin revised due to grant of 150 MW LTA towards SR from NEW grid	ER-SR
	29-04-2014		Margin revised due to Non-Commissioning of Kudankulam U-1, Vallur U-3 unit and NLC-2 EXP units and Allocation of 150 MW to TANGEDCO.	S1-S2
			Margin revised due to incorporation of existing Solar Power Allocation to SR, ER, NER constituents between 6 hrs -18 hrs in LTA figures and allocation data avialable on RPCs RTA/REA.	NR-ER/ ER- SR
6		Whole	Margin revised due to Commissioning of Sasan Unit-4.	WR-NR
0	29-04-2014	Month	Margin revised considering the LTA/MTOA allocation avialable in RPCs RTA/REA and due to incorporation of existing Solar Power Allocation to Assam.	ER-NER
			Margin revised considering the LTA/MTOA allocation	NR-WR/
			avialable in RPCs RTA/REA.	ER-NR
			Margin revised considering the LTA/MTOA allocation avialable on RPCs RTA/REA and Re-routing of existing MTOA granted by CTU.	W3-ER

ASSUMPTIONS IN BASECASE

Month: May '14

				Month : May 14			
		Loa	ad	Generation			
S.No.	Name of State/Area	Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)		
ı	NORTHERN REGION						
1	Punjab	5971	5191	2258	2229		
2	Haryana	5885	5116	3178	3178		
3	Rajasthan	7955	6916	5132	5116		
4	Delhi	4102	3566	1296	1296		
5	Uttar Pradesh	11500	10090	6358	6354		
6	Jammu & Kashmir	2133	1854	387	420		
7	Uttarakhand	1628	1415	461	416		
8	Himachal Pradesh	1413	1228	469	385		
9	Chandigarh	238	192	0	0		
10	ISGS/IPPs			18314	13943		
	Total NR	40825	35568	37853	33337		
П	EASTERN REGION						
1	West Bengal	4920	4680	4920	3644		
2	Jharkhand	1070	850	580	420		
3	Orissa	3745	2780	3180	2160		
4	Bihar	1770	1500	0	0		
5	Damodar Valley Corporation	2670	2350	3752	3336		
6	Sikkim	96	32	0	0		
7	Bhutan	108	110	494	484		
8	ISGS/IPPs	245	250	7253	7344		
	Total ER	14624	12552	20179	17388		
III	WESTERN REGION						
1	Chattisgarh	3400	2700	1629	1629		
2	Madhya Pradesh	7728	5521	3632	3013		
3	Maharashtra	16790	15516	13037	11828		
4	Gujarat	12301	11245	11178	9102		
5	Goa	367	257				
6	Daman and Diu	264	245				
7	Dadra and Nagar Haveli	590	585				
8	ISGS/IPPs	1258	1240	17391	16068		
	Total WR	42698	37309	46867	41640		
		· · · · · · · · · · · · · · · · · · ·					

IV	SOUTHERN REGION				
1	Andhra Pradesh	11603	10209	7716	6690
2	Tamil Nadu	11969	10938	7142	6612
3	Karnataka	8415	6979	6440	4970
4	Kerala	3314	2552	1724	893
5	Pondy	329	276		
6	Goa	84	83		
7	ISGS/IPPs			10873	10054
	Total SR	35714	31037	33895	29219
V	NORTH-EASTERN REGION				
1	Arunachal Pradesh	120	84	0	0
2	Assam	1350	980	240	200
3	Manipur	120	84	0	0
4	Meghalaya	310	217	60	55
5	Mizoram	75	52.5	4	4
6	Nagaland	120	84	12	12
7	Tripura	250	130	110	110
8	ISGS/IPPs			1188	938
	Total NER	2345	1631.5	1614	1319
	Tatal All India	100000	440555	4.40.122	400000
	Total All India	136206	118098	140408	122903