

**National Load Despatch Centre**  
**Total Transfer Capability for Nov 2024**

Issue Date:Feb 28 2024

Issue Time:14:52:22

Revision No :3

Corridor	Date	Time Period(hrs)	Total Transfer Capability(TTC)	Reliability Margin(RM)	Available Transfer Capability(ATC)	Approved GNA(MW)	Margin for T-GNA (MW)	Changes w.r.t. Previous Revision	Comment	
ER-NER	01 Nov to 30 Nov	00:00 to 07:00	1320	60	1260	NA		0		
		07:00 to 12:00	1220	60	1160	NA		0		
		12:00 to 17:00	1150	60	1090	NA		0		
		17:00 to 21:00	900	60	840	NA		0		
		21:00 to 24:00	1320	60	1260	NA		0		
ER-NR	01 Nov to 30 Nov	00:00 to 24:00	6700	400	6300	NA		0		
ER-SR	01 Nov to 30 Nov	00:00 to 06:00	6200	350	5850	NA		0		
		06:00 to 18:00	6200	350	5850	NA		0		
		18:00 to 24:00	6200	350	5850	NA		0		
ER-W3	01 Nov to 30 Nov	00:00 to 24:00	No limit is being specified.							
ER-WR	01 Nov to 30 Nov	00:00 to 24:00	NA	NA		NA		0		
NER-ER	01 Nov to 30 Nov	00:00 to 17:00	3480	60	3420	NA		0		
		17:00 to 21:00	3480	60	3420	NA		0		
		21:00 to 24:00	3480	60	3420	NA		0		
NR-ER	01 Nov to 30 Nov	00:00 to 06:00	4000	300	3700	NA		0		
		06:00 to 18:00	4000	300	3700	NA		0		
		18:00 to 24:00	4000	300	3700	NA		0		
NR-WR	01 Nov to 30 Nov	00:00 to 06:00	4000	500	3500	NA		0		
		06:00 to 18:00	4000	500	3500	NA		0		
		18:00 to 24:00	4000	500	3500	NA		0		
SR-ER	01 Nov to 30 Nov	00:00 to 24:00	No limit is being specified.							
SR-WR	01 Nov to 30 Nov	00:00 to 06:00	6000	650	5350	NA		0		
		06:00 to 18:00	7650	650	7000	NA		0		
		18:00 to 24:00	6000	650	5350	NA		0		
W3 Injection	01 Nov to 30 Nov	00:00 to 24:00	NA	NA		NA		0		
W3-ER	01 Nov to 30 Nov	00:00 to 24:00	No limit is being specified.							
WR-ER	01 Nov to 30 Nov	00:00 to 06:00	5500	300	5200	NA		0		
		06:00 to 18:00	5500	300	5200	NA		0		
		18:00 to 24:00	5500	300	5200	NA		0		
WR-NR	01 Nov to 30 Nov	00:00 to 06:00	19200	1000	18200	NA		0		
		06:00 to 18:00	19200	1000	18200	NA		0		
		18:00 to 24:00	19200	1000	18200	NA		0		
WR-SR	01 Nov to 30 Nov	00:00 to 06:00	16100	650	15450	NA		0		
		06:00 to 18:00	16100	650	15450	NA		0		
		18:00 to 24:00	16100	650	15450	NA		0		

- Based on the actual distribution of corridor flows, Counter flow benefit on account of transactions in the reverse direction would be considered for short-term transactions wherever applicable.
- Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.
- S1 comprises of Telangana, AP and Karnataka; S2 comprises of Tamil Nadu and Puducherry; S3 comprises Kerala
- W3 comprises of the following regional entities : a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) NTPC Korba I, II & III, j) NTPC Sipat I & II, k) KSK Mahanadi, l) DB Power, m) REGL (Previously KWPC), n) RKM, o) REL, p) Bharat Aluminium, q) MCCPL, r) SKS, s) TRN, t) NTPC Lara, u) Adani Power Limited Raipur and any other regional entity generator in Chhattisgarh
- The figure is based on GNA approved by CTU. In actual Operation, due to Units being on Maintenance/ Fuel shortage/New units being commissioned, the dispatches of units would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

- In case of TTC Revision due to any shutdown : 1) The TTC value will be revised to normal values after restoration of shutdown. 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.
- Real Time TTC/ATC revisions are uploaded on Grid-India/NLDC "News Update" (Flasher) Section

### Simultaneous Import Capability

Corridor	Date	Time Period(hrs)	Total Transfer Capability(TTC)	Reliability Margin(RM)	Available Transfer Capability(ATC)	Approved GNA(MW)	Margin for T-GNA (MW)	Changes w.r.t. Previous Revision	Comment
ER	01 Nov to 30 Nov	00:00 to 24:00	NA	NA		3088	NA	0	
NER	01 Nov to 30 Nov	00:00 to 07:00	1320	60	1260	446	814	0	
		07:00 to 12:00	1220	60	1160	446	714	0	
		12:00 to 17:00	1150	60	1090	446	644	0	
		17:00 to 21:00	900	60	840	446	394	0	
		21:00 to 24:00	1320	60	1260	446	814	0	
NR	01 Nov to 30 Nov	00:00 to 06:00	25900	1400	24500	17344	7156	0	
		06:00 to 18:00	25900	1400	24500	17344	7156	0	
		18:00 to 24:00	25900	1400	24500	17344	7156	0	
SR	01 Nov to 30 Nov	00:00 to 06:00	22300	1000	21300	7101	14199	0	Revised T-GNA margin due to approval of 500 MW GNA for Andhra Pradesh from Outside Southern Region
		06:00 to 18:00	22300	1000	21300	7101	14199	0	
		18:00 to 24:00	22300	1000	21300	7101	14199	0	
WR	01 Nov to 30 Nov	00:00 to 24:00	NA	NA		7788	NA	0	

- Based on the actual distribution of corridor flows, Counter flow benefit on account of transactions in the reverse direction would be considered for short-term transactions wherever applicable.
- Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.
- S1 comprises of Telangana, AP and Karnataka; S2 comprises of Tamil Nadu and Puducherry; S3 comprises Kerala
- W3 comprises of the following regional entities : a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) NTPC Korba I, II & III, j) NTPC Sipat I & II, k) KSK Mahanadi, l) DB Power, m) REGL (Previously KWPC), n) RKM, o) REL, p) Bharat Aluminium, q) MCCPL, r) SKS, s) TRN, t) NTPC Lara, u) Adani Power Limited Raipur and any other regional entity generator in Chhattisgarh
- The figure is based on GNA approved by CTU. In actual Operation, due to Units being on Maintenance/ Fuel shortage/New units being commissioned, the dispatches of units would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.
- In case of TTC Revision due to any shutdown : 1) The TTC value will be revised to normal values after restoration of shutdown. 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.
- Real Time TTC/ATC revisions are uploaded on Grid-India/NLDC "News Update" (Flasher) Section

### Simultaneous Export Capability

Corridor	Date	Time Period(hrs)	Total Transfer Capability(TTC)	Reliability Margin(RM)	Available Transfer Capability(ATC)	Approved GNA(MW)	Margin for T-GNA (MW)	Changes w.r.t. Previous Revision	Comment
ER	01 Nov to 30 Nov	00:00 to 24:00	NA	NA		NA		0	
NER	01 Nov to 30 Nov	00:00 to 17:00	3480	60	3420	NA		0	
		17:00 to 21:00	3480	60	3420	NA		0	
		21:00 to 24:00	3480	60	3420	NA		0	

Corridor	Date	Time Period(hrs)	Total Transfer Capability(TTC)	Reliability Margin(RM)	Available Transfer Capability(ATC)	Approved GNA(MW)	Margin for T-GNA (MW)	Changes w.r.t. Previous Revision	Comment
NR	01 Nov to 30 Nov	00:00 to 06:00	4000	500	3500	NA		0	
		06:00 to 18:00	4000	500	3500	NA		0	
		18:00 to 24:00	4000	500	3500	NA		0	
SR	01 Nov to 30 Nov	00:00 to 06:00	5150	650	4500	NA		0	
		06:00 to 18:00	6600	650	5950	NA		0	
		18:00 to 24:00	5150	650	4500	NA		0	
WR	01 Nov to 30 Nov	00:00 to 24:00	NA	NA		NA		0	

- Based on the actual distribution of corridor flows, Counter flow benefit on account of transactions in the reverse direction would be considered for short-term transactions wherever applicable.
- Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.
- S1 comprises of Telangana, AP and Karnataka; S2 comprises of Tamil Nadu and Puducherry; S3 comprises Kerala
- W3 comprises of the following regional entities : a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) NTPC Korba I, II & III, j) NTPC Sipat I & II, k) KSK Mahanadi, l) DB Power, m) REGL (Previously KWPC), n) RKM, o) REL, p) Bharat Aluminium, q) MCCPL, r) SKS, s) TRN, t) NTPC Lara, u) Adani Power Limited Raipur and any other regional entity generator in Chhattisgarh
- The figure is based on GNA approved by CTU. In actual Operation, due to Units being on Maintenance/ Fuel shortage/New units being commissioned, the dispatches of units would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.
- In case of TTC Revision due to any shutdown : 1) The TTC value will be revised to normal values after restoration of shutdown. 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.
- Real Time TTC/ATC revisions are uploaded on Grid-India/NLDC "News Update" (Flasher) Section

## Limiting Constraints

Corridor	Constraints	Revisions
WR-NR	N-1 contingency of one ckt of 765 kV Vindhyachal-Varanasi will overload the other circuit	0-3
NR-ER	1. Overloading of one circuit of 400 kV New Ranchi – New PPSP D/C on the tripping of the other circuit 2. Overloading of one circuit of 400 kV Kahalgaon – Farakka D/C on the tripping of the other circuit 3. Overloading of 400 kV Farakka – Sagardighi – 1 on the tripping of 400 kV Farakka – Sagardighi - 2	0-3
WR-ER	1. Overloading of one circuit of 400 kV New Ranchi – New PPSP D/C on the tripping of the other circuit 2. Overloading of one circuit of 400 kV Kahalgaon – Farakka D/C on the tripping of the other circuit 3. Overloading of 400 kV Farakka – Sagardighi – 1 on the tripping of 400 kV Farakka – Sagardighi - 2	0-3
ER-NR	Inter-regional flow pattern towards NR	0-3
WR-SR	Outage of any one of the 2x1500 MVA, 765/400 kV ICTs at Maheswaram overloads the other ICT	0-3
ER-SR	1. Low Voltage at Gazuwaka (East) Bus.	0-3
SR-WR	a) Angular separation between Kudgi & Kolhapur (PG) under N-1 of 400 kV Kudgi - Kolhapur (PG) D/C touches 30 deg b) N-1 non-compliance of 2*1500 MVA, 765/400 kV ICTs at Section– A at Raigarh - PS(Kotra) with increase in HVDC Raigarh – Pugalur Bipole – II power order beyond 950 MW in SR to WR Direction (Solar Hours) c) N-1 non-compliance of 2*1500 MVA, 765/400 kV ICTs at Section– B at Raigarh -PS (Kotra) with increase in HVDC Raigarh – Pugalur Bipole – I power order beyond 450 MW in SR to WR Direction (Solar Hours) d) N-1 Contingency of 400 kV Pune – Kalwa will overload 400 kV Pune -Khargar and vice-versa	0-3
ER-NER	a) N-1 contingency of 400 kV Bongaigaon - Azara line b) High Loading of 220 kV Balipara-Sonabil D/C	0-3
NER-ER	a) N-1 contingency of 400 kV Bongaigaon-Alipurduar I or II b) High Loading of 400 kV Bongaigaon-Alipurduar II or I	0-3
NR_IMPORT	N-1 contingency of one ckt of 765 kV Vindhyachal-Varanasi will overload the other circuit	0-3
NR_EXPORT	(N-1) Contingency of 400 kV Kankroli-Zerda-S/C will overload 400 kV Bhinmal-Zerda-S/C	0-3
NER_IMPORT	a) N-1 contingency of 400 kV Bongaigaon - Azara line b) High Loading of 220 kV Balipara-Sonabil D/C	0-3
NER_EXPORT	a) N-1 contingency of 400 kV Bongaigaon-Alipurduar I or II b) High Loading of 400 kV Bongaigaon-Alipurduar II or I	0-3
SR_IMPORT	1. Outage of any one of the 2x1500 MVA, 765/400 kV ICTs at Maheswaram overloads the other ICT 2. Low Voltage at Gazuwaka (East) Bus	0-3
SR_EXPORT	a) Angular separation between Kudgi & Kolhapur (PG) under N-1 of 400 kV Kudgi - Kolhapur (PG) D/C touches 30 deg b) N-1 non-compliance of 2*1500 MVA, 765/400 kV ICTs at Section– A at Raigarh - PS(Kotra) with increase in HVDC Raigarh – Pugalur Bipole – II power order beyond 950 MW in SR to WR Direction (Solar Hours) c) N-1 non-compliance of 2*1500 MVA, 765/400 kV ICTs at Section– B at Raigarh -PS (Kotra) with increase in HVDC Raigarh – Pugalur Bipole – I power order beyond 450 MW in SR to WR Direction (Solar Hours) d) N-1 Contingency of 400 kV Pune – Kalwa will overload 400 kV Pune -Khargar and vice-versa	0-3

**Revision Summary**

Revision	Date Of Revision	Period Of Revision	Reason for Revision/Comment	Corridor Affected
1	28 Dec	01 Nov to 30 Nov	Change in T-GNA Margin due to grant of additional 174 MW GNA to Uttar Pradesh from outside Northern Region	NR_IMPORT
		01 Nov to 30 Nov	Change in T-GNA Margin due to grant of additional 55 MW GNA to Mizoram from outside North Eastern Region	NER_IMPORT
2	26 Jan	01 Nov to 30 Nov	TTC/ATC revised in view of change in load generation balance and inter-regional flow pattern towards NR	WR-NR
		01 Nov to 30 Nov	TTC/ATC revised in view of change in load generation balance and inter-regional flow pattern towards NR	ER-NR
		01 Nov to 30 Nov	TTC/ATC increased with the Commissioning of 765/400 kV, 1500 MVA ICT - 3 at Nizamabad and Change in LGB	WR-SR
		01 Nov to 30 Nov	TTC/ATC increased with the Commissioning of 765/400 kV, 1500 MVA ICT - 3 at Nizamabad and Change in LGB	ER-SR
		01 Nov to 30 Nov	TTC/ATC revised in view of change in load generation balance and inter-regional flow pattern towards NR	NR_IMPORT
		01 Nov to 30 Nov	TTC/ATC increased with the Commissioning of 765/400 kV, 1500 MVA ICT - 3 at Nizamabad and Change in LGB	SR_IMPORT
3	28 Feb	01 Nov to 30 Nov	Revised T-GNA margin due to approval of 500 MW GNA for Andhra Pradesh from Outside Southern Region	SR_IMPORT

ASSUMPTIONS IN BASECASE					
Month : November'24					
S.No.	Name of State/Area	Demand		Generation	
		Non-Solar Peak(MW)	Solar Peak (MW)	Non-Solar Peak(MW)	Solar Peak (MW)
I	<b>NORTHERN REGION</b>				
1	Punjab	6786	6770	3900	3660
2	Haryana	6932	7300	1426	3659
3	Rajasthan	13840	17619	6944	8474
4	Delhi	4003	4328	365	314
5	Uttar Pradesh	18915	17337	10369	10075
6	Uttarakhand	1977	1728	821	366
7	Himachal Pradesh	1660	1709	595	306
8	Jammu & Kashmir	2278	2673	226	230
9	Chandigarh	203	176	0	0
10	ISGS/IPPs	114	115	19978	22204
	<b>Total NR</b>	<b>56708</b>	<b>59755</b>	<b>44624</b>	<b>49288</b>
II	<b>EASTERN REGION</b>				
1	Bihar	5084	4030	445	436
2	Jharkhand	1645	1700	406	427
3	Damodar Valley Corporation	3510	3400	5600	5332
4	Orissa	6186	6000	3818	3764
5	West Bengal	7660	8000	6462	6115
6	Sikkim	106	98	0	0
7	Bhutan	33	49	307	372
8	ISGS/IPPs	920	728	16923	17242
	<b>Total ER</b>	<b>25143</b>	<b>24005</b>	<b>33962</b>	<b>33688</b>
III	<b>WESTERN REGION</b>				
1	Maharashtra	25755	29506	16723	19565
2	Gujarat	18687	20689	8270	8865
3	Madhya Pradesh	14705	17125	7923	9952
4	Chattisgarh	4208	3970	1768	1801
5	DD & DNH	971	974	0	0
6	Goa-WR	674	676	0	0
7	ISGS/IPPs	2490	2493	47245	48284
	<b>Total WR</b>	<b>67491</b>	<b>75433</b>	<b>81929</b>	<b>88468</b>

IV	SOUTHERN REGION				
1	Andhra Pradesh	9057	12431	5376	7080
2	Telangana	7435	9730	4578	7247
3	Karnataka	10750	13304	5081	7257
4	Tamil Nadu	16629	16830	5755	9952
5	Kerala	4253	3484	1637	646
6	Pondy	578	575	25	40
7	Goa-SR	87	87	0	0
8	ISGS/IPPs	12	12	21969	20081
	Total SR	48800	56452	44422	52305
V	NORTH-EASTERN REGION				
1	Arunachal Pradesh	164	100	0	0
2	Assam	1430	1140	271	444
3	Manipur	260	138	0	0
4	Meghalaya	468	348	139	13
5	Mizoram	169	140	31	8
6	Nagaland	157	119	14	7
7	Tripura	366	316	190	193
8	ISGS/IPPs	0	0	3215	2609
	Total NER	3014	2301	3860	3274
	Total All India	201120	217890	208385	226545