National Load Despatch Centre Total Transfer Capability for November 2017

Issue Date: 29th September 2017 Issue Time: 1800 hrs Revision No. 3

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
	1st November	00-06				55	1945		
NR-WR*	2017 to 30th	06-18	2500	500	2000	65	1935		
	November 2017	18-24				55	1945		
WR-NR*	1st November 2017 to 30th November 2017	00-24	10050	500	9550	8368	1182	1000	Revised TTC due to commissioning and commercial operation of HVDC Champa Kurukshetra pole II and revised STOA margins due to change in LTA/MTOA approved by CTU
	1st November	00.06	2000		1900	102	1607	T	
NR-ER*	2017 to 30th	00-06 06-18	2000	200	1800 1800	193 303	1607 1497	_	
MK-EK.	November 2017	18-24	2000	200	1800	193	1607		
ER-NR*	1st November 2017 to 30th November 2017	00-24	4500	300	4200	3030	1170		
W3-ER	1st November 2017 to 30th November 2017	00-24	No limit is being specified.						
ER-W3	1st November 2017 to 30th November 2017	00-24	No limit is being specified.						
WR-SR	1st November 2017 to 30th November 2017	00-05 05-22 22-24	4700 4700 4700	500	4200 4200 4200	3710	490 490 490		Revised STOA margins due to change in LTA/MTOA approved by CTU
SR-WR*	1st November 2017 to 30th November 2017	00-24	No limit is being Specified.						
	1st November	00.06				2200	211		Paying STOA marries due to
ER-SR	2017 to 30th November 2017	00-06 06-18' 18-24	3750	250	3500	3289 3374 3289	211 126 211		Revised STOA margins due to change in LTA/MTOA approved by CTU
SR-ER*	1st November 2017 to 30th November 2017	00-24	No limit is being Specified.						

National Load Despatch Centre Total Transfer Capability for November 2017

Issue Date: 29th September 2017 Issue Time: 1800 hrs Revision No. 3

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
	1-4 N	00.17	1120		1075		050		
ED MED	1st November	00-17	1120	4.5	1075	225	850		
ER-NER	2017 to 30th	17-23	1010	45	965	225	740		
	November 2017	23-24	1120		1075		850		
	1st November	00-17	1340		1295		1295		
NER-ER	2017 to 30th	17-23	1260	45	1215	0	1215		
	November 2017	23-24	1340		1295		1295		
W3 zone Injection	1 2017 to 30th 1 00-24 INo limit is being specified (In case of any constraints appearing in the system, W.3 zone export would be revised accordingly)								
Note: TTC/	ATC of S1-(S2&S	83) corrid	or, Import of	S3(Kerala),	Import of Pur	ijab and Import o	f DD & DNH is u	ploaded or	NLDC website under Intra-
Regional Se	ction in Monthly	ATC.							

^{*} Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

- 1) S1 comprises of Telangana, AP and Karnataka; S2 comprises of Tamil Nadu and Puducherry; S3 comprises Kerala
- 2) W3 comprises of the following regional entities:
- a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak
- f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPCL, n)Vandana Vidyut o)RKM, p)GMR Raikheda, q)Ind Barath and any other regional entity generator in Chhattisgarh

The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/Fuel shortage/New units being commissionned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

In case of TTC Revision due to any shutdown :

- 1) The TTC value will be revised to normal values after restoration of shutdown.
- 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.

Simultaneous Import Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER									
		00-05	14350		13550		2152	1450	Revised TTC due to commissioning and
	1st November	05-08	14350		13550		2152	1450	commercial operation of
NR	2017 to 30th	08-18	14350	800	13550	11398	2152	1450	HVDC Champa Kurukshetra pole II and revised STOA margins due to change in LTA/MTOA approved by CTU
	November 2017	18-23	13050		12250		852	1450	
		23-24	14350		13550		2152	1450	
	1st November	00-17	1120		1075		850		
NER	2017 to 30th	17-23	1010	45	965	225	740		
	November 2017	23-24	1120		1075		850		
WR									
		00-05	8450		7700	6998	702		
	1st November	05-06	8450	•	7700	6998	702		Revised STOA margins
SR	2017 to 30th	06-18	8450	750	7700	7083	617		due to change in
	November 2017	18-22	8450	•	7700	6998	702		LTA/MTOA approved by
		22-24	8450		7700	6998	702		CTU

^{*} Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

* For approving STOA Bilateral transactions, margin available in Simultaneous Import of NR would be apportioned on WR-NR Corridor & ER-NR Corridor in the following ratio:

Margin in Simultaneous import of NR = A

WR-NR ATC =B

ER-NRATC = C

Margin for WR-NR applicants = A * B/(B+C)

Margin for ER-NR Applicants = A * C/(B+C)

Simultaneous Export Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments		
	1st November 00-06 450	4500	600	3800	248	3552					
NR*	2017 to 30th	06-18'		700	3800	368	3432				
	November 2017	18-24	4500		3800	248	3552				
	1st November	00-17	1340 1260	45	1295	0	1295				
NER	2017 to 30th	17-23			1215		1215				
	November 2017	23-24	1340		1295		1295				
WD											
WR											
	1st November			No limit is being Specified.							
SR *	2017 to 30th	00-24									
	November 2017										

^{*} Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Limiting Constraints (Corridor wise)

		Applicable Revisions
Corridor	Constraint	
NR-WR	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak	All
WR-NR	1. (n-1) Contingnecy of 765kV Gwalior-Agra one ckt leads to 2750 MW loading on second circuit. 2.High Loading of 400kV Singrauli-Anpara S/C.	All
NR-ER	(n-1) contingency of 400 kV Saranath-Pusauli	All
ER-NR	(n-1) contingencies of N.Ranchi - Chandawa S/c & (n-1) contingencies of 400kV MPL- Maithon S/c	All
WR-SR	(n-1) contingency of 400 kV Dichipalli-Ramagundam or one ckt of 765 kV Aurangabad-Solapur D/C will lead to 874 MW loading on 400kV Vemagiri(PG)-Gazuwaka (With Opening of 400kV Vemagiri(PG)-Nunna S/C)	All
w Lit	 a. (n-1) contingency of 400 kV Vemagiri - Vijaywada S/C will lead to high loading (874 MW) on 400 kV Vemagiri - Gazuwaka S/C b. N-1 contingency of 765/400 kV 2x1500 MVA Maheswaram (PG) ICTs results in high loading of other ICT 	All except Rev 0-1
	Low Voltage at Gazuwaka (East) Bus.	All
ER-NER	a. (n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa b. High loading of 220 kV Balipara-Sonabil line(200 MW)	All
NER-ER	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other 400/220 kV, 315 MVA ICT at Misa	All
W3 zone Injection		All

Limiting Constraints (Simultaneous)

			Applicable Revisions
NR	Import	(n-1) contingencies of N.Ranchi - Chandawa S/c & (n-1) contingencies of 400kV MPL- Maithon S/c. 1. (n-1) Contingency of 765kV Gwalior-Agra one ckt leads to 2750 MW loading on second circuit. 2. High Loading of 400kV Singrauli-Anpara S/C.	All
E	Export	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak. (n-1) contingency of 400 kV Saranath-Pusauli	All
NER	Import	a. (n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa b. High loading of 220 kV Balipara-Sonabil line(200 MW)	All
NER -	Export	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other 400/220 kV, 315 MVA ICT at Misa.	All
		(n-1) contingency of 400 kV Dichipalli-Ramagundam or one ckt of 765 kV Aurangabad-Solapur D/C will lead to 874 MW loading on 400kV Vemagiri(PG)-Gazuwaka (With Opening of 400kV Vemagiri(PG)-Nunna S/C)	All
SR	Import	a. (n-1) contingency of 400 kV Vemagiri - Vijaywada S/C will lead to high loading (874 MW) on 400 kV Vemagiri - Gazuwaka S/C b. N-1 contingency of 765/400 kV 2x1500 MVA Maheswaram (PG) ICTs results in high loading of other ICT	All except Rev 0-1
		Low Voltage at Gazuwaka (East) Bus.	All

National Load Despatch Centre Total Transfer Capability for November 2017

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor Affected
1	31st July 2017	Whole month	Revised considering the change in LTA/MTOA granted by CTU	WR- NR/Import of NR
2	20th Sepetmber 2017	Whole month	Revised considering commissioning and commercial operation of 765 kV Nizamabad - Maheswaram D/C, 765/400 kV 2x1500 MVA ICTs at Maheswaram, 400 kV Maheswaram(PG) - Maheswaram D/C, 400/220 kV 1x500 MVA ICTs at Maheswaram, 400 kV Maheswaram(PG) - Kurnool S/C and 400 kV Maheswaram - Ghanapur S/C (LILO of 400 kV Ghanapur - Kurnool S/C)	ER-SR / WR- SR / Import of SR
29th		Whole month	Due to commissioning and commercial operation of HVDC Champa Kurukshetra pole II and change in LTA/MTOA as approved by CTU	WR-NR / Import of NR
3	Sepetmber 2017	whole month	Revised STOA margins to change in LTA/MTOA approved by CTU	WR-SR / ER- SR/Import of SR

ASSUN	MPTIONS IN BASECASE				
				Month: Nov'17	
S.No.	Name of State/Area	Load		Generation	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
I	NORTHERN REGION	,	,	,	ì
1	Punjab	5076	3313	2505	2469
2	Haryana	6779	3330	1533	1533
3	Rajasthan	10005	10899	5097	5121
4	Delhi	3244	1750	755	755
5	Uttar Pradesh	15422	13884	8026	7851
6	Uttarakhand	1899	1518	848	390
7	Himachal Pradesh	1421	1282	195	85
8	Jammu & Kashmir	2496	2504	551	356
9	Chandigarh	175	91	0	0
10	ISGS/IPPs	26	26	17096	8611
	Total NR	46543	38599	36606	27171
II	EASTERN REGION				
1	Bihar	4062	2536	202	181
2	Jharkhand	1290	891	197	190
3	Damodar Valley Corporation	3068	2634	4868	3974
4	Orissa	4265	3347	3232	2292
5	West Bengal	7139	5869	5379	4539
6	Sikkim	88	50	0	0
7	Bhutan	212	216	1434	1434
8	ISGS/IPPs	267	263	11767	8535
	Total ER	20389	15807	27079	21146
Ш	WESTERN REGION				
1	Maharashtra	17837	13518	12629	10871
2	Gujarat	12982	10844	9406	8143
3	Madhya Pradesh	11007	8265	5273	4547
4	Chattisgarh	3620	2188	2520	1990
5	Daman and Diu	312	269	0	0
6	Dadra and Nagar Haveli	635	686	0	0
7	Goa-WR	570	316	0	0
8	ISGS/IPPs	3903	3510	34513	29450
	Total WR	50865	39597	64342	55002

IV	SOUTHERN REGION				
1	Andhra Pradesh	7515	6742	5781	3958
2	Telangana	7346	5433	4521	2775
3	Karnataka	10351	8454	5936	4350
4	Tamil Nadu	13800	11600	6869	5544
5	Kerala	3743	2200	1400	141
6	Pondy	387	387	0	0
7	Goa-SR	87	87	0	0
8	ISGS/IPPs	0	0	13456	12330
	Total SR	43229	34903	37963	29098
V	NORTH-EASTERN REGION				
1	Arunachal Pradesh	122	63	0	0
2	Assam	1057	825	230	140
3	Manipur	147	87	0	0
4	Meghalaya	307	203	145	82
5	Mizoram	89	65	8	8
6	Nagaland	97	81	8	6
7	Tripura	197	185	83	82
8	ISGS/IPPs	160	60	1677	1260
	Total NER	2176	1569	2151	1578
	T	100111	100701	40000	105100
	Total All India	163444	130721	169633	135488