National Load Despatch Centre Total Transfer Capability for October 2013

Issue Date: 03/10/2013

Issue Time: 1300 hrs

Revision No. 6

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR-WR*	1st October 2013 to 31st October 2013	00-24	2500	500	2000	LTA -286 MW	1714		
WR-NR ¹	1st October 2013 to 31st October 2013	00-17 23-24 17-23	3700 3700	500	3200 3200	LTA - 3176 MW	24 24		
			5700		3200		24		
NR-ER*	1st October 2013 to	00-17 23-24	1000	200	800	0	800		
	31st October 2013	17-23	1100		900	-	900		
ER-NR	1st October 2013 to 31st October 2013	00-17 23-24 17-23	4000	300	3700	LTA- 2189 MW	1511 1511		
	1 + 0 + 1 - 2012 +		і. Г						
W3-ER	1st October 2013 to 31st October 2013	00-24	1800	300	1500	0	1500		
ER-W3	1st October 2013 to 31st October 2013	00-24	1000	300	700	700	0		
	1st October 2013 to					LTA: 316 MW			
WR-SR	31st October 2013	00-24	1000	0	1000	MTOA: 684 MW Total:1000 MW	0		
SR-WR*	1st October 2013 to 31st October 2013	00-24	1000	0	1000	0	1000		
	1st October 2013	00-05	700	0	700	LTA:35 MW,	88		
		10-19 05-10				MTOA: 577 MW, Total- 612 MW			
	2nd October 2013 to 3rd October 2013	19-24 00-05	700		700	Total 012 Mill	88		
		10-19	750	0	750	612	138		
		05-10 19-24	1250	200	1050		438		
	4th October 2013	00-05	750	0	750		138		
		05-06 19-24	1250	200	1050	612	438		
ER-SR		06-10' 10-19'	950 450	200	750 450		138	-300 -300	Revised due to shutdown of 400 kV Meramundli-Angul-Bolangir
ER-5R		00-05	750	0	750		138	-300	too k Chiefananan Tingar Dolangi
	05th October 2013	10-19 05-10	1250	200	1050	612	438		
		19-24 00-05	750	0	750		138		
	6th October 2013 to 16th October 2013	10-19 05-10				612			
		19-24 00-05	1250	200	1050		438		
	17th October 2013 to 31st October 2013	10-19	830	0	830	612	218		
	5131 October 2015	05-10 19-24	830	0	830		218		
SR-ER*	1st October 2013 to 31st October 2013	00-17 23-24	800	0	800	197	603		
	5131 October 2015	17-23	900		900		703		
	1.0.1.0010	00-08 23-24	680	0.5	645		415		
ER-NER	1st October 2013	08-17'	480	35	445	LTA - 230 MW	215		
EK-IVEK	2nd October 2013 to	17-23 00-17	590 680		555 645		325 415		
	31st October 2013	23-24 17-23	590	35	555	230 MW	325		
NED ED	1st October 2013 to	00-17	500	100	400	0	400		
NER-ER	31st October 2013	23-24 17-23	440	100	340	0	340		
	1 . 0 . 1 . 2012					LTA: 4100MW			
S1-S2	1st October 2013 to 31st October 2013	00-24	5600	400	5200	MTOA:700 MW Total: 4800 MW	400		
Import of Punjab	1st October 2013 to 31st October 2013	00-24	5600	300	5300	3800	1500		
i unjan	5150 000000 2015								

National Load Despatch Centre Total Transfer Capability for October 2013

Issue Date: 03/10/2013

Issue Time: 1300 hrs

Revision No. 6

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
Import TTC for DD & DNH	1st October 2013 to 31st October 2013	00-24	980	0	980	LTA and MTOA as per ex-pp schedule			
W3 zone Injection	1st October 2013 to 31st October 2013	00-17, 23-24	9000 9500	200	8800 9300	LTA-6162 MW, MTOA-1211 MW, Total- 7373 MW	1427 1927		

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

ER-SR TTC declared at Talcher Interconnector and Gazuwaka HVDC B/B seam
 S1 comprises of AP and Karnataka: S2 comprises of Tamil Nadu, Kerala and Pondicherry
 W3 comprises of the following regional entities :

 a) Chattisgarh, b) Jindal Power Limited (JPL), c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak
 BALCO, g) Sterlite (1,3,4), h) NSPCL, i) Korba, j) Sipat, k)KSK Mahanadi, L)KWPCL, M) DB Power, N) Vandana Vidyut

The figure is based on LTA/MTOA approved by CTU. In actual Operation, due to Units being on Maintenance/ Fuel shortage the LTA/MTOA utilized would be les. RLDC/ NLDC would factor this situation while issuing STOS approvals.

1. WR-NR Total Transfer capability will be reduced to 3100 MW in case of outage of any one of the following sections: 765 kV Gwalior-Agra one circuit 765 kV Bina-Gwalior one circuit

Limiting Constraints

Corridor	Constraint
NR-WR	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.
WR-NR	High loading of 765 kV Agra-Gwalior (1000 MW SPS setting on each circuit of 765 kV Gwalior-Agra)
NR-ER	(n-1) contingency of 400 kV Allahabad-Pusauli
ER-NR	(n-1) contingency of 400 kV Farakka-Malda
W3-ER	(n-1) contingency of 400kV Sterilte-Rourkela S/C
ER-W3	High loading of 400 kV Raipur-Bhadrawati T/C, Bhilai-Bhadrawati S/C, Bhilai-Koradi and Bhilai-Seoni* (n-1) contingency of 400kV Raigarh-Sterlite
WR-SR	Bhadrawati HVDC B/B link capacity
SR-WR	Bhadrawati HVDC B/B link capacity
ER-SR	Off-Peak: 1. Talcher-Kolar HVDC Capacity; 2. (n-1) contingency of 400 kV Jeypore-Gazuwaka Peak: 1. Talcher-Kolar HVDC Capacity; 2. (n-1) contingency of 400 kV Jeypore-Gazuwaka
SR-ER	
ER-NER	(n-1) contingency of 400/220 kV,315 MVA ICT at Misa* (n-1) contingency of 400 kV Binaguri-Bongaigaon
NER-ER	(n-1) contingency of 400 kV Binaguri-Bongaigaon* Insufficient generating resources in NER
S1-S2	(n-1) contingency of 400 kV Kolar-Hosur D/C line, 400kV Hosur-Salem S/C and 400kV Somanahalli-Salem S/C line.
Import of Punjab	(n-1) contingency of ICT at Patiala/Moga
W3 zone Injection	(n-1-1) contingency of 400 kV Raipur-Bhadrawati D/C section

*Primary constraints

Simultaneous Import Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER									
NR ¹	1st October 2013 to 31st October 2013	00-17 23-24 17-23	7700 7700	800	6900 6900	LTA-5365 MW	1535 1535		
	1st October 2013	00-08 23-24 08-17'	680 480	35	645 445	LTA-230 MW	415 215		
NER	2nd October 2013 to 31st October 2013	17-23 00-17 23-24 17-23	590 680 590	35	555 645 555	230	325 415 325		
WR		17 20					020		
	1st October 2013	00-05 10-19	1700	0	1700	LTA-351 MW, MTOA- 1261 MW, Total- 1612 MW	88		
		05-10 19-24	1700		1700		88		
	2nd October 2013 to 3rd October 2013	00-05 10-19 05-10	1750	0	1750	1612	138		
		19-24	2250	200	2050		438		
		00-05 05-06 19-24	1750 2250	0 200	1750 2050		138 438		
	4th October 2013	06-10'	1950	200	1750	1612	138	-300	Revised due to shutdown of 400 kV Meramundli-Angul-
SR		10-19'	1450	0	1450		0	-300	Bolangir
	05th October 2013	00-05 10-19	1750	0	1750	1612	138		
		05-10 19-24	2250	200	2050		438		
	6th October 2013 to 16th October 2013	00-05 10-19 05-10	1750	0	1750	1612	138		
	1001 October 2015	03-10 19-24 00-05	2250	200	2050		438		
	17th October 2013 to 31st October 2013	10-19 05-10	1830	0	1830	1612	218		
	5150 000001 2015	19-24	1830		1830		218		

WR-NR Total Transfer capability will be reduced to 3100 MW in case of outage of any one of the following sections:
 • 765 kV Gwalior-Agra one circuit
 • 765 kV Bina-Gwalior one circuit

Simultaneous Export Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR	1st October 2013 to	00-17 23-24	3500	700	2800	286	2514		
	31st October 2013	17-23	3600		2900		2614		
NER	1st October 2013 to 31st October 2013	00-17 23-24	500	100	400	0	400		
		17-23	440		340		340		
WR									
WK									
SR	1st October 2013 to	00-17 23-24	1800	0	1800	197	1603		
	31st October 2013	17-23	1900		1900		1703		

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

The figure is based on LTA/MTOA approved by CTU. In actual Operation, due to Units being on Maintenance/ Fuel shortage the LTA/MTOA utilized would be les. RLDC/ NLDC would factor this situation while issuing STOS approvals.

Limiting Constraints

NR -	Import	(n-1) contingency of 400 kV Faarakka-Malda* High loading of 765 kV Agra-Gwalior (1000 MW SPS setting on each circuit of 765 kV Gwalior-Agra)						
	Export	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak. (n-1) contingency of 400 kV Allahabad-Pusauli						
NER	Import (n-1) contingency of 400/220 kV,315 MVA ICT at Misa* (n-1) contingency of 400 kV Binaguri-Bongaigaon							
NER	Export	(n-1) contingency of 400 kV Binaguri-Bongaigaon* Insufficient generating resources in NER						
SR	Import	Bhadrawati HVDC B/B link capacity Off-Peak(ER-side): 1. Talcher-Kolar HVDC Capacity; 2. (n-1) contingency of 400 kV Jeypore-Gazuwaka Peak(ER-side): 1. Talcher-Kolar HVDC Capacity; 2. (n-1) contingency of 400 kV Jeypore-Gazuwaka						
	Export							

*Primary constraints

Revision No	Date of Revision	Period of revision	Reason for Revision	Corridor Affected
1	26/08/2013	Whole Month	Revised due to Allocation of 150 MW additional power to J&K.	WR-NR
2	28/08/2013	Whole Month	Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).	NR-WR, NR-ER, SR-WR, SR-ER
3	10/09/2013	Whole Month	Revised due to commissioning of Sasan UMPP Unit 30 Increase in share of Punjab from Sasan, DSTPS, Parbati-III	WR-NR Import of Punjab
4	28/09/2013	Whole Month	Revised considering SPS setting of 1000 MW on each circuit of 765 kV Agra-Gwalior	WR-NR
4		1st Oct	Revised considering present load generation balance and shutdown of 220 kV BTPS-Salakati D/C	ER-NER
			Revised due to shutdown of Unit-1 of Talcher Stage-I and also due to change in LGBR	ER-SR
5	30/09/2013	Whole Month	Revised due to Non-Commissioning of Kudankulam Unit-1	S1-S2
		Whole Month	Margin revised considering reduction in MTOA quantum.	W3 zone Injection
6	03/10/2013	04th Oct	Revised due to shutdown of 400 kV Meramundli-Angul-Bolangir	ER-SR

National Load Despatch Centre Total Transfer Capability for October 2013

ASSUMPTIONS IN BASECASE

Month : October '13

		Loa	ad	Generation			
S.No.	Name of State/Area	Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)		
I	NORTHERN REGION						
1	Punjab	7000	4924	2546	2351		
2	Haryana	5559	4660	2770	2770		
3	Rajasthan	7051	6539	4002	4002		
4	Delhi	3974	3720	1514	1514		
5	Uttar Pradesh	11000	10322	6008	5756		
6	Jammu & Kashmir	1876	1185	584	429		
7	Uttarakhand	1543	902	713	340		
8	Himachal Pradesh	1327	730	444	523		
9	Chandigarh	224	118	0	0		
10	ISGS/IPPs			16740	11303		
	Total NR	39554	33100	35321	28988		
II	EASTERN REGION						
1	West Bengal	4900	4500	4837	3944		
2	Jharkhand	1110	770	561	561		
3	Orissa	3500	2200	2430	1699		
4	Bihar	1820	1320	0	0		
5	Damodar Valley Corporation	2600	2035	3439	3039		
6	Sikkim	40	40				
7	Bhutan	110	110	648	648		
8	ISGS/IPPs	131	241	6494	6762		
	Total ER	14211	11216	18409	16653		
	WESTERN REGION						
1	Chattisgarh	3181	2462	1804	1065		
2	Madhya Pradesh	7637	5600	9905	7817		
3	Maharashtra	15506	12500	4366	2928		
4	Gujarat	11119	10121	11221	8374		
5	Goa	432	281	0	0		
6	Daman and Diu	245	208	0	0		
7	Dadra and Nagar Haveli	604	471	0	0		
8	ISGS/IPPs	590	590	16763	15466		
	Total WR	39314	32233	44059	35650		

IV	SOUTHERN REGION				
1	Andhra Pradesh	10900	9350	7204	6066
2	Tamil Nadu	11300	8617	6433	4962
3	Karnataka	7800	6499	5213	3549
4	Kerala	3225	2234	1917	760
5	Pondy	320	244	0	0
6	Goa	80	80	0	0
7	ISGS/IPPs			11130	10168
	Total SR	33625	27024	31897	25505
V	NORTH-EASTERN REGION				
1	Manipur	130	91	0	0
2	Meghalaya	280	196	110	95
3	Mizoram	85	60	8	4
4	Nagaland	120	84	20	10
5	Assam	1350	970	220	180
6	Tripura	260	130	100	100
7	Arunachal Pradesh	130	91	0	0
8	ISGS/IPPs	·		1020	735
	Total NER	2355	1622	1478	1124
		100050	405405	404404	107000
	Total All India	129059	105195	131164	107920