

**National Load Despatch Centre
Total Transfer Capability for Oct 2022**

Issue Date:Oct 15 2022

Issue Time:10:40:09

Revision No :11

Corridor	Date	Time Period(hrs)	Total Transfer Capability(TTC)	Reliability Margin(RM)	Available Transfer Capability(ATC)	Long Term Access(LTA)/Medium Term Open Access(MTOA)	Margin Available For Short Term Open Access(STOA)	Chnages w.r.t. Previous Revision	Comment
ER-NER	01 Oct to 05 Oct	00:00 to 17:00	1620	60	1560	455	1105	0	
		17:00 to 21:00	1415	60	1355	455	900	0	
		21:00 to 24:00	1620	60	1560	455	1105	0	
	06 Oct to 06 Oct	00:00 to 09:00	1620	60	1560	455	1105	0	
		09:00 to 17:00	1500	60	1440	455	985	0	
		17:00 to 21:00	1215	60	1155	455	700	0	
		21:00 to 24:00	1500	60	1440	455	985	0	
	07 Oct to 07 Oct	00:00 to 17:00	1500	60	1440	455	985	0	
		17:00 to 21:00	1215	60	1155	455	700	0	
		21:00 to 24:00	1500	60	1440	455	985	0	

Corridor	Date	Time Period(hrs)	Total Transfer Capability(TTC)	Reliability Margin(RM)	Available Transfer Capability(ATC)	Long Term Access(LTA)/Medium Term Open Access(MTOA)	Margin Available For Short Term Open Access(STOA)	Chnages w.r.t. Previous Revision	Comment	
	08 Oct to 14 Oct	00:00 to 17:00	1620	60	1560	455	1105	0		
		17:00 to 21:00	1415	60	1355	455	900	0		
		21:00 to 24:00	1620	60	1560	455	1105	0		
	15 Oct to 15 Oct	00:00 to 09:00	1620	60	1560	455	1105	0		
		09:00 to 17:00	1500	60	1440	455	985	0		
		17:00 to 21:00	1215	60	1155	455	700	0		
		21:00 to 24:00	1500	60	1440	455	985	0		
	16 Oct to 31 Oct	00:00 to 09:00	1620	60	1560	455	1105	120	Due to deferment of shutdown of 220kV Salakati - BTPS - 1 TL	
		09:00 to 17:00	1620	60	1560	455	1105	120		
		17:00 to 21:00	1415	60	1355	455	900	200		
		21:00 to 24:00	1620	60	1560	455	1105	120		
	ER-NR	01 Oct to 01 Oct	00:00 to 09:30	7700	400	7300	4854	2446	0	

Corridor	Date	Time Period(hrs)	Total Transfer Capability(TTC)	Reliability Margin(RM)	Available Transfer Capability(ATC)	Long Term Access(LTA)/Medium Term Open Access(MTOA)	Margin Available For Short Term Open Access(STOA)	Chnages w.r.t. Previous Revision	Comment
		09:30 to 24:00	7300	400	6900	4854	2046	0	
	02 Oct to 14 Oct	00:00 to 24:00	7700	400	7300	4854	2446	0	
	15 Oct to 31 Oct	00:00 to 24:00	8000	400	7600	4854	2746	0	
ER-SR	01 Oct to 31 Oct	00:00 to 06:00	5700	350	5350	3250	2100	0	
		06:00 to 18:00	5700	350	5350	3316	2034	0	
		18:00 to 24:00	5700	350	5350	3250	2100	0	
ER-W3	01 Oct to 31 Oct	00:00 to 24:00	No limit is being specified.						
NER-ER	01 Oct to 05 Oct	00:00 to 17:00	2860	60	2800	258	2542	0	
		17:00 to 21:00	2770	60	2710	258	2452	0	
		21:00 to 24:00	2860	60	2800	258	2542	0	
	06 Oct to 06 Oct	00:00 to 09:00	2860	60	2800	258	2542	0	
		09:00 to 17:00	2810	60	2750	258	2492	0	

Corridor	Date	Time Period(hrs)	Total Transfer Capability(TTC)	Reliability Margin(RM)	Available Transfer Capability(ATC)	Long Term Access(LTA)/Medium Term Open Access(MTOA)	Margin Available For Short Term Open Access(STOA)	Chnages w.r.t. Previous Revision	Comment
		17:00 to 21:00	2700	60	2640	258	2382	0	
		21:00 to 24:00	2860	60	2800	258	2542	0	
	07 Oct to 07 Oct	00:00 to 17:00	2810	60	2750	258	2492	0	
		17:00 to 21:00	2700	60	2640	258	2382	0	
		21:00 to 24:00	2860	60	2800	258	2542	0	
	08 Oct to 14 Oct	00:00 to 17:00	2860	60	2800	258	2542	0	
		17:00 to 21:00	2770	60	2710	258	2452	0	
		21:00 to 24:00	2860	60	2800	258	2542	0	
	15 Oct to 15 Oct	00:00 to 09:00	2860	60	2800	258	2542	0	
		09:00 to 17:00	2810	60	2750	258	2492	0	
		17:00 to 21:00	2700	60	2640	258	2382	0	
		21:00 to 24:00	2860	60	2800	258	2542	0	

Corridor	Date	Time Period(hrs)	Total Transfer Capability(TTC)	Reliability Margin(RM)	Available Transfer Capability(ATC)	Long Term Access(LTA)/Medium Term Open Access(MTOA)	Margin Available For Short Term Open Access(STOA)	Chnages w.r.t. Previous Revision	Comment
	16 Oct to 31 Oct	00:00 to 09:00	2860	60	2800	258	2542	50	Due to deferment of shutdown of 220kV Salakati - BTPS - 1 TL
		09:00 to 17:00	2860	60	2800	258	2542	50	
		17:00 to 21:00	2770	60	2710	258	2452	70	
		21:00 to 24:00	2860	60	2800	258	2542	0	
NR-ER	01 Oct to 31 Oct	00:00 to 06:00	2000	200	1800	100	1700	0	
		06:00 to 18:00	2000	200	1800	1615	185	0	
		18:00 to 24:00	2000	200	1800	100	1700	0	
NR-WR	01 Oct to 31 Oct	00:00 to 06:00	3600	500	3100	1232	1868	0	
		06:00 to 18:00	3600	500	3100	4568	0	0	
		18:00 to 24:00	3600	500	3100	1232	1868	0	
SR-ER	01 Oct to 31 Oct	00:00 to 24:00	No limit is being specified.						
SR-WR	01 Oct to 31 Oct	00:00 to 06:00	7400	650	6750	852	5898	0	

Corridor	Date	Time Period(hrs)	Total Transfer Capability(TTC)	Reliability Margin(RM)	Available Transfer Capability(ATC)	Long Term Access(LTA)/Medium Term Open Access(MTOA)	Margin Available For Short Term Open Access(STOA)	Chnages w.r.t. Previous Revision	Comment
		06:00 to 18:00	7400	650	6750	1052	5698	0	
		18:00 to 24:00	7400	650	6750	852	5898	0	
W3 Injection	01 Oct to 31 Oct	00:00 to 24:00	NA	NA		NA		0	
W3-ER	01 Oct to 31 Oct	00:00 to 24:00	No limit is being specified.						
WR-NR	01 Oct to 01 Oct	00:00 to 06:00	16950	1000	15950	11106	4844	0	
		06:00 to 09:30	16950	1000	15950	11405	4545	0	
		09:30 to 18:00	16250	1000	15250	11405	3845	0	
		18:00 to 24:00	16250	1000	15250	11106	4144	0	
	02 Oct to 14 Oct	00:00 to 06:00	16950	1000	15950	11106	4844	0	
		06:00 to 18:00	16950	1000	15950	11405	4545	0	
		18:00 to 24:00	16950	1000	15950	11106	4844	0	
	15 Oct to 31 Oct	00:00 to 06:00	17800	1000	16800	11106	5694	0	

Corridor	Date	Time Period(hrs)	Total Transfer Capability(TTC)	Reliability Margin(RM)	Available Transfer Capability(ATC)	Long Term Access(LTA)/Medium Term Open Access(MTOA)	Margin Available For Short Term Open Access(STOA)	Chnages w.r.t. Previous Revision	Comment
		06:00 to 18:00	17800	1000	16800	11405	5395	0	
		18:00 to 24:00	17800	1000	16800	11106	5694	0	
WR-SR	01 Oct to 14 Oct	00:00 to 06:00	11600	650	10950	3598	7352	0	
		06:00 to 18:00	11600	650	10950	4560	6390	0	
		18:00 to 24:00	11600	650	10950	3598	7352	0	
	15 Oct to 15 Oct	00:00 to 06:00	11600	650	10950	3598	7352	0	
		06:00 to 07:00	11600	650	10950	4560	6390	0	
		07:00 to 18:00	11000	650	10350	4560	5790	0	
		18:00 to 24:00	11000	650	10350	3598	6752	0	
	16 Oct to 31 Oct	00:00 to 06:00	11600	650	10950	3598	7352	0	
		06:00 to 18:00	11600	650	10950	4560	6390	0	
		18:00 to 24:00	11600	650	10950	3598	7352	0	

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

**Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.

1) S1 comprises of Telangana, AP and Karnataka; S2 comprises of Tamil Nadu and Puducherry; S3 comprises Kerala 2) W3 comprises of the following regional entities : a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, l) DB Power, m) KWPC, n) Vandana Viduyut o) RKM, p) GMR Raikheda, q) Ind Barath and any other regional entity generator in Chhattisgarh

The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/ Fuel shortage/New units being commissioned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

In case of TTC Revision due to any shutdown : 1) The TTC value will be revised to normal values after restoration of shutdown. 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.

Real Time TTC/ATC revisions are uploaded on POSOCO/NLDC "News Update" (Flasher) Section

^Though 3X315 MVA, 400/220 kV ICTs at Maradam are N-1 non-compliant, the TTC of WR-SR and ER-SR corridor has not been restricted due to the same considering that this aspect will be managed by AP SLDC through appropriate measures like SPS implementation.

^In case of drawl of Karnataka beyond 3800 MW, the voltages in Bengaluru area are observed to be critically low. This issue may be taken care of by Karnataka SLDC by taking appropriate measures.

SR-WR TTC/ATC figures have been calculated considering 01 unit (800 MW) at Kudgi TPS in service. The figures are subject to change with change in generation at Kudgi TPS.

WR-NR/Import of NR TTC has been calculated considering generation at Pariccha TPS as 350 MW. TTC figures are subject to change with significant change in generation at Pariccha TPS..

Simultaneous Import Capability

Corridor	Date	Time Period(hrs)	Total Transfer Capability(TTC)	Reliability Margin(RM)	Available Transfer Capability(ATC)	Long Term Access(LTA)/Medium Term Open Access(MTOA)	Margin Available For Short Term Open Access(STOA)	Chnages w.r.t. Previous Revision	Comment
ER	01 Oct to 31 Oct	00:00 to 24:00	NA	NA		NA		0	
NER	01 Oct to 05 Oct	00:00 to 17:00	1120	60	1060	455	605	0	
		17:00 to 21:00	915	60	855	455	400	0	
		21:00 to 24:00	1120	60	1060	455	605	0	
	06 Oct to 06 Oct	00:00 to 09:00	1120	60	1060	455	605	0	
		09:00 to 17:00	1000	60	940	455	485	0	
		17:00 to 21:00	715	60	655	455	200	0	
		21:00 to 24:00	1000	60	940	455	485	0	
	07 Oct to 07 Oct	00:00 to 17:00	1000	60	940	455	485	0	
		17:00 to 21:00	715	60	655	455	200	0	

Corridor	Date	Time Period(hrs)	Total Transfer Capability(TTC)	Reliability Margin(RM)	Available Transfer Capability(ATC)	Long Term Access(LTA)/Medium Term Open Access(MTOA)	Margin Available For Short Term Open Access(STOA)	Chnages w.r.t. Previous Revision	Comment
		21:00 to 24:00	1000	60	940	455	485	0	
	08 Oct to 14 Oct	00:00 to 17:00	1120	60	1060	455	605	0	
		17:00 to 21:00	915	60	855	455	400	0	
		21:00 to 24:00	1120	60	1060	455	605	0	
		00:00 to 09:00	1120	60	1060	455	605	0	
	15 Oct to 15 Oct	09:00 to 17:00	1000	60	940	455	485	0	
		17:00 to 21:00	715	60	655	455	200	0	
		21:00 to 24:00	1000	60	940	455	485	0	
		00:00 to 17:00	1120	60	1060	455	605	120	Due to deferment of shutdown of 220kV Salakati - BTPS - 1 TL
	16 Oct to 31 Oct	17:00 to 21:00	915	60	855	455	400	200	
		21:00 to 24:00	1120	60	1060	455	605	120	

Corridor	Date	Time Period(hrs)	Total Transfer Capability(TTC)	Reliability Margin(RM)	Available Transfer Capability(ATC)	Long Term Access(LTA)/Medium Term Open Access(MTOA)	Margin Available For Short Term Open Access(STOA)	Chnages w.r.t. Previous Revision	Comment	
NR	01 Oct to 01 Oct	00:00 to 06:00	24650	1400	23250	15960	7290	0		
		06:00 to 09:30	24650	1400	23250	16259	6991	0		
		09:30 to 18:00	23550	1400	22150	16259	5891	0		
		18:00 to 24:00	23550	1400	22150	15960	6190	0		
	02 Oct to 14 Oct	00:00 to 06:00	24650	1400	23250	15960	7290	0		
		06:00 to 18:00	24650	1400	23250	16259	6991	0		
		18:00 to 24:00	24650	1400	23250	15960	7290	0		
	15 Oct to 31 Oct	00:00 to 06:00	25800	1400	24400	15960	8440	0		
		06:00 to 18:00	25800	1400	24400	16259	8141	0		
		18:00 to 24:00	25800	1400	24400	15960	8440	0		
	SR	01 Oct to 14 Oct	00:00 to 06:00	17300	1000	16300	6848	9452	0	
			06:00 to 18:00	17300	1000	16300	7876	8424	0	

Corridor	Date	Time Period(hrs)	Total Transfer Capability(TTC)	Reliability Margin(RM)	Available Transfer Capability(ATC)	Long Term Access(LTA)/Medium Term Open Access(MTOA)	Margin Available For Short Term Open Access(STOA)	Chnages w.r.t. Previous Revision	Comment
		18:00 to 24:00	17300	1000	16300	6848	9452	0	
	15 Oct to 15 Oct	00:00 to 06:00	17300	1000	16300	6848	9452	0	
		06:00 to 07:00	17300	1000	16300	7876	8424	0	
		07:00 to 18:00	16700	1000	15700	7876	7824	0	
		18:00 to 24:00	16700	1000	15700	6848	8852	0	
		16 Oct to 31 Oct	00:00 to 06:00	17300	1000	16300	6848	9452	0
	06:00 to 18:00		17300	1000	16300	7876	8424	0	
	18:00 to 24:00		17300	1000	16300	6848	9452	0	
WR	01 Oct to 31 Oct	00:00 to 24:00	NA	NA			0	0	

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

**Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.

* For approving STOA Bilateral transactions, margin available in Simultaneous Import of NR would be apportioned on WR-NR Corridor & ER-NR Corridor in the following ratio: Margin in Simultaneous import of NR = A WR-NR ATC = B ER-NR ATC = C Margin for WR-NR applicants = $A * B / (B+C)$
Margin for ER-NR Applicants = $A * C / (B+C)$

Real Time TTC/ATC revisions are uploaded on POSOCO/NLDC "News Update" (Flasher) Section

#Though 2X315 MVA, 400/220 kV ICTs at Maradam are N-1 non-compliant, the TTC of SR Import has not been restricted due to the same considering that this aspect will be managed by AP SLDC through appropriate measures like SPS implementation

In case of drawl of Karnataka beyond 3800 MW, the voltages in Bengaluru area are observed to be critically low. This issue may be taken care of by Karnataka by taking appropriate measures.

WR-NR/Import of NR TTC has been calculated considering generation at Pariccha TPS as 350 MW. TTC figures are subject to change with significant change in generation at Pariccha TPS..

Simultaneous Export Capability

Corridor	Date	Time Period(hrs)	Total Transfer Capability(TTC)	Reliability Margin(RM)	Available Transfer Capability(ATC)	Long Term Access(LTA)/Medium Term Open Access(MTOA)	Margin Available For Short Term Open Access(STOA)	Chnages w.r.t. Previous Revision	Comment
ER	01 Oct to 31 Oct	00:00 to 24:00	NA	NA		NA		0	
NER	01 Oct to 05 Oct	00:00 to 17:00	3360	60	3300	258	3042	0	
		17:00 to 21:00	3270	60	3210	258	2952	0	
		21:00 to 24:00	3360	60	3300	258	3042	0	
	06 Oct to 06 Oct	00:00 to 09:00	3360	60	3300	258	3042	0	

Corridor	Date	Time Period(hrs)	Total Transfer Capability(TTC)	Reliability Margin(RM)	Available Transfer Capability(ATC)	Long Term Access(LTA)/Medium Term Open Access(MTOA)	Margin Available For Short Term Open Access(STOA)	Chnages w.r.t. Previous Revision	Comment
		09:00 to 17:00	3310	60	3250	258	2992	0	
		17:00 to 21:00	3200	60	3140	258	2882	0	
		21:00 to 24:00	3360	60	3300	258	3042	0	
	07 Oct to 07 Oct	00:00 to 17:00	3310	60	3250	258	2992	0	
		17:00 to 21:00	3200	60	3140	258	2882	0	
		21:00 to 24:00	3360	60	3300	258	3042	0	
	08 Oct to 14 Oct	00:00 to 17:00	3360	60	3300	258	3042	0	
		17:00 to 21:00	3270	60	3210	258	2952	0	
		21:00 to 24:00	3360	60	3300	258	3042	0	
	15 Oct to 15 Oct	00:00 to 09:00	3360	60	3300	258	3042	0	
		09:00 to 17:00	3310	60	3250	258	2992	0	
		17:00 to 21:00	3200	60	3140	258	2882	0	

Corridor	Date	Time Period(hrs)	Total Transfer Capability(TTC)	Reliability Margin(RM)	Available Transfer Capability(ATC)	Long Term Access(LTA)/Medium Term Open Access(MTOA)	Margin Available For Short Term Open Access(STOA)	Chnages w.r.t. Previous Revision	Comment
	16 Oct to 31 Oct	21:00 to 24:00	3360	60	3300	258	3042	0	
		00:00 to 17:00	3360	60	3300	258	3042	50	Due to deferment of shutdown of 220kV Salakati - BTPS - 1 TL
		17:00 to 21:00	3270	60	3210	258	2952	70	
		21:00 to 24:00	3360	60	3300	258	3042	0	
NR	01 Oct to 31 Oct	00:00 to 06:00	3600	500	3100	1332	1768	0	
		06:00 to 18:00	3600	500	3100	6183	0	0	
		18:00 to 24:00	3600	500	3100	1332	1768	0	
SR	01 Oct to 31 Oct	00:00 to 06:00	6350	650	5700	1944	3756	0	
		06:00 to 18:00	6350	650	5700	2294	3406	0	
		18:00 to 24:00	6350	650	5700	1944	3756	0	
WR	01 Oct to 31 Oct	00:00 to 24:00	NA	NA		NA		0	

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Real Time TTC/ATC revisions are uploaded on POSOCO/NLDC "News Update" (Flasher) Section

^SR Export TTC/ATC figures have been calculated considering 01 unit (800 MW) at Kudgi TPS in service. The figures are subject to change with change in generation at Kudgi TPS.

Limiting Constraints

Corridor	Constraints	Revisions
WR-NR	N-1 contingency of one ckt of 765 kV Vindhyachal-Varanasi will overload the other circuit	0-11
NR-ER	(n-1) contingency of 400 kV Saranath-Pusauli	0-11
ER-NR	Inter-regional flow pattern towards NR	0-11
WR-SR	N-1 of one ICT of 765/400 kV, 1500 MVA ICT at Nizamabad will overload the other ICT	0-11
ER-SR	Low Voltage at Gazuwaka (East) Bus.	0-11
SR-WR	a) N-1 contingency of one ckt of 400 kV Kolhapur-PG - Kolhapur-MS D/C will overload of the other ckt b) N-1 contingency of 500 MVA ICT at 400 kV Kolhapur-MS will overload the other 2x315 MVA ICTs	0-11
ER-NER	a) N-1 contingency of 400 kV Bongaigaon - Azara line b) High Loading of 220 kV Salakati - BTPS D/C	0-11
NER-ER	a) N-1 contingency of 220 kV Salakati - BTPS I or II b) High Loading of 220 kV Salakati - BTPS II or I	0-11
NR_IMPORT	N-1 contingency of one ckt of 765 kV Vindhyachal-Varanasi will overload the other circuit	0-11
NR_EXPORT	(N-1) Contingency of 400 kV Banaskantha - Veloda D/C (n-1) contingency of 400 kV Saranath-Pusauli	0-11
NER_IMPORT	a) N-1 contingency of 400 kV Bongaigaon - Azara line b) High Loading of 220 kV Salakati - BTPS D/C	0-11
NER_EXPORT	a) N-1 contingency of 220 kV Salakati - BTPS I or II b) High Loading of 220 kV Salakati - BTPS II or I	0-11
SR_IMPORT	N-1 of one ICT of 765/400 kV, 1500 MVA ICT at Nizamabad will overload the other ICT Low Voltage at Gazuwaka (East) Bus	0-11
SR_EXPORT	N-1 contingency of one ckt of 400 kV Kolhapur-PG - Kolhapur-MS D/C will overload of the other ckt	0-11
		0-11

Revision Summary

Revision	Date Of Revision	Period Of Revision	Reason for Revision/Comment	Corridor Affected
1	30 Jun	01 Oct to 31 Oct	Due to change in LGB and change in inter-regional flow pattern	WR-NR
		01 Oct to 31 Oct	Due to change in LGB and change in inter-regional flow pattern	ER-NR
		01 Oct to 31 Oct	Due to change in LGB and change in inter-regional flow pattern	NR_IMPORT
2	28 Jul	01 Oct to 31 Oct	Revised STOA margin due to discontinuation of LTA quantum of 72.81 MW from NSNTPC_FTG1 to TSNPDCL	NR-WR
		01 Oct to 31 Oct	Revised STOA margin due to discontinuation of LTA quantum of 72.81 MW from NSNTPC_FTG1 to TSNPDCL	NR_EXPORT
3	28 Aug	01 Oct to 31 Oct	Revised STOA margin due to increase in LTA quantum of 34.43 MW from NSNTPC_FTG1 to TSSPDCL	NR-WR
		01 Oct to 31 Oct	Revised STOA margin due to a) Increase in LTA quantum by 26.3 MW from POWERICA to UPPCL b) Operationalization of new LTA quantum of 72 MW from SRIJAN_MORJAR_BHJ2_W to BRPL c) Operationalization of new LTA quantum of 72 MW from SRIJAN_MORJAR_BHJ2_W to BYPL	WR-NR
		01 Oct to 31 Oct	Revised STOA margin due to a) Increase in LTA quantum by 96.3 MW from Fatehgarh-I Solar to Telangana b) Increase in LTA quantum by 36 MW from KAWAS to TELANGANA c) Operationalization of new LTA quantum of 10.1 MW from GANDHAR to TELANGANA	WR-SR
		01 Oct to 31 Oct	Revised STOA margin due to operationalization of new MTOA quantum of 102 MW from SEILP2 to Gujarat	SR-WR

Revision	Date Of Revision	Period Of Revision	Reason for Revision/Comment	Corridor Affected
		01 Oct to 31 Oct	Revised STOA margin due to a) Increase in LTA quantum by 26.3 MW from POWERICA to UPPCL b) Operationalization of new LTA quantum of 72 MW from SRIJAN_MORJAR_BHJ2_W to BRPL c) Operationalization of new LTA quantum of 72 MW from SRIJAN_MORJAR_BHJ2_W to BYPL	NR_IMPORT
		01 Oct to 31 Oct	Revised STOA margin due to a) Increase in LTA quantum by 96.3 MW from Fatehgarh-I Solar to Telangana b) Increase in LTA quantum by 36 MW from KAWAS to TELANGANA c) Operationalization of new LTA quantum of 10.1 MW from GANDHAR to TELANGANA	SR_IMPORT
		01 Oct to 31 Oct	Revised STOA margin due to increase in LTA quantum of 34.43 MW from NSNTPC_FTG1 to TSSPDCL	NR_EXPORT
		01 Oct to 31 Oct	Revised STOA margin due to operationalization of new MTOA quantum of 102 MW from SEILP2 to Gujarat	SR_EXPORT
4	28 Sep	01 Oct to 31 Oct	Revised STOA margin due to a) Increase in LTA quantum by 27.9 MW from SRIJAN_MORJAR_BHJ2_W to BRPL b) Increase in LTA quantum by 23.4 MW from SRIJAN_MORJAR_BHJ2_W to BYPL c) Operationalization of new LTAs of quantum of 50 MW & 274.4 MW from SBESS_PTHMPUR_INDR_W to UPPCL	WR-NR
		01 Oct to 31 Oct	Revised STOA margin due to increase in LTA quantum by 23.4 MW from SITAC_CHUGGER_BHJ2_W to Pondicherry	WR-SR
		01 Oct to 31 Oct	Revised STOA margin due to a) Increase in LTA quantum by 27.9 MW from SRIJAN_MORJAR_BHJ2_W to BRPL b) Increase in LTA quantum by 23.4 MW from SRIJAN_MORJAR_BHJ2_W to BYPL c) Operationalization of new LTAs of quantum of 50 MW & 274.4 MW from SBESS_PTHMPUR_INDR_W to UPPCL	NR_IMPORT
		01 Oct to 31 Oct	Revised STOA margin due to increase in LTA quantum by 23.4 MW from SITAC_CHUGGER_BHJ2_W to Pondicherry	SR_IMPORT

Revision	Date Of Revision	Period Of Revision	Reason for Revision/Comment	Corridor Affected
5	29 Sep	01 Oct to 01 Oct	Due to forced outage of 765 kV Agra - Gwalior- 1 & the shutdown of 765 kV Jabalpur - Vindhyanchal - 2	WR-NR
		02 Oct to 31 Oct	Due to forced outage of 765 kV Agra - Gwalior- 1	WR-NR
		01 Oct to 01 Oct	Due to forced outage of 765 kV Agra - Gwalior- 1 & the shutdown of 765 kV Jabalpur - Vindhyanchal - 2	ER-NR
		02 Oct to 31 Oct	Due to forced outage of 765 kV Agra - Gwalior- 1	ER-NR
		01 Oct to 31 Oct	Change in Load-Generation of NER	ER-NER
		01 Oct to 31 Oct	Change in Load-Generation of NER	NER-ER
		01 Oct to 01 Oct	Due to forced outage of 765 kV Agra - Gwalior- 1 & the shutdown of 765 kV Jabalpur - Vindhyanchal - 2	NR_IMPORT
		02 Oct to 31 Oct	Due to forced outage of 765 kV Agra - Gwalior- 1	NR_IMPORT
		01 Oct to 31 Oct	Change in Load-Generation of NER	NER_IMPORT

Revision	Date Of Revision	Period Of Revision	Reason for Revision/Comment	Corridor Affected
		01 Oct to 31 Oct	Change in Load-Generation of NER	NER_EXPORT
6	04 Oct	06 Oct to 06 Oct	Due to the shutdown of 220 kV Salakati - BTPS 1	ER-NER
		07 Oct to 20 Oct	Due to the shutdown of 220 kV Salakati - BTPS 1	ER-NER
		21 Oct to 31 Oct	Due to the shutdown of 220 kV Salakati - BTPS 2	ER-NER
		06 Oct to 06 Oct	Due to the shutdown of 220 kV Salakati - BTPS 1	NER-ER
		07 Oct to 20 Oct	Due to the shutdown of 220 kV Salakati - BTPS 1	NER-ER
		21 Oct to 31 Oct	Due to the shutdown of 220 kV Salakati - BTPS 2	NER-ER
		06 Oct to 06 Oct	Due to the shutdown of 220 kV Salakati - BTPS 1	NER_IMPORT
		07 Oct to 20 Oct	Due to the shutdown of 220 kV Salakati - BTPS 1	NER_IMPORT

Revision	Date Of Revision	Period Of Revision	Reason for Revision/Comment	Corridor Affected
		21 Oct to 31 Oct	Due to the shutdown of 220 kV Salakati - BTPS 2	NER_IMPORT
		06 Oct to 06 Oct	Due to the shutdown of 220 kV Salakati - BTPS 1	NER_EXPORT
		07 Oct to 20 Oct	Due to the shutdown of 220 kV Salakati - BTPS 1	NER_EXPORT
		21 Oct to 31 Oct	Due to the shutdown of 220 kV Salakati - BTPS 2	NER_EXPORT
7	07 Oct	08 Oct to 31 Oct	Due to deferment of shutdown of 220 kV Salakati - BTPS 1	ER-NER
		08 Oct to 31 Oct	Due to deferment of shutdown of 220 kV Salakati - BTPS 1	NER-ER
		08 Oct to 31 Oct	Due to deferment of shutdown of 220 kV Salakati - BTPS 1	NER_IMPORT
		08 Oct to 31 Oct	Due to deferment of shutdown of 220 kV Salakati - BTPS 1	NER_EXPORT
8	13 Oct	15 Oct to 15 Oct	TTC/ATC curtailed due to shutdown of 765KV-WARDHA-NIZAMABAD-2	WR-SR

Revision	Date Of Revision	Period Of Revision	Reason for Revision/Comment	Corridor Affected
		15 Oct to 30 Oct	TTC/ATC curtailed due to Shutdown of 220 kV Salakati-BTPS 1	ER-NER
		15 Oct to 30 Oct	TTC/ATC curtailed due to Shutdown of 220 kV Salakati-BTPS 1	NER-ER
		15 Oct to 30 Oct	TTC/ATC curtailed due to Shutdown of 220 kV Salakati-BTPS 1	NER_IMPORT
		15 Oct to 15 Oct	TTC/ATC curtailed due to shutdown of 765KV-WARDHA-NIZAMABAD-2	SR_IMPORT
		15 Oct to 30 Oct	TTC/ATC curtailed due to shutdown of 765KV-WARDHA-NIZAMABAD-2	NER_EXPORT
		15 Oct to 31 Oct	Due to revival of 765 kV Agra Gwalior ckt 1	WR-NR
9	14 Oct	15 Oct to 31 Oct	Due to revival of 765 kV Agra Gwalior ckt 1	ER-NR
		15 Oct to 31 Oct	Due to revival of 765 kV Agra Gwalior ckt 1	NR_IMPORT
10	14 Oct	16 Oct to 30 Oct	Due to the shutdown of 220kV Salakati - BTPS - 1 TL	ER-NER

Revision	Date Of Revision	Period Of Revision	Reason for Revision/Comment	Corridor Affected
		16 Oct to 30 Oct	Due to the shutdown of 220kV Salakati - BTPS - 1 TL	NER-ER
		16 Oct to 30 Oct	Due to the shutdown of 220kV Salakati - BTPS - 1 TL	NER_IMPORT
		16 Oct to 30 Oct	Due to the shutdown of 220kV Salakati - BTPS - 1 TL	NER_EXPORT
11	15 Oct	16 Oct to 31 Oct	Due to deferment of shutdown of 220kV Salakati - BTPS - 1 TL	ER-NER
		16 Oct to 31 Oct	Due to deferment of shutdown of 220kV Salakati - BTPS - 1 TL	NER-ER
		16 Oct to 31 Oct	Due to deferment of shutdown of 220kV Salakati - BTPS - 1 TL	NER_IMPORT
		16 Oct to 31 Oct	Due to deferment of shutdown of 220kV Salakati - BTPS - 1 TL	NER_EXPORT

BASECASE LGBR					
				Month:	Oct - 22
S.No.	Name of State/Region	Load		Generation	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
I	NORTHERN REGION				

1	Punjab	9901	8919	3311	2367
2	Haryana	8683	7554	2322	1661
3	Rajasthan	9888	8413	5333	4622
4	Delhi	4938	4116	554	506
5	Uttar Pradesh	19668	17584	10839	9186
6	Uttarakhand	1946	1567	1600	1183
7	Himachal Pradesh	1401	1026	1975	1611
8	Jammu & Kashmir	2271	1181	1157	1072
9	Chandigarh	278	203	0	0
10	ISGS/IPPs	59	57	22573	17521
	Total NR	59033	50620	49662	39730
II	EASTERN REGION				
1	Bihar	6568	5935	496	419
2	Jharkhand	1667	1216	444	343
3	Damodar Valley Corporation	3183	2698	5421	4571
4	Orissa	5625	4979	4035	3090
5	West Bengal	9573	7825	6642	5433
6	Sikkim	111	64	0	0
7	Bhutan	55	54	1450	1307
8	ISGS/IPPs	850	850	17853	14945
	Total ER	27633	23622	36340	30107
III	WESTERN REGION				
1	Maharashtra	16324	13276	9397	9871
2	Gujarat	15123	11957	6126	7052
3	Madhya Pradesh	9698	7600	2929	3614

4	Chattisgarh	3856	2970	1583	1753
5	Daman and Diu	327	273	0	0
6	Dadra and Nagar Haveli	836	698	0	0
7	Goa-WR	477	391	0	0
8	ISGS/IPPs	5260	4220	45660	31729
	Total WR	51902	41385	65696	54019
IV	SOUTHERN REGION				
1	Andhra Pradesh	8717	8076	4326	4705
2	Telangana	13020	10843	6994	6493
3	Karnataka	10457	8057	9165	6768
4	Tamil Nadu	16096	14724	7302	6166
5	Kerala	3877	2743	1540	458
6	Pondy	398	403	0	0
7	Goa-SR	118	120	0	0
8	ISGS/IPPs	0	0	16130	15796
	Total SR	52684	44966	45457	40386
V	NORTH-EASTERN REGION				
1	Arunachal Pradesh	147	83	0	0
2	Assam	2051	1702	280	259
3	Manipur	223	101	0	0
4	Meghalaya	365	236	274	123
5	Mizoram	134	75	49	42
6	Nagaland	189	161	23	18
7	Tripura	485	287	194	180
8	ISGS/IPPs	0	0	3198	2891

	Total NER	3594	2645	4017	3512
	Total All India	194846	163237	201173	167754