

National Load Despatch Centre
Total Transfer Capability for September 2015

Issue Date: 25/06/2015

Issue Time: 1200 hrs

Revision No. 1

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR-WR *	1st Sep 2015 to 30th Sep 2015	00-24	2500	500	2000	706	1294		
WR-NR*	1st Sep 2015 to 30th Sep 2015	00-24	5100	500	4600	5277	0		
NR-ER*	1st Sep 2015 to 30th Sep 2015	00-06	2000	200	1800	293	1507		
		06-18'	2000		1800	358	1442		
		18-24	2000		1800	293	1507		
ER-NR**	1st Sep 2015 to 30th Sep 2015	00-24	4800	300	4500	2431	2069		
W3-ER ^s	1st Sep 2015 to 30th Sep 2015	00-24	No limit is being specified. No Re-routing is allowed via W3-ER-NR.						
ER-W3	1st Sep 2015 to 30th Sep 2015	00-24	1000	300	700	874	0		
WR-SR	1st Sep 2015 to 30th Sep 2015	00-24	2300	750	1550	1550	0		
SR-WR *	1st Sep 2015 to 30th Sep 2015	00-24	No limit is being Specified.						
ER-SR	1st Sep 2015 to 30th Sep 2015	00-06	2650	0	2650	2385	265		
		18-24				2450	200		
		06-18'							
SR-ER *	1st Sep 2015 to 30th Sep 2015	00-24	No limit is being Specified.						
S1-S2 (Rev-0)	1st Sep 2015 to 7th Sep 2015	00-24	3565	350	3215	2573	642		
	8th Sep 2015 to 14th Sep 2015	00-24	3565	350	3215	2484	731		
	15th Sep 2015 to 21st Sep 2015	00-24	3565	350	3215	2561	654		
	22nd Sep 2015 to 25th Sep 2015	00-24	3565	350	3215	2612	603		
	26th Sep 2015 to 27th Sep 2015	00-24	3565	350	3215	2691	524		
	28th Sep 2015 to 30th Sep 2015	00-24	3565	350	3215	2602	613		
ER-NER	1st Sep 2015 to 30th Sep 2015	00-17	1200	40	1160	210	950		
		23-24	1250		1210		1000		
NER-ER	1st Sep 2015 to 30th Sep 2015	00-17	1220	30	1190	0	1190		
		23-24	1300		1260		1260		
W3 zone Injection	1st Sep 2015 to 30th Sep 2015	00-17	9400	200	9200	7236	1964		
		23-24	9900		9700		2464		
		17-23							

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

National Load Despatch Centre
Total Transfer Capability for September 2015

Issue Date: 25/06/2015

Issue Time: 1200 hrs

Revision No. 1

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
----------	------	-------------------	---------------------------------	--------------------	-------------------------------------	--	--	-------------------------------------	----------

S1-S2 Corridor: Any revision in S1-S2 TTC/ATC from Rev-0, would be uploaded under Intra-Regional Section on NLDC website.

\$ As per Simulations, predominant direction of flow is on West to North Corridor. Hence, in case injection point is in Western Region (W1,W2,W3), STOA/PX transactions from West to North on West-East-North corridor shall not be allowed as such transaction increases congestion in the West to North Corridor. & ER-NR TTC is independent of WR-NR corridor flow

1) S1 comprises of Telangana, AP and Karnataka: S2 comprises of Tamil Nadu, Kerala and Puducherry

2) W3 comprises of the following regional entities :

a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak
f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPC, n)Vandana Vidyt

The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/ Fuel shortage/New units being commissioned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

In case of TTC Revision due to any shutdown :

- 1) The TTC value will be revised to normal values after restoration of shutdown.
- 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.

Limiting Constraints

Corridor	Constraint
NR-WR	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.
WR-NR	High Loading of 400kV Singrauli-Anpara & High loading of 765 kV Agra-Gwalior (1250 MW SPS setting on each circuit of 765 kV Gwalior-Agra) and Loop flows on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda (power flowing from WR to NR on 765kV Gwalior-Agra D/C and from NR to WR on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda).
NR-ER	(n-1) contingency of 400 kV Saranath-Pusauli
ER-NR	N-1 contingency of 400 kV Biharshariff- Lakhisarai S/C
ER-W3	1. n-1 of 400 kV Wardha – Parli will lead to 30 degrees angular separation between Wardha and Parli. 2. (n-1) contingency of one circuit of 400kV Parli(PG)-Sholapur(PG)
WR-SR & ER-SR	1. (n-1) of 400 kV Wardha – Parli will lead to 30 degrees angular separation between Wardha and Parli. 2. (n-1) contingency of one circuit of 400kV Parli(PG)-Sholapur(PG) 3. ER-SR TTC has been declared assuming more than 1100 MW generation at Talcher Stage-2. In case Talcher Stage-2 generation goes below 1100 MW, then the ER-SR TTC would be revised downward as constraints within ER would emerge.
ER-NER	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other 400/220 kV, 315 MVA ICT at Misa
NER-ER	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other 400/220 kV, 315 MVA ICT at Misa
W3 zone Injection	1. n-1 of 400 kV Wardha – Parli will lead to 30 degrees angular separation between Wardha and Parli. 2. (n-1) contingency of one circuit of 400kV Parli(PG)-Sholapur(PG)

*Primary constraints

Simultaneous Import Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER									
NR*	1st Sep 2015 to 30th Sep 2015	00-24	7300	800	6500	7708	0	-2600	Revised considering skewed sharing of flows on WR-NR and ER-NR corridor in the range 70:30
NER	1st Sep 2015 to 30th Sep 2015	00-17	1200	40	1160	210	950		
		23-24			1210		1000		
WR									
SR	1st Sep 2015 to 30th Sep 2015	00-06	4950	750	4200	3935	265		
		18-24	4950		4200	4000	200		

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Simultaneous Export Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR*	1st Sep 2015 to 30th Sep 2015	00-06	4500	700	3800	999	2801		
		06-18'			3800	1064	2736		
		18-24			3800	999	2801		
NER	1st Sep 2015 to 30th Sep 2015	00-17	1220	30	1190	0	1190		
		23-24	1300	40	1260		1260		
WR									
SR *	1st Sep 2015 to 30th Sep 2015	00-24	No limit is being Specified.						

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Limiting Constraints

NR	Import	(n-1) contingency of 400 kV Biharshariff- Lakhisarai S/C High loading of 765 kV Agra-Gwalior (1250 MW SPS setting on each circuit of 765 kV Gwalior-Agra) and high loop flows on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda (power flowing from WR to NR on 765kV Gwalior-Agra D/C and from NR to WR on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda).
	Export	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak. (n-1) contingency of 400 kV Saranath-Pusauli
NER	Import	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other 400/220 kV, 315 MVA ICT at Misa
SR	Export	
	Import	1. n-1 of 400 kV Wardha – Parli will lead to 30 degrees angular separation between Wardha and Parli. 2. (n-1) contingency of one circuit of 400kV Parli(PG)-Sholapur(PG) 3. ER-SR TTC has been declared assuming more than 1100 MW generation at Talcher Stage-2. In case Talcher Stage-2 generation goes below 1100 MW, then the ER-SR TTC would be revised downward as constraints within ER would emerge.

*Primary constraints

ASSUMPTIONS IN BASECASE					
				Month : September '15	
S.No.	Name of State/Area	Load		Generation	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
I	NORTHERN REGION				
1	Punjab	8327	7408	4656	4626
2	Haryana	7890	7084	3318	3318
3	Rajasthan	9096	8161	5709	5646
4	Delhi	4549	3953	1095	1095
5	Uttar Pradesh	12551	12022	6555	6605
6	Uttarakhand	1677	1295	874	723
7	Himachal Pradesh	1189	985	988	971
8	Jammu & Kashmir	2123	1439	438	438
9	Chandigarh	266	159	0	0
10	ISGS/IPPs	0	0	19172	14064
	Total NR	47668	42504	42804	37485
II	EASTERN REGION				
1	Bihar	2690	2033	110	0
2	Jharkhand	915	749	507	330
3	Damodar Valley Corporation	2906	2140	3619	2922
4	Orissa	3574	2894	3176	2150
5	West Bengal	7617	5926	5553	3524
6	Sikkim	88	43	0	0
7	Bhutan	105	104	1300	1030
8	ISGS/IPPs	608	568	9360	8909
	Total ER	18502	14458	23625	18865
III	WESTERN REGION				
1	Maharashtra	20211	11204	14900	6645
2	Gujarat	12909	7121	10115	4527
3	Madhya Pradesh	7861	4927	4832	2521
4	Chattisgarh	3612	2182	2491	1036
5	Daman and Diu	305	233	0	0
6	Dadra and Nagar Haveli	771	570	0	0
7	Goa-WR	513	293	0	0
8	ISGS/IPPs	1048	1046	23713	20410
	Total WR	47230	27575	56050	35139

IV	SOUTHERN REGION				
1	Andhra Pradesh	5904	5359	4699	4399
2	Telangana	7336	6348	3626	2262
3	Karnataka	7925	6076	7334	5247
4	Tamil Nadu	13399	11925	8681	7218
5	Kerala	3381	2230	1779	694
6	Pondy	338	290	0	0
7	Goa-SR	81	81	0	0
8	ISGS/IPPs	0	0	9605	9470
	Total SR	38364	32309	35724	29290
V	NORTH-EASTERN REGION				
1	Arunachal Pradesh	107	92	0	0
2	Assam	1050	944	285	250
3	Manipur	125	105	0	0
4	Meghalaya	312	208	211	155
5	Mizoram	72	44	4	4
6	Nagaland	110	106	22	16
7	Tripura	266	166	110	110
8	ISGS/IPPs	7	7	1501	1302
	Total NER	2049	1672	2133	1837
	Total All India	153812	118517	160336	122616