National Load Despatch Centre Total Transfer Capability for September 2015

Issue Date: 02/09/2015 Issue Time: 1150 hrs Revision No. 6

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR-WR *	1st Sep 2015 to 30th Sep 2015	00-24	2500	500	2000	421	1579		
WR-NR*	1st Sep 2015 to 30th Sep 2015	00-24	6400	500	5900	5638	262		
				l .	1000	202	1707		I
	1st Sep 2015 to	00-06	2000	•	1800	293	1507		
NR-ER*	30th Sep 2015	06-18'	2000	200	1800	358	1442		
	30th Sep 2013	18-24	2000		1800	293	1507		
ER-NR*	1st Sep 2015 to 30th Sep 2015	00-24	4800	300	4500	2431	2069		
W3-ER ^{\$}	1st Sep 2015 to	00-24					s being specified.		
W3-EK	30th Sep 2015	00-24				No Re-routing is	allowed via W3-El	R-NR.	
ER-W3	1st Sep 2015 to 30th Sep 2015	00-24	1000	300	700	874	0		
	, in the second			•					
WR-SR	1st Sep 2015 to 30th Sep 2015	00-24	2300	750	1550	1550	0		
SR-WR*	1st Sep 2015 to 30th Sep 2015	00-24				No limit i	s being Specified.		
	1st Sep 2015 to	00-06				2300	350		
ER-SR	30th Sep 2015	18-24	2650	0	2650	2300	330		
	30th Sep 2013	06-18'	1			2365	285		
	1st Sep 2015 to			•		XX 41 1. 1	1		
SR-ER *	30th Sep 2015	00-24				No limit i	s being Specified.		
	20th Sep 2012		<u> </u>						
G1 G2	1st Sep 2015 to	00.24	C	1 62	TTC/ATC:	alaadad aa NI DC	boite and an Inte	a Danianal	Section in Monthly ATC.
S1-S2	30th Sep 2015	00-24	3	1-S2 COTTIGOT	TTC/ATC is u	pioaded on NLDC	website under mir	a-Regionai	Section in Monthly ATC.
	1st San 2015 to	00-17	1200		1160		050		
ER-NER	1st Sep 2015 to	23-24	1200	40	1160	210	950		
	30th Sep 2015	17-23	1250		1210		1000		
		00-17							
NER-ER	1st Sep 2015 to	23-24	1220	30	1190	0	1190		
TIEN-DIC	30th Sep 2015	17-23	1300	40	1260	U	1260		
		17-23	1300	40	1200		1200		
		00-17							
W3 zone	1st Sep 2015 to	23-24	9400	200	9200	7576	1624		
Injection	30th Sep 2015	17-23	0000	200	0700	1310	2124		
		17-23	9900		9700		2124		

^{*} Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

National Load Despatch Centre Total Transfer Capability for September 2015

Issue Date: 02/09/2015 Issue Time: 1150 hrs Revision No. 6

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
----------	------	-------------------------	--	-----------------------	--	--	--	---	----------

\$ As per Simulations, predominant direction of flow is on West to North Corridor. Hence, in case injection point is in Western Region (W1,W2,W3), STOA/PX transactions from West to North on West-East-North corridor shall not be allowed as such transaction increases congestion in the West to North Corridor.

- 1) S1 comprises of Telangana, AP and Karnataka: S2 comprises of Tamil Nadu, Kerala and Puducherry
- 2) W3 comprises of the following regional entities:
- a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak
- f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPCL, n)Vandana Vidyut

The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/Fuel shortage/New units being commissionned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

In case of TTC Revision due to any shutdown:

- 1) The TTC value will be revised to normal values after restoration of shutdown.
- 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.

Limiting Constraints

Corridor	Constraint						
NR-WR	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.						
WR-NR	High Loading of 400kV Singrauli-Anpara & High loading of 765 kV Agra-Gwalior (1400 MW SPS setting on each circuit of 765 kV Gwalior-Agra) and Loop flows on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda (power flowing from WR to NR on 765kV Gwalior-Agra D/C and from NR to WR on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda).						
NR-ER	,						
ER-NR	N-1 contingency of 400 kV Biharshariff- Lakhisarai S/C						
ER-W3	1. n-1 of 400 kV Wardha – Parli will lead to 30 degrees angular separation between Wardha and Parli. 2. (n-1) contingency of one circuit of 400kV Parli(PG)-Sholapur(PG)						
WR-SR & ER-SR	(n-1) of 400 kV Wardha – Parli will lead to 30 degrees angular separation between Wardha and Parli. (n-1) contingency of one circuit of 400kV Parli(PG)-Sholapur(PG) 3. ER-SR TTC has been declared assuming more than 1100 MW generation at Talcher Stage-2. In case Talcher Stage-2 generation goes below 1100 MW, then the ER-SR TTC would be revised downward as						
	constraints within ER would emerge.						
ER-NER	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other 400/220 kV, 315 MVA ICT at Misa						
NER-ER	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other 400/220 kV, 315 MVA ICT at Misa						
W3 zone	1. n-1 of 400 kV Wardha – Parli will lead to 30 degrees angular separation between Wardha and Parli.						
Injection	2. (n-1) contingency of one circuit of 400kV Parli(PG)-Sholapur(PG)						

^{*}Primary constraints

Simultaneous Import Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER									
	1st Sep 2015 to 30th Sep 2015	00-05	9100	800	8300		231		
NR*		05-08'	9600		8800	8069	731		
1416		08-19'	9100		8300		231		
		19-24'	8500		7700		0		
	1st Sep 2015 to	00-17	1200	40	1160		0.50		
NER		23-24	1200		1160	210	950		
	30th Sep 2015	17-23	1250		1210		1000		
WR									
** K									
SR	1st Sep 2015 to	00-06 18-24	4950	750	4200	3850	350		
	30th Sep 2015	06-18'	4950		4200	3915	285		

^{*} Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Margin in Simultaneous import of NR = A

WR-NR ATC =B ER-NR ATC = C

Margin for WR-NR applicants = B * A/(B+C)Margin for ER-NR Applicants = C * A/(B+C)

Example: Margin for WR-NR applicants from 00-05 hours = 231 * 5900/(5900+4500) = 131

Margin for ER-NR applicants from 00-05 hours = 231 * 4500/(5900+4500) = 100

Simultaneous Export Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
NR*	1st Sep 2015 to 30th Sep 2015	00-06 06-18'	4500	700	3800 3800	714 779	3086 3021			
	2011 20p 2013	18-24	4500		3800	714	3086			
NER	1st Sep 2015 to 30th Sep 2015	00-17 23-24	1220	30	1190	0	1190			
		17-23	1300	40	1260		1260			
WD										
WR										
SR *	1st Sep 2015 to 30th Sep 2015	00-24		No limit is being Specified.						

^{*} Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

^{*} For approving STOA Bilateral transactions, margin available in Simultaneous Import of NR would be apportioned on WR-NR Corridor & ER-NR Corridor in the following ratio:

Limiting Constraints

		(n-1) contingency of 400 kV Biharshariff- Lakhisarai S/C
	Immout	High loading of 765 kV Agra-Gwalior (1400 MW SPS setting on each circuit of 765 kV Gwalior-Agra) and high loop
NR	Import	flows on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda (power flowing from WR to NR on 765kV Gwalior-Agra
1111		D/C and from NR to WR on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda).
	Export	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.
	Export	(n-1) contingency of 400 kV Saranath-Pusauli
NER	Import	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other 400/220 kV, 315 MVA
NEK	Export	ICT at Misa
		1. n-1 of 400 kV Wardha – Parli will lead to 30 degrees angular separation between Wardha and Parli.
		2. (n-1) contingency of one circuit of 400kV Parli(PG)-Sholapur(PG)
SR	Import	3. ER-SR TTC has been declared assuming more than 1100 MW generation at Talcher Stage-2. In case Talcher Stage-
	•	2 generation goes below 1100 MW, then the ER-SR TTC would be revised downward as constraints within ER would
		emerge.
		emerge.

^{*}Primary constraints

National Load Despatch Centre Total Transfer Capability for September 2015

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor Affected
1	6/25/2015	Whole month	Revised considering skewed sharing of flows on WR-NR and ER-NR corridor in the range 70:30	Import of NR
2	6/28/2015	Whole month	STOA Margin revised due to Jhajjar reallocation	ER-SR/ NR-WR
3	7/20/2015	Whole month	STOA Margin revised considering CERC order dated 03-07-2015 in petition No- 92/MP/2015 which is under implementation by CTU. Pending this any margins would be released for short term transactions on day ahead basis.	ER-SR
4	8/24/2015	Whole month	Revised due to the commissioning of 765 kV Gwalior-Phagi 1,2	WR-NR/ Import of NR
5	5 8/26/2015 Wh		Revised due to commissioning of 765kV Phagi-Bhiwani S/C and STOA margin revised due to operationalization of MTOA.	WR-NR/ Import of NR
		month	STOA Margin revised due to Operationalization of LTA.	W3 Zone Injection
6	8/26/2015	03/09/15 to 30/09/15	A remark has been put on Simultaneous Import of NR for approving STOA Bilateral Transactions	Import of NR

ASSU	MPTIONS IN BASECASE				
				Month : September	15
S.No.	Name of State/Area	Load		Generation	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
l	NORTHERN REGION				
1	Punjab	8327	7408	4656	4626
2	Haryana	7890	7084	3318	3318
3	Rajasthan	9096	8161	5709	5646
4	Delhi	4549	3953	1095	1095
5	Uttar Pradesh	12551	12022	6555	6605
6	Uttarakhand	1677	1295	874	723
7	Himachal Pradesh	1189	985	988	971
8	Jammu & Kashmir	2123	1439	438	438
9	Chandigarh	266	159	0	0
10	ISGS/IPPs	0	0	19172	14064
	Total NR	47668	42504	42804	37485
II	EASTERN REGION				
1	Bihar	2690	2033	110	0
2	Jharkhand	915	749	507	330
3	Damodar Valley Corporation	2906	2140	3619	2922
4	Orissa	3574	2894	3176	2150
5	West Bengal	7617	5926	5553	3524
6	Sikkim	88	43	0	0
7	Bhutan	105	104	1300	1030
8	ISGS/IPPs	608	568	9360	8909
	Total ER	18502	14458	23625	18865
III	WESTERN REGION				
	Maharashtra	20211	11204	14900	6645
		12909	7121		+
	Gujarat Madhya Bradash		4927	10115	4527 2521
	Madhya Pradesh	7861 3612	2182	4832 2491	1036
	Chattisgarh Daman and Diu	305	2182	0	0
		771	570	0	
	Dadra and Nagar Haveli	513	293	0	0
	Goa-WR ISGS/IPPs		1046	23713	
8		1048			20410
	Total WR	47230	27575	56050	35139

IV	SOUTHERN REGION				
1	Andhra Pradesh	5904	5359	4699	4399
2	Telangana	7336	6348	3626	2262
	Karnataka	7925	6076	7334	5247
4	Tamil Nadu	13399	11925	8681	7218
5	Kerala	3381	2230	1779	694
6	Pondy	338	290	0	0
7	Goa-SR	81	81	0	0
8	ISGS/IPPs	0	0	9605	9470
	Total SR	38364	32309	35724	29290
V	NORTH-EASTERN REGION				
1	Arunachal Pradesh	107	92	0	0
2	Assam	1050	944	285	250
3	Manipur	125	105	0	0
4	Meghalaya	312	208	211	155
5	Mizoram	72	44	4	4
6	Nagaland	110	106	22	16
7	Tripura	266	166	110	110
8	ISGS/IPPs	7	7	1501	1302
	Total NER	2049	1672	2133	1837
	Total All India	153812	118517	160336	122616