

**National Load Despatch Centre  
Total Transfer Capability for September 2020**

Issue Date: 28th September 2020

Issue Time: 1900 hrs

Revision No. 19

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR-WR*	1st September 2020 to 30th September 2020	00-06	2500	500	2000	195	1805		
		06-18				1281	719		
		18-24				195	1805		
WR-NR*	1st September 2020 to 17th September 2020	00-06	18150	500	17650	10268	7382		
			17200**		16700**	9318**			
		06-18	18150	500	17650	10657	6993		
			17200**		16700**	9707**			
		18-24	18150	500	17650	10268	7382		
			17200**		16700**	9318**			
WR-NR*	18th September 2020	00-06	18150	500	17650	10268	7382		
			17200**		16700**	9318**			
		06-10	18150	500	17650	10657	6993		
			17200**		16700**	9707**			
		10-18	17000	500	16500	10657	5843		
			16050**		15550**	9707**			
		18-24	17000	500	16500	10268	6232		
			16050**		15550**	9318**			
WR-NR*	19th September 2020	00-06	18150	500	17650	10268	7382		
			17200**		16700**	9318**			
		06-10	18150	500	17650	10657	6993		
			17200**		16700**	9707**			
		10-18	17000	500	16500	10657	5843		
			16050**		15550**	9707**			
		18-24	17000	500	16500	10268	6232		
			16050**		15550**	9318**			
WR-NR*	20th September 2020 to 24th September 2020	00-06	18150	500	17650	10268	7382		
			17200**		16700**	9318**			
		06-18	18150	500	17650	10657	6993		
			17200**		16700**	9707**			
		18-24	18150	500	17650	10268	7382		
			17200**		16700**	9318**			
WR-NR*	25th September 2020	00-06	18150	500	17650	10268	7382		
			17200**		16700**	9318**			
		06-07	18150	500	17650	10657	6993		
			17200**		16700**	9707**			
		07-18	15800	500	15300	10657	4643		
			14850**		14350**	9707**			
18-24	15800	500	15300	10268	5032				
	14850**		14350**	9318**					

**National Load Despatch Centre**  
**Total Transfer Capability for September 2020**

Issue Date: 28th September 2020

Issue Time: 1900 hrs

Revision No. 19

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
WR-NR*	26th September 2020	00-06	18150	500	17650	10268	7382		
			17200**		16700**	9318**			
		06-07	18150	500	17650	10657	6993		
			17200**		16700**	9707**			
		07-18	18150	500	17650	10657	6993		
17200**	16700**		9707**						
18-24	18150	500	17650	10268	7382				
			17200**		16700**	9318**			
WR-NR*	27th September 2020 to 30th September 2020	00-06	18150	500	17650	10268	7382		
			17200**		16700**	9318**			
		06-18	18150	500	17650	10657	6993		
			17200**		16700**	9707**			
		18-24	18150	500	17650	10268	7382		
17200**	16700**		9318**						
			17200**		16700**	9318**			
NR-ER*	1st September 2020 to 30th September	00-06	2000	200	1800	193	1607		
		06-18	2000		1800	303	1497		
		18-24	2000		1800	193	1607		
ER-NR*	1st September 2020 to 17th September 2020	00-24	6250	300	5950	4066	1884		
ER-NR*	18th September 2020	00-10	6250	300	5950	4066	1884		
		10-24	6100	300	5800	4066	1734		
ER-NR*	19th September 2020	00-10	6250	300	5950	4066	1884		
		10-24	6100	300	5800	4066	1734		
ER-NR*	20th September 2020 to 24th September 2020	00-24	6250	300	5950	4066	1884		
ER-NR*	25th September 2020	00-07	6250	300	5950	4066	1884		
		07-24	6000	300	5700	4066	1634		
ER-NR*	26th September 2020	00-07	6250	300	5950	4066	1884		
		07-24	6250	300	5950	4066	1884		
ER-NR*	27th September 2020 to 30th September 2020	00-24	6250	300	5950	4066	1884		

**National Load Despatch Centre  
Total Transfer Capability for September 2020**

Issue Date: 28th September 2020

Issue Time: 1900 hrs

Revision No. 19

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
W3-ER	1st September 2020 to 30th September 2020	00-24	No limit is being specified.						
ER-W3	1st September 2020 to 30th September 2020	00-24	No limit is being specified.						
WR-SR <sup>^</sup>	1st September 2020 to 5th September	00-05	6950	500	6450	4049	2401		
		05-22	6950		6450		2401		
		22-24	6950		6450		2401		
WR-SR <sup>^</sup>	6th September 2020	00-05	6950	500	6450	4049	2401		
		05-09	6950		6450		2401		
		09-22	6100		5600		1551		
		22-24	6100		5600		1551		
WR-SR <sup>^</sup>	7th September 2020 to 8th September 2020	00-05	6950	500	6450	4049	2401		
		05-22	6950		6450		2401		
		22-24	6950		6450		2401		
WR-SR <sup>^</sup>	9th September 2020	00-05	6950	500	6450	4049	2401		
		05-09	6950	500	6450	4049	2401		
		09-22	6300	500	5800	4049	1751		
		22-24	6300	500	5800	4049	1751		
WR-SR <sup>^</sup>	10th September 2020 to 12th September 2020	00-05	6950	500	6450	4049	2401		
		05-22	6950	500	6450	4049	2401		
		22-24	6950	500	6450	4049	2401		
WR-SR <sup>^</sup>	13th September 2020	00-05	6950	500	6450	4049	2401		
		05-09	6950	500	6450	4049	2401		
		09-22	6300	500	5800	4049	1751		
		22-24	6300	500	5800	4049	1751		
WR-SR <sup>^</sup>	14th September 2020 to 17th September 2020	00-05	6950	500	6450	4049	2401		
		05-22	6950	500	6450	4049	2401		
		22-24	6950	500	6450	4049	2401		
WR-SR <sup>^</sup>	18th September 2020	00-05	6950	500	6450	4049	2401		
		05-08	6950	500	6450	4049	2401		
		08-22	5950	500	5450	4049	1401		
		22-24	5950	500	5450	4049	1401		
WR-SR <sup>^</sup>	19th September 2020	00-05	6950	500	6450	4049	2401		
		05-12	6950	500	6450	4049	2401		
		12-22	6200	500	5700	4049	1651		
		22-24	6200	500	5700	4049	1651		
WR-SR <sup>^</sup>	20th September 2020 to 24th September 2020	00-05	6950	500	6450	4049	2401		
		05-22	6950	500	6450	4049	2401		
		22-24	6950	500	6450	4049	2401		

**National Load Despatch Centre**  
**Total Transfer Capability for September 2020**

Issue Date: 28th September 2020

Issue Time: 1900 hrs

Revision No. 19

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
WR-SR <sup>^</sup>	25th September 2020	00-08	6950	500	6450	4049	2401			
		08-22	6050	500	5550	4049	1501			
		22-24	6050	500	5550	4049	1501			
WR-SR <sup>^</sup>	26th September 2020	00-05	6950	500	6450	4049	2401			
		05-08	6950	500	6450	4049	2401			
		08-22	6350	500	5850	4049	1801			
		22-24	6350	500	5850	4049	1801			
WR-SR <sup>^</sup>	27th September 2020	00-08	6950	500	6450	4049	2401			
		08-24	6300	500	5800	4049	1751			
WR-SR <sup>^</sup>	28th September 2020	00-05	6950	500	6450	4049	2401			
		05-08	6950	500	6450	4049	2401			
		08-22	5450	500	4950	4049	901			
		22-24	5450	500	4950	4049	901			
WR-SR <sup>^</sup>	29th September 2020	00-05	6950	500	6450	4049	2401			
		05-08	6950	500	6450	4049	2401			
		08-22	5450	500	4950	4049	901			
		22-24	5450	500	4950	4049	901			
WR-SR <sup>^</sup>	30th September 2020	00-05	6950	500	6450	4049	2401		Revised TTC due to HVDC Talcher Kolart Pole-1 outage	
		05-08	6950	500	6450	4049	2401			
		08-22	6900	500	6400	4049	2351	-50		
		22-24	6900	500	6400	4049	2351	-50		
SR-WR <sup>*</sup>	1st September 2020 to 30th September 2020	00-24	4600	400	4200	550	3650			
ER-SR <sup>^</sup>	1st September 2020 to 5th September 2020	00-06	5950	250	5700	2663	3037			
		06-18				2748	2952			
		18-24				2663	3037			
ER-SR <sup>^</sup>	6th September 2020	00-06	5950	250	5700	2663	3037			
		06-09				5700	2748	2952		
		09-18				5600	2748	2852		
		18-24				5600	2663	2937		
ER-SR <sup>^</sup>	7th September 2020 to 8th September 2020	00-06	5950	250	5700	2663	3037			
		06-18				2748	2952			
		18-24				2663	3037			

**National Load Despatch Centre  
Total Transfer Capability for September 2020**

Issue Date: 28th September 2020

Issue Time: 1900 hrs

Revision No. 19

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER-SR <sup>^</sup>	9th September 2020	00-06	5950	250	5700	2663	3037		
		06-09	5950	250	5700	2748	2952		
		09-18	5900	250	5650	2748	2902		
		18-24	5900	250	5650	2663	2987		
ER-SR <sup>^</sup>	10th September 2020 to 11th September 2020	00-06				2663	3037		
		06-18	5950	250	5700	2748	2952		
		18-24				2663	3037		
ER-SR <sup>^</sup>	12th September 2020	00-06	5950	250	5700	2663	3037		
		06-09	5950		5700	2748	2952		
		09-18	5650		5400	2748	2652		
		18-24	5650		5400	2663	2737		
ER-SR <sup>^</sup>	13th September 2020	00-06	5950	250	5700	2663	3037		
		06-09	5950		5700	2748	2952		
		09-18	5900		5650	2748	2902		
		18-24	5900		5650	2663	2987		
ER-SR <sup>^</sup>	14th September 2020 to 20th September 2020	00-06		250	5700	2663	3037		
		06-18	5950			2748	2952		
		18-24				2663	3037		
ER-SR <sup>^</sup>	21st September	00-06		250	5480	2663	2817		
		06-18	5730			2748	2732		
		18-24				2663	2817		
ER-SR <sup>^</sup>	22nd September to 23rd September 2020	00-06		250	5480	2663	2817		
		06-18	5730			2748	2732		
		18-24				2663	2817		
ER-SR <sup>^</sup>	24th September to 25th September 2020	00-06		250	5480	2663	2817		
		06-18	5730			2748	2732		
		18-24				2663	2817		
ER-SR <sup>^</sup>	26th September 2020	00-06		250	5480	2663	2817		
		06-18	5730			2748	2732		
		18-24				2663	2817		
ER-SR <sup>^</sup>	27th September 2020	00-06	5730	250	5480	2663	2817		
		06-08	5730		5480	2748	2732		
		08-18	5680		5430	2748	2732		
		18-24	5680		5430	2663	2817		

**National Load Despatch Centre  
Total Transfer Capability for September 2020**

Issue Date: 28th September 2020

Issue Time: 1900 hrs

Revision No. 19

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER-SR <sup>^</sup>	28th September 2020 to 29th September 2020	00-06	5730	250	5480	2663	2817		
		06-18				2748	2732		
		18-24				2663	2817		
ER-SR <sup>^</sup>	30th September 2020	00-06	5950	250	5700	2663	3037		Revised TTC due to HVDC Talcher Kolart Pole-1 outage
		06-08	5950		5700	2748	2952		
		08-18	4900		4650	2748	1902	-1050	
		18-24	4900		4650	2663	1987	-1050	
SR-ER *	1st September 2020 to 30th September 2020	00-24	No limit is being Specified.						
ER-NER*	1st September 2020 to 15th September 2020	00-02	1750	45	1705	474	1231		
		02-07	1750		1705	474	1231		
		07-12	1750		1705	474	1231		
		12-17	1750		1705	474	1231		
		17-18	1750		1705	474	1231		
		18-22	1620		1575	474	1101		
		22-23	1750		1705	474	1231		
		23-24	1750		1705	474	1231		
ER-NER*	16th September 2020	00-02	1750	45	1705	474	1231		
		02-07	1750		1705	474	1231		
		07-09	1750		1705	474	1231		
		09-12	1350		1305	474	831		
		12-17	1350		1305	474	831		
		17-18	1350		1305	474	831		
		18-22	1175		1130	474	656		
		22-23	1350		1305	474	831		
23-24	1350	1305	474	831					
ER-NER*	17th September 2020 to 30th September 2020	00-02	1750	45	1705	474	1231		
		02-07	1750		1705	474	1231		
		07-12	1750		1705	474	1231		
		12-17	1750		1705	474	1231		
		17-18	1750		1705	474	1231		
		18-22	1620		1575	474	1101		
		22-23	1750		1705	474	1231		
		23-24	1750		1705	474	1231		
NER-ER*	1st September 2020 to 5th September 2020	00-02	1820	45	1775	42	1733		
		02-07	1820		1775	42	1733		
		02-07	1820		1775	42	1733		
		07-12	1820		1775	42	1733		
		12-17	1820		1775	42	1733		
		17-18	1820		1775	42	1733		
		18-22	1910		1865	42	1823		
		22-23	1820		1775	42	1733		
		23-24	1820		1775	42	1733		

**National Load Despatch Centre**  
**Total Transfer Capability for September 2020**

Issue Date: 28th September 2020

Issue Time: 1900 hrs

Revision No. 19

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NER-ER*	6th September 2020	00-02	1820	45	1775	42	1733		
		02-06	1820		1775	42	1733		
		06-07	1020		975	42	933		
		07-12	1020		975	42	933		
		12-17	1020		975	42	933		
		17-18	1020		975	42	933		
		18-22	1040		995	42	953		
		22-23	1020		975	42	933		
		23-24	1020		975	42	933		
NER-ER*	7th September 2020 to 15th September 2020	00-02	1820	45	1775	42	1733		
		02-07	1820		1775	42	1733		
		07-12	1820		1775	42	1733		
		12-17	1820		1775	42	1733		
		17-18	1820		1775	42	1733		
		18-22	1910		1865	42	1823		
		22-23	1820		1775	42	1733		
		23-24	1820		1775	42	1733		
NER-ER*	16th September 2020	00-02	1820	45	1775	42	1733		
		02-07	1820		1775	42	1733		
		07-09	1820		1775	42	1733		
		09-12	1650		1605	42	1563		
		12-17	1650		1605	42	1563		
		17-18	1650		1605	42	1563		
		18-22	1710		1665	42	1623		
		22-23	1650		1605	42	1563		
		23-24	1650		1605	42	1563		
NER-ER*	17th September 2020 to 30th September 2020	00-02	1820	45	1775	42	1733		
		02-07	1820		1775	42	1733		
		07-12	1820		1775	42	1733		
		12-17	1820		1775	42	1733		
		17-18	1820		1775	42	1733		
		18-22	1910		1865	42	1823		
		22-23	1820		1775	42	1733		
		23-24	1820		1775	42	1733		

<b>W3 zone Injection</b>	1st September 2020 to 30th September 2020	00-24	No limit is being specified (In case of any constraints appearing in the system, W3 zone export would be revised accordingly)						
--------------------------	---	-------	---	--	--	--	--	--	--

**Note: TTC/ATC of S1-(S2&S3) corridor, Import of S3(Kerala), Import of Punjab and Import of DD & DNH is uploaded on NLDC website under Intra-Regional Section in Monthly ATC.**

**National Load Despatch Centre**  
**Total Transfer Capability for September 2020**

Issue Date: 28th September 2020

Issue Time: 1900 hrs

Revision No. 19

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
----------	------	-------------------	---------------------------------	--------------------	-------------------------------------	--	--	-------------------------------------	----------

\* Fifty Percent (50 % ) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

\*\*Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.

1) S1 comprises of Telangana, AP and Karnataka; S2 comprises of Tamil Nadu and Puducherry; S3 comprises Kerala

2) W3 comprises of the following regional entities :

a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak

f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPCCL, n)Vandana Vidyut o)RKM, p)GMR Raikheda, q)Ind Barath and any other regional entity generator in Chhattisgarh

# The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/ Fuel shortage/New units being commissioned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis.

In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

In case of TTC Revision due to any shutdown :

1) The TTC value will be revised to normal values after restoration of shutdown.

2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.

Real Time TTC/ATC revisions are uploaded on POSOCO/NLDC "News Update" (Flasher) Section

^Though 2X315 MVA, 400/220 kV ICTs at Maradam are N-1 non-compliant, the TTC of WR-SR and ER-SR corridor has not been restricted due to the same considering that this aspect will be managed by AP SLDC through appropriate measures like SPS implementation.

^In case of drawl of Karnataka beyond 3800 MW, the voltages in Bengaluru area are observed to be critically low. This issue may be taken care of by Karnataka SLDC by taking appropriate measures.

SR-WR TTC/ATC figures have been calculated considering 01 unit (800 MW) at Kudgi TPS in service. The figures are subject to change with change in generation at Kudgi TPS.

WR-NR/Import of NR TTC has been calculated considering generation at Pariccha TPS as 350 MW. TTC figures are subject to change with significant change in generation at Pariccha TPS.

Simultaneous Import Capability									
Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR*	1st September 2020 to 17th September 2020	00-06	24400	800	23600	14334	9266		
			23450**		22650**	13384**			
		06-09	24400		23600	14723	8877		
			23450**		22650**	13773**			
		09-17	24400		23600	14723	8877		
			23450**		22650**	13773**			
17-18	24400	23600	14723	8877					
	23450**	22650**	13773**						
18-24	24400	23600	14334	9266					
	23450**	22650**	13384**						
NR*	18th September 2020	00-06	24400	800	23600	14334	9266		
			23450**		22650**	13384**			
		06-09	24400		23600	14723	8877		
			23450**		22650**	13773**			
		09-10	24400		23600	14723	8877		
			23450**		22650**	13773**			
10-17	23100	22300	14723	7577					
	22150**	21350**	13773**						
17-18	23100	22300	14723	7577					
	22150**	21350**	13773**						
18-24	23100	22300	14334	7966					
	22150**	21350**	13384**						
NR*	19th September 2020	00-06	24400	800	23600	14334	9266		
			23450**		22650**	13384**			
		06-09	24400		23600	14723	8877		
			23450**		22650**	13773**			
		09-10	24400		23600	14723	8877		
			23450**		22650**	13773**			
10-17	23100	22300	14723	7577					
	22150**	21350**	13773**						
17-18	23100	22300	14723	7577					
	22150**	21350**	13773**						
18-24	23100	22300	14334	7966					
	22150**	21350**	13384**						

NR*	20th September 2020 to 24th September 2020	00-06	24400	800	23600	14334	9266	
			23450**		22650**	13384**		
		06-09	24400		23600	14723	8877	
			23450**		22650**	13773**		
		09-17	24400		23600	14723	8877	
			23450**		22650**	13773**		
		17-18	24400		23600	14723	8877	
			23450**		22650**	13773**		
		18-24	24400		23600	14334	9266	
			23450**		22650**	13384**		
NR*	25th September 2020	00-06	24400	800	23600	14334	9266	
			23450**		22650**	13384**		
		06-07	24400		23600	14723	8877	
			23450**		22650**	13773**		
		07-09	21800		21000	14723	6277	
			20850**		20050**	13773**		
		09-17	21800		21000	14723	6277	
			20850**		20050**	13773**		
		17-18	21800		21000	14723	6277	
			20850**		20050**	13773**		
18-24	21800	21000	14334	6666				
	20850**	20050**	13384**					
NR*	26th September 2020	00-06	24400	800	23600	14334	9266	
			23450**		22650**	13384**		
		06-07	24400		23600	14723	8877	
			23450**		22650**	13773**		
		07-09	24400		23600	14723	8877	
			23450**		22650**	13773**		
		09-17	24400		23600	14723	8877	
			23450**		22650**	13773**		
		17-18	24400		23600	14723	8877	
			23450**		22650**	13773**		
18-24	24400	23600	14334	9266				
	23450**	22650**	13384**					

<b>NR*</b>	27th September 2020 to 30th September 2020	00-06	24400 23450**	800	23600 22650**	14334 13384**	9266		
		06-09	24400 23450**		23600 22650**	14723 13773**	8877		
		09-17	24400 23450**		23600 22650**	14723 13773**	8877		
		17-18	24400 23450**		23600 22650**	14723 13773**	8877		
		18-24	24400 23450**		23600 22650**	14334 13384**	9266		
		00-02	1050		45	1005	474	531	
		02-07	1050			1005	474	531	
		07-12	1050			1005	474	531	
		12-17	1050			1005	474	531	
		17-18	1050			1005	474	531	
18-22	920	875	474	401					
22-23	1050	1005	474	531					
23-24	1050	1005	474	531					
<b>NER*</b>	16th September 2020	00-02	1050	45	1005	474	531		
		02-07	1050		1005	474	531		
		07-09	1050		1005	474	531		
		09-12	650		605	474	131		
		12-17	650		605	474	131		
		17-18	650		605	474	131		
		18-22	475		430	474	0		
		22-23	650		605	474	131		
		23-24	650		605	474	131		
<b>NER*</b>	17th September 2020 to 30th September 2020	00-02	1050	45	1005	474	531		
		02-07	1050		1005	474	531		
		07-12	1050		1005	474	531		
		12-17	1050		1005	474	531		
		17-18	1050		1005	474	531		
		18-22	920		875	474	401		
		22-23	1050		1005	474	531		
		23-24	1050		1005	474	531		

WR*									
SR**	1st September 2020 to 5th September 2020	00-06	12900	750	12150	6712	5438		
		06-18	12900		12150	6797	5353		
		18-24	12900		12150	6712	5438		
SR**	6th September 2020	00-06	12900	750	12150	6712	5438		
		06-09	12900		12150	6797	5353		
		09-18	11950		11200	6797	4403		
		18-24	11950		11200	6712	4488		
SR**	7th September 2020 to 8th September 2020	00-06	12900	750	12150	6712	5438		
		06-18	12900		12150	6797	5353		
		18-24	12900		12150	6712	5438		
SR**	9th September 2020	00-06	12900	750	12150	6712	5438		
		06-09	12900	750	12150	6797	5353		
		09-18	12200	750	11450	6797	4653		
		18-24	12200	750	11450	6712	4738		
SR**	10th September 2020 to 11th September 2020	00-06	12900	750	12150	6712	5438		
		06-18	12900		12150	6797	5353		
		18-24	12900		12150	6712	5438		
SR**	12th September 2020	00-06	12900	750	12150	6712	5438		
		06-09	12900		12900	6797	6103		
		09-18	12600		11850	6797	5053		
		18-24	12600		11850	6712	5138		
SR**	13th September 2020	00-06	12900	750	12150	6712	5438		
		06-09	12900	750	12150	6797	5353		
		09-18	12200	750	11450	6797	4653		
		18-24	12200	750	11450	6712	4738		
SR**	14th September 2020 to 17th September 2020	00-06	12900	750	12150	6712	5438		
		06-18	12900		12150	6797	5353		
		18-24	12900		12150	6712	5438		
SR**	18th September 2020	00-06	12900	750	12150	6712	5438		
		06-08	12900		12150	6797	5353		
		08-18	11900		11150	6797	4353		
		18-24	11900		11150	6712	4438		

SR <sup>**</sup>	19th September 2020	00-06	12900	750	12150	6712	5438	
		06-12	12900		12150	6797	5353	
		12-18	12150		11400	6797	4603	
		18-24	12150		11400	6712	4688	
SR <sup>**</sup>	20th September	00-06	12900	750	12150	6712	5438	
		06-18	12900		12150	6797	5353	
		18-24	12900		12150	6712	5438	
SR <sup>**</sup>	21st September	00-06	12680	750	11930	6712	5218	
		06-18	12680		11930	6797	5133	
		18-24	12680		11930	6712	5218	
SR <sup>**</sup>	22nd September to 23rd September 2020	00-06	12680	750	11930	6712	5218	
		06-18	12680		11930	6797	5133	
		18-24	12680		11930	6712	5218	
SR <sup>**</sup>	24th September 2020	00-06	12680	750	11930	6712	5218	
		06-18	12680		11930	6797	5133	
		18-24	12680		11930	6712	5218	
SR <sup>**</sup>	25th September 2020	00-06	12680	750	11930	6712	5218	
		06-08	12680	750	11930	6797	5133	
		08-18	11780	750	11030	6797	4233	
		18-24	11780	750	11030	6712	4318	
SR <sup>**</sup>	26th September 2020	00-06	12680	750	11930	6712	5218	
		06-08	12680		11930	6797	5133	
		08-18	12080		11330	6797	4533	
		18-24	12080		11330	6712	4618	

SR**	27th September 2020	00-06	12680	750	11930	6712	5218	
		06-08	12680		11930	6797	5133	
		08-18	12180		11430	6797	4633	
		18-24	12180		11430	6712	4718	
SR**	28th September 2020	00-06	12680	750	11930	6712	5218	
		06-08	12680		12680	6797	5883	
		08-18	11180		10430	6797	3633	
		18-24	11180		10430	6712	3718	
SR**	29th September 2020	00-06	12680	750	11930	6712	5218	
		06-08	12680		12680	6797	5883	
		08-18	11180		10430	6797	3633	
		18-24	11180		10430	6712	3718	
SR**	30th September 2020	00-06	12900	750	12150	6712	5438	
		06-08	12900		12900	6797	6103	
		08-18	11800		11050	6797	4253	-1100
		18-24	11800		11050	6712	4338	-1100

Revised TTC due to HVDC Talcher Kolart Pole-1 outage

\* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

\*\*Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.

\* For approving STOA Bilateral transactions, margin available in Simultaneous Import of NR would be apportioned on WR-NR Corridor & ER-NR Corridor in the following ratio:

Margin in Simultaneous import of NR = A

WR-NR ATC = B

ER-NR ATC = C

Margin for WR-NR applicants =  $A * B / (B+C)$

Margin for ER-NR Applicants =  $A * C / (B+C)$

Real Time TTC/ATC revisions are uploaded on POSOCO/NLDC "News Update" (Flasher) Section

#Though 2X315 MVA, 400/220 kV ICTs at Maradam are N-1 non-compliant, the TTC of SR Import has not been restricted due to the same considering that this aspect will be managed by AP SLDC through appropriate measures like SPS implementation.

In case of drawl of Karnataka beyond 3800 MW, the voltages in Bengaluru area are observed to be critically low. This issue may be taken care of by Karnataka by taking appropriate measures.

WR-NR/Import of NR TTC has been calculated considering generation at Pariccha TPS as 350 MW. TTC figures are subject to change with significant change in generation at Pariccha TPS.

<b>Simultaneous Export Capability</b>									
<b>Corridor</b>	<b>Date</b>	<b>Time Period (hrs)</b>	<b>Total Transfer Capability (TTC)</b>	<b>Reliability Margin</b>	<b>Available Transfer Capability (ATC)</b>	<b>Long Term Access (LTA)/ Medium Term Open Access (MTOA)</b>	<b>Margin Available for Short Term Open Access (STOA)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
<b>NR*</b>	1st September 2020 to 30th September 2020	00-06	4500	700	3800	388	3412		
		06-18			3800	1584	2216		
		18-24	4500		3800	388	3412		
<b>NER*</b>	1st September 2020 to 5th September 2020	00-02	2520	45	2475	42	2433		
		02-07	2520		2475	42	2433		
		07-12	2520		2475	42	2433		
		12-17	2520		2475	42	2433		
		17-18	2520		2475	42	2433		
		18-22	2610		2565	42	2523		
		22-23	2520		2475	42	2433		
		23-24	2520		2475	42	2433		
<b>NER*</b>	6th September 2020	00-02	2520	45	2475	42	2433		
		02-06	2520		2475	42	2433		
		02-07	1720		1675	42	1633		
		07-12	1720		1675	42	1633		
		12-17	1720		1675	42	1633		
		17-18	1720		1675	42	1633		
		18-22	1740		1695	42	1653		
		22-23	1720		1675	42	1633		
23-24	1720	1675	42	1633					
<b>NER*</b>	7th September 2020 to 15th September 2020	00-02	2520	45	2475	42	2433		
		02-07	2520		2475	42	2433		
		07-12	2520		2475	42	2433		
		12-17	2520		2475	42	2433		
		17-18	2520		2475	42	2433		
		18-22	2610		2565	42	2523		
		22-23	2520		2475	42	2433		
		23-24	2520		2475	42	2433		
<b>NER*</b>	16th September 2020	00-02	2520	45	2475	42	2433		
		02-07	2520		2475	42	2433		
		07-09	2520		2475	42	2433		
		09-12	2350		2305	42	2263		
		12-17	2350		2305	42	2263		
		17-18	2350		2305	42	2263		
		18-22	2410		2365	42	2323		
		22-23	2350		2305	42	2263		
		23-24	2350		2305	42	2263		

<b>NER*</b>	17th September 2020 to 30th September 2020	00-02	2520	45	2475	42	2433		
		02-07	2520		2475	42	2433		
		07-12	2520		2475	42	2433		
		12-17	2520		2475	42	2433		
		17-18	2520		2475	42	2433		
		18-22	2610		2565	42	2523		
		22-23	2520		2475	42	2433		
		23-24	2520		2475	42	2433		
<b>WR*</b>									
<b>SR*^</b>	1st September 2020 to 30th September 2020	00-24	3700	400	3300	1150	2150		

\* Fifty Percent (50 % ) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Real Time TTC/ATC revisions are uploaded on POSOCO/NLDC "News Update" (Flasher) Section

^SR Export TTC/ATC figures have been calculated considering 01 unit (800 MW) at Kudgi TPS in service. The figures are subject to change with change in generation at Kudgi TPS.

<b>Limiting Constraints (Corridor wise)</b>		<b>Applicable Revisions</b>	
<b>Corridor</b>	<b>Constraint</b>		
<b>WR-NR</b>	N-1 contingency of 1000 MVA, 765/400 kV ICT at Orai will overload the other ICT	Rev 0 to 19	
<b>NR-ER</b>	(n-1) contingency of 400 kV Saranath-Pusauli	Rev 0 to 19	
<b>ER-NR</b>	1. N-1 contingency of 400 kV Mejia-Maithon A line will overload the other ckt. 2. Inter-regional flow pattern towards NR	Rev 0 to 19	
<b>WR-SR and ER-SR</b>	n-1 contingency of one ckt of 765 kV Wardha - Nizamabad D/C will overload of the other ckt	Rev 0 to 19	
	n-1 contingency of one ckt of 765 kV Angul - Srikakulam D/C will overload of the other ckt		
	Low Voltage at Gazuwaka (East) Bus.		
<b>SR-WR</b>	a) N-1 contingency of one ckt of 400 kV Kolhapur-PG - Kolhapur-MS D/C will overload of the other ckt b) N-1 contingency of 500 MVA ICT at 400 kV Kolhapur-MS will overload the other 2x315 MVA ICTs	Rev 0 to 19	
<b>ER-NER</b>	a) N-1 contingency of 400 kV Bongaigaon - Azara line b) High Loading of 220 kV Salakati - BTPS D/C	Rev 0 to 19	
<b>NER-ER</b>	a) N-1 contingency of 400 kV Silchar- Azara line b) High Loading of 400 kV Silchar-Killing Line	Rev 0 to 19	
<b>W3 zone Injection</b>	---	Rev 0 to 19	
<b>Limiting Constraints (Simultaneous)</b>		<b>Applicable Revisions</b>	
<b>NR</b>	<b>Import</b>	1. N-1 contingency of 400 kV Mejia-Maithon A line will overload the other ckt. 2. Inter-regional flow pattern towards NR	Rev 0 to 19
		N-1 contingency of 1000 MVA, 765/400 kV ICT at Orai will overload the other ICT	Rev 0 to 19
	<b>Export</b>	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak. (n-1) contingency of 400 kV Saranath-Pusauli	Rev 0 to 19
<b>NER</b>	<b>Import</b>	a) N-1 contingency of 400 kV Bongaigaon - Azara line b) High Loading of 220 kV Salakati - BTPS D/C	Rev 0 to 19
	<b>Export</b>	a) N-1 contingency of 400 kV Silchar- Azara line b) High Loading of 400 kV Silchar-Killing Line	Rev 0 to 19
<b>SR</b>	<b>Import</b>	n-1 contingency of one ckt of 765 kV Wardha - Nizamabad D/C will overload of the other ckt	Rev 0 to 19
		n-1 contingency of one ckt of 765 kV Angul - Srikakulam D/C will overload of the other ckt	
		Low Voltage at Gazuwaka (East) Bus	
	<b>Export</b>	N-1 contingency of one ckt of 400 kV Kolhapur-PG - Kolhapur-MS D/C will overload of the other ckt N-1 contingency of 500 MVA ICT at 400 kV Kolhapur-MS will overload the other 2x315 MVA ICTs	Rev 0 to 19

**National Load Despatch Centre**  
**Total Transfer Capability for September 2020**

Revision No	Date of Revision	Period of Revision	Reason for Revision/Comment	Corridor Affected
1	28th June 2020	Whole Month	Revision in STOA margin due to change in LTA quantum from GIWEL_SECI-III_RE (Wind, Bhuj) to Punjab from 151.2 MW to 200 MW	WR-NR/Import of NR
			Revision in STOA margin due to allocation of 20.75 MW power from Kameng HEP to UP, Haryana, Chhattisgarh and Goa	NER-ER/Export of NER/ER-NR/Import of NR
2	30th August 2020	Whole Month	Revision in TTC/ATC due to the following:- a) Change in Load-Generation of NER b) Addition of 2x150 MW out of 4 x 150 MW Kameng Generation c) Incorporation of HVDC flow of 700 MW between Biswanath Chariali and Agra	ER-NER/NER-ER/Import and Export of NER
			Revision in STOA margin due to the following:- a) Increase in allocation from Kameng HEP to UP, Haryana, Chhattisgarh and Goa b) Revision in LTA/allocation from GIWEL, Bhuj (Wind) and Mangdechhu HEP to Assam	
3	4th Sep 2020	6th Sep 2020	Revision in TTC/ATC due to planned outage of 765 kV Raichur - Solapur-I	ER-SR/WR-SR/Import of SR
			Revised TTC due to planned shutdown of 400 kV Alipurduar Binaguri D/C-I	NER-ER/Export of NER
4	7th Sep 2020	9th Sep 2020	Revision in TTC due to planned outage of HVDC Bhadrawati Block-II	ER-SR/WR-SR/Import of SR
5	10th Sep 2020	12th Sep 2020	Revised TTC due to shutdown of 400/220 kV 315 MVA ICT-1 at Jeypore	ER-SR/Import of SR
6	11th Sep 2020	13th Sep 2020	Revision in TTC due to planned outage of HVDC Bhadrawati Block-I	ER-SR/WR-SR/Import of SR
7	14th Sep 2020	16th Sep 2020	Revised TTC due to day time shutdown of 400 kV Bongaigaon Azara S/C	NER-ER/Export of NER/ER-NR/Import of NR
8	16th Sep 2020	18th Sep 2020	Revised TTC due to shutdown of HVDC Champa Kurukshetra Pole-II	ER-NR/WR-NR/Import of NR
			Revised TTC due to reverse power order testing on HVDC Raigarh-Pugalur	WR-SR/Import of SR
9	17th Sep 2020	19th Sep 2020	Revised TTC due to shutdown of HVDC Champa Kurukshetra Pole-II	ER-NR/WR-NR/Import of NR
			Revised TTC due to reverse power order testing on HVDC Raigarh-Pugalur	WR-SR/Import of SR
10	20th Sep 2020	21st Sep 2020	Revised due to operation of HVDC Talchar -Kolar Pole 1 in RVO Mode @ 80% of DC Voltage due to suspected/damaged smoothing reactor	ER-SR/Import of SR
11	20th Sep 2020	22nd Sep 2020 to 23rd Sep 2020	Revised due to operation of HVDC Talchar -Kolar Pole 1 in RVO Mode @ 80% of DC Voltage due to suspected/damaged smoothing reactor	ER-SR/Import of SR
12	22nd Sep 2020	24th Sep 2020 to 25th Sep 2020	Revised due to operation of HVDC Talchar -Kolar Pole 1 in RVO Mode @ 80% of DC Voltage due to suspected/damaged smoothing reactor	ER-SR/Import of SR
13	23rd Sep 2020	25th Sep 2020	Revised TTC due to reverse power order testing on HVDC Raigarh-Pugalur	WR-SR/Import of SR
		25th Sep 2020	Revision in TTC due to planned outage of HVDC Champa - Kurukshetra Pole - 3 & 4	WR-NR/ER-NR/Import of NR
		26th Sep 2020	Revision in TTC due to planned outage of HVDC Champa - Kurukshetra Pole -1 & 2	
14	24th Sep 2020	26th Sep 2020	1.Revised TTC due to reverse power order testing on HVDC Raigarh-Pugalur 2.Revised due to operation of HVDC Talchar -Kolar Pole 1 in RVO Mode @ 80% of DC Voltage due to suspected/damaged smoothing reactor	WR-SR/ER-SR/Import of SR
			Revised due to non-availing shutdown of HVDC Champa-Kurukshetra Pole-1 and 2	WR-NR/ER-NR/Import of NR
15	25th Sep 2020	27th Sep 2020	Revised due to operation of HVDC Talchar -Kolar Pole 1 in RVO Mode @ 80% of DC Voltage due to suspected/damaged smoothing reactor	ER-SR/Import of SR
16	26th Sep 2020	27th Sep 2020	TTC/ATC Revised due to planned shutdown of 400 kV Bus 2 at Bhadrawati	WR-SR/Import of SR
17	26th Sep 2020	28th Sep 2020	Revised TTC due to reverse power order testing on HVDC Raigarh-Pugalur	WR-SR/Import of SR
18	27th Sep 2020	29th Sep 2020	Revised TTC due to reverse power order testing on HVDC Raigarh-Pugalur	WR-SR/Import of SR
19	28th Sep 2020	30th Sep 2020	Revised TTC due to HVDC Talchar Kolar Pole-1 outage	ER-SR/WR-SR/Import of SR

ASSUMPTIONS IN BASECASE					
				Month : September'2020	
S.No.	Name of State/Area	Load		Generation	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
I	<b>NORTHERN REGION</b>				
1	Punjab	10228	9530	4580	4618
2	Haryana	9146	9428	2953	2953
3	Rajasthan	10205	11428	6168	6168
4	Delhi	5674	6558	753	753
5	Uttar Pradesh	18102	15529	9903	9908
6	Uttarakhand	2144	1981	1060	1015
7	Himachal Pradesh	1562	1558	859	854
8	Jammu & Kashmir	3049	1686	1075	1017
9	Chandigarh	375	303	0	0
10	ISGS/IPPs	23	23	20932	19626
	<b>Total NR</b>	<b>60510</b>	<b>58023</b>	<b>48283</b>	<b>46912</b>
II	<b>EASTERN REGION</b>				
1	Bihar	5380	4412	99	110
2	Jharkhand	1637	1024	425	421
3	Damodar Valley Corporation	3028	2466	4980	4180
4	Orissa	4823	3995	3952	2615
5	West Bengal	8541	7006	5659	4956
6	Sikkim	114	43	0	0
7	Bhutan	171	168	1474	1444
8	ISGS/IPPs	-171	-168	11907	10404
	<b>Total ER</b>	<b>23523</b>	<b>18947</b>	<b>28495</b>	<b>24128</b>
III	<b>WESTERN REGION</b>				
1	Maharashtra	16912	14197	12996	9886
2	Gujarat	13683	8433	10325	6208
3	Madhya Pradesh	8253	5455	4058	2863
4	Chattisgarh	3890	3168	2239	2230
5	Daman and Diu	297	153	0	0
6	Dadra and Nagar Haveli	781	550	0	0
7	Goa-WR	513	326	0	0
8	ISGS/IPPs	4640	3609	33397	25451
	<b>Total WR</b>	<b>48969</b>	<b>35891</b>	<b>63015</b>	<b>46638</b>

S.No.	Name of State/Area	Load		Generation	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
IV	SOUTHERN REGION				
1	Andhra Pradesh	9316	6695	6310	5934
2	Telangana	9937	9870	5913	4863
3	Karnataka	8351	4343	6606	3257
4	Tamil Nadu	14738	12867	8660	7460
5	Kerala	3683	2236	1649	423
6	Pondy	298	246	0	0
7	Goa-SR	58	48	0	0
8	ISGS/IPPs	0	0	14970	12179
	Total SR	46381	36305	44109	34117
V	NORTH-EASTERN REGION				
1	Arunachal Pradesh	111	70	18	16
2	Assam	1707	1346	295	245
3	Manipur	183	82	0	0
4	Meghalaya	269	198	237	142
5	Mizoram	99	66	68	42
6	Nagaland	120	75	22	16
7	Tripura	259	154	76	75
8	ISGS/IPPs	159	81	2385	2242
	Total NER	2907	2073	3101	2778
	Total All India	182131	151157	187003	154572