

**National Load Despatch Centre
Total Transfer Capability for Sep 2025**

Issue Date:Sep 28 2024

Issue Time:19:28:55

Revision No :0

| Corridor | Date | Time Period(hrs) | Total Transfer Capability(TTC) | Reliability Margin(RM) | Available Transfer Capability(ATC) | Approved GNA(MW) | Margin for T-GNA (MW) | Changes w.r.t. Previous Revision | Comment |
|--------------|------------------|------------------|--------------------------------|------------------------|------------------------------------|------------------|-----------------------|----------------------------------|---------|
| ER-NER | 01 Sep to 30 Sep | 00:00 to 06:00 | 1400 | 60 | 1340 | NA | | 0 | |
| | | 06:00 to 12:00 | 1550 | 60 | 1490 | NA | | 0 | |
| | | 12:00 to 18:00 | 1550 | 60 | 1490 | NA | | 0 | |
| | | 18:00 to 22:00 | 1050 | 60 | 990 | NA | | 0 | |
| | | 22:00 to 24:00 | 1400 | 60 | 1340 | NA | | 0 | |
| ER-NR | 01 Sep to 30 Sep | 00:00 to 24:00 | 6700 | 400 | 6300 | NA | | 0 | |
| ER-SR | 01 Sep to 30 Sep | 00:00 to 06:00 | 6200 | 350 | 5850 | NA | | 0 | |
| | | 06:00 to 18:00 | 6200 | 350 | 5850 | NA | | 0 | |
| | | 18:00 to 24:00 | 6200 | 350 | 5850 | NA | | 0 | |
| ER-W3 | 01 Sep to 30 Sep | 00:00 to 24:00 | No limit is being specified. | | | | | | |
| ER-WR | 01 Sep to 30 Sep | 00:00 to 24:00 | NA | NA | | NA | | 0 | |
| NER-ER | 01 Sep to 30 Sep | 00:00 to 06:00 | 3480 | 60 | 3420 | NA | | 0 | |
| | | 06:00 to 12:00 | 3480 | 60 | 3420 | NA | | 0 | |
| | | 12:00 to 18:00 | 3480 | 60 | 3420 | NA | | 0 | |
| | | 18:00 to 22:00 | 3480 | 60 | 3420 | NA | | 0 | |
| | | 22:00 to 24:00 | 3480 | 60 | 3420 | NA | | 0 | |
| NR-ER | 01 Sep to 30 Sep | 00:00 to 06:00 | 4000 | 300 | 3700 | NA | | 0 | |
| | | 06:00 to 18:00 | 4000 | 300 | 3700 | NA | | 0 | |
| | | 18:00 to 24:00 | 4000 | 300 | 3700 | NA | | 0 | |
| NR-WR | 01 Sep to 30 Sep | 00:00 to 06:00 | 6000 | 500 | 5500 | NA | | 0 | |
| | | 06:00 to 18:00 | 6000 | 500 | 5500 | NA | | 0 | |
| | | 18:00 to 24:00 | 6000 | 500 | 5500 | NA | | 0 | |
| SR-ER | 01 Sep to 30 Sep | 00:00 to 24:00 | No limit is being specified. | | | | | | |
| SR-WR | 01 Sep to 30 Sep | 00:00 to 06:00 | 7200 | 650 | 6550 | NA | | 0 | |
| | | 06:00 to 18:00 | 7100 | 650 | 6450 | NA | | 0 | |
| | | 18:00 to 24:00 | 7200 | 650 | 6550 | NA | | 0 | |
| W3 Injection | 01 Sep to 30 Sep | 00:00 to 24:00 | NA | NA | | NA | | 0 | |
| W3-ER | 01 Sep to 30 Sep | 00:00 to 24:00 | No limit is being specified. | | | | | | |
| WR-ER | 01 Sep to 30 Sep | 00:00 to 06:00 | 5500 | 300 | 5200 | NA | | 0 | |
| | | 06:00 to 18:00 | 5500 | 300 | 5200 | NA | | 0 | |
| | | 18:00 to 24:00 | 5500 | 300 | 5200 | NA | | 0 | |
| WR-NR | 01 Sep to 30 Sep | 00:00 to 09:00 | 22350 | 1000 | 21350 | NA | | 0 | |
| | | 09:00 to 16:00 | 18050 | 1000 | 17050 | NA | | 0 | |
| | | 16:00 to 24:00 | 22350 | 1000 | 21350 | NA | | 0 | |
| WR-SR | 01 Sep to 30 Sep | 00:00 to 06:00 | 16100 | 650 | 15450 | NA | | 0 | |
| | | 06:00 to 18:00 | 16100 | 650 | 15450 | NA | | 0 | |
| | | 18:00 to 24:00 | 16100 | 650 | 15450 | NA | | 0 | |

- Based on the actual distribution of corridor flows, Counter flow benefit on account of transactions in the reverse direction would be considered for short-term transactions wherever applicable.
- Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.
- S1 comprises of Telangana, AP and Karnataka; S2 comprises of Tamil Nadu and Puducherry; S3 comprises Kerala
- W3 comprises of the following regional entities : a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) NTPC Korba I, II & III, j) NTPC Sipat I & II, k) KSK Mahanadi, l) DB Power, m) REGL (Previously KWPC), n) RKM, o) REL, p) Bharat Aluminium, q) MCCPL, r) SKS, s) TRN, t) NTPC Lara, u) Adani Power Limited Raipur and any other regional entity generator in Chhattisgarh
- The figure is based on GNA approved by CTU. In actual Operation, due to Units being on Maintenance/ Fuel shortage/New units being commissioned, the dispatches of units would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net

schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

- In case of TTC Revision due to any shutdown : 1) The TTC value will be revised to normal values after restoration of shutdown. 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.
- Real Time TTC/ATC revisions are uploaded on Grid-India/NLDC "News Update" (Flasher) Section

Simultaneous Import Capability

| Corridor | Date | Time Period(hrs) | Total Transfer Capability(TTC) | Reliability Margin(RM) | Available Transfer Capability(ATC) | Approved GNA(MW) | Margin for T-GNA (MW) | Changes w.r.t. Previous Revision | Comment |
|----------|------------------|------------------|--------------------------------|------------------------|------------------------------------|------------------|-----------------------|----------------------------------|---------|
| ER | 01 Sep to 30 Sep | 00:00 to 24:00 | NA | NA | | 3222 | NA | 0 | |
| NER | 01 Sep to 30 Sep | 00:00 to 06:00 | 1400 | 60 | 1340 | 824 | 516 | 0 | |
| | | 06:00 to 12:00 | 1550 | 60 | 1490 | 824 | 666 | 0 | |
| | | 12:00 to 18:00 | 1550 | 60 | 1490 | 824 | 666 | 0 | |
| | | 18:00 to 22:00 | 1050 | 60 | 990 | 824 | 166 | 0 | |
| | | 22:00 to 24:00 | 1400 | 60 | 1340 | 824 | 516 | 0 | |
| NR | 01 Sep to 30 Sep | 00:00 to 09:00 | 25700 | 1400 | 24300 | 17344 | 6956 | 0 | |
| | | 09:00 to 16:00 | 19250 | 1400 | 17850 | 17344 | 506 | 0 | |
| | | 16:00 to 24:00 | 25700 | 1400 | 24300 | 17344 | 6956 | 0 | |
| SR | 01 Sep to 30 Sep | 00:00 to 06:00 | 22300 | 1000 | 21300 | 7601 | 13699 | 0 | |
| | | 06:00 to 18:00 | 22300 | 1000 | 21300 | 7601 | 13699 | 0 | |
| | | 18:00 to 24:00 | 22300 | 1000 | 21300 | 7601 | 13699 | 0 | |
| WR | 01 Sep to 30 Sep | 00:00 to 24:00 | NA | NA | | 7813 | NA | 0 | |

- Based on the actual distribution of corridor flows, Counter flow benefit on account of transactions in the reverse direction would be considered for short-term transactions wherever applicable.
- Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.
- S1 comprises of Telangana, AP and Karnataka; S2 comprises of Tamil Nadu and Puducherry; S3 comprises Kerala
- W3 comprises of the following regional entities : a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) NTPC Korba I, II & III, j) NTPC Sipat I & II, k) KSK Mahanadi, l) DB Power, m) REGL (Previously KWPC), n) RKM, o) REL, p) Bharat Aluminium, q) MCCPL, r) SKS, s) TRN, t) NTPC Lara, u) Adani Power Limited Raipur and any other regional entity generator in Chhattisgarh
- The figure is based on GNA approved by CTU. In actual Operation, due to Units being on Maintenance/ Fuel shortage/New units being commissioned, the dispatches of units would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.
- In case of TTC Revision due to any shutdown : 1) The TTC value will be revised to normal values after restoration of shutdown. 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.
- Real Time TTC/ATC revisions are uploaded on Grid-India/NLDC "News Update" (Flasher) Section

Simultaneous Export Capability

| Corridor | Date | Time Period(hrs) | Total Transfer Capability(TTC) | Reliability Margin(RM) | Available Transfer Capability(ATC) | Approved GNA(MW) | Margin for T-GNA (MW) | Changes w.r.t. Previous Revision | Comment |
|----------|------------------|------------------|--------------------------------|------------------------|------------------------------------|------------------|-----------------------|----------------------------------|---------|
| ER | 01 Sep to 30 Sep | 00:00 to 24:00 | NA | NA | | NA | | 0 | |
| NER | 01 Sep to 30 Sep | 00:00 to 06:00 | 3480 | 60 | 3420 | NA | | 0 | |
| | | 06:00 to 12:00 | 3480 | 60 | 3420 | NA | | 0 | |
| | | 12:00 to 18:00 | 3480 | 60 | 3420 | NA | | 0 | |
| | | 18:00 to 22:00 | 3480 | 60 | 3420 | NA | | 0 | |
| | | 22:00 to 24:00 | 3480 | 60 | 3420 | NA | | 0 | |
| NR | 01 Sep to 30 Sep | 00:00 to 06:00 | 6000 | 500 | 5500 | NA | | 0 | |
| | | 06:00 to 18:00 | 6000 | 500 | 5500 | NA | | 0 | |
| | | 18:00 to 24:00 | 6000 | 500 | 5500 | NA | | 0 | |
| SR | 01 Sep to 30 Sep | 00:00 to 06:00 | 6400 | 650 | 5750 | NA | | 0 | |
| | | 06:00 to 18:00 | 6400 | 650 | 5750 | NA | | 0 | |
| | | 18:00 to 24:00 | 6400 | 650 | 5750 | NA | | 0 | |
| WR | 01 Sep to 30 Sep | 00:00 to 24:00 | NA | NA | | NA | | 0 | |

- Based on the actual distribution of corridor flows, Counter flow benefit on account of transactions in the reverse direction would be considered for short-term transactions wherever applicable.

- Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.
- S1 comprises of Telangana, AP and Karnataka; S2 comprises of Tamil Nadu and Puducherry; S3 comprises Kerala
- W3 comprises of the following regional entities : a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) NTPC Korba I, II & III, j) NTPC Sipat I & II, k) KSK Mahanadi, l) DB Power, m) REGL (Previously KWPC), n) RKM, o) REL, p) Bharat Aluminium, q) MCCPL, r) SKS, s) TRN, t) NTPC Lara, u) Adani Power Limited Raipur and any other regional entity generator in Chhattisgarh
- The figure is based on GNA approved by CTU. In actual Operation, due to Units being on Maintenance/ Fuel shortage/New units being commissioned, the dispatches of units would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.
- In case of TTC Revision due to any shutdown : 1) The TTC value will be revised to normal values after restoration of shutdown. 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.
- Real Time TTC/ATC revisions are uploaded on Grid-India/NLDC "News Update" (Flasher) Section

Limiting Constraints

| Corridor | Constraints | Revisions |
|------------|---|-----------|
| WR-NR | 1. N-1 contingency of one ckt of 765 kV Vindhyachal-Varanasi will overload the other circuit 2. Low Voltages in major load Centers in the northern region during solar hours. 3. High loading of 765 KV Aligarh-Gr. Noida under N-1 contingency of 765 KV Bara-Mainpuri ckt | 0-30,0 |
| NR-ER | 1. Overloading of one circuit of 400 kV New Ranchi – New PPSP D/C on the tripping of the other circuit 2. Overloading of one circuit of 400 kV Kahalgaon – Farakka D/C on the tripping of the other circuit 3. Overloading of 400 kV Farakka – Sagardighi – 1 on the tripping of 400 kV Farakka – Sagardighi - 2 | 0-30,0 |
| WR-ER | 1. Overloading of one circuit of 400 kV New Ranchi – New PPSP D/C on the tripping of the other circuit 2. Overloading of one circuit of 400 kV Kahalgaon – Farakka D/C on the tripping of the other circuit 3. Overloading of 400 kV Farakka – Sagardighi – 1 on the tripping of 400 kV Farakka – Sagardighi - 2 | 0-30,0 |
| ER-NR | Inter-regional flow pattern towards NR | 0-30,0 |
| WR-SR | Outage of any one of the 2x1500 MVA, 765/400 kV ICTs at Maheswaram overloads the other ICT | 0-30,0 |
| ER-SR | 1. Low Voltage at Gazuwaka (East) Bus. | 0-30,0 |
| SR-WR | a) Angular separation between Kudgi & Kolhapur (PG) under N-1 touches 30 deg. b) N-1 Contingency of 765/400 kV, 1500 MVA ICTs at Raichur - PG will overload the other ICT. c) N-1 Contingency of 400 kV Pune – Kalwa will overload 400 kV Pune - Khargar & and vice-versa. d) N-1 Contingency of 400 kV Kolhapur – Karad D/C will overload the other circuit. e) N-1 non-compliance of 2*1500 MVA, 765/400 kV ICTs at Section– B at Raigarh – PS (Kotra) with operation of HVDC Raigarh – Pugalur Bipole – 1 in SR-WR direction f) Restriction in power order of HVDC Gazuwaka(SR to ER) to maximum set point of 700 MW for solar hrs and 500 MW for non-solar hrs against the rated capacity of 1000 MW | 0-30,0 |
| ER-NER | Outage of 400 kV Bongaigaon - Azara line will lead to the high Loading of 220 kV Balipara-Sonabil - 1 & 2 | 0-30,0 |
| NER-ER | N-1 contingency of 400 kV Bongaigaon-Alipurduar I or II will lead to High Loading of 400 kV Bongaigaon- New Siliguri I & II | 0-30,0 |
| NR_IMPORT | 1. N-1 contingency of one ckt of 765 kV Vindhyachal-Varanasi will overload the other circuit 2. Low Voltages in major load Centers in the northern region during solar hours. 3. High loading of 765 KV Aligarh-Gr. Noida under N-1 contingency of 765 KV Bara-Mainpuri ckt 4. Inter-regional flow pattern towards NR | 0-30,0 |
| NR_EXPORT | Outage of the longer circuit from 400 kV Kankroli to Zerda (Bypassed at Bhinmal) will overload the shorter circuit (Direct Line) | 0-30,0 |
| NER_IMPORT | Outage of 400 kV Bongaigaon - Azara line will lead to the high Loading of 220 kV Balipara-Sonabil - 1 & 2 | 0-30,0 |
| NER_EXPORT | N-1 contingency of 400 kV Bongaigaon-Alipurduar I or II will lead to High Loading of 400 kV Bongaigaon- New Siliguri I & II | 0-30,0 |
| SR_IMPORT | 1. Outage of any one of the 2x1500 MVA, 765/400 kV ICTs at Maheswaram overloads the other ICT 2. Low Voltage at Gazuwaka (East) Bus | 0-30,0 |
| SR_EXPORT | a) Angular separation between Kudgi & Kolhapur (PG) under N-1 touches 30 deg. b) N-1 Contingency of 765/400 kV, 1500 MVA ICTs at Raichur - PG will overload the other ICT. c) N-1 Contingency of 400 kV Pune – Kalwa will overload 400 kV Pune - Khargar & and vice-versa. d) N-1 Contingency of 400 kV Kolhapur – Karad D/C will overload the other circuit. e) N-1 non-compliance of 2*1500 MVA, 765/400 kV ICTs at Section– B at Raigarh – PS (Kotra) with operation of HVDC Raigarh – Pugalur Bipole – 1 in SR-WR direction f) Restriction in power order of HVDC Gazuwaka(SR to ER) to maximum set point of 700 MW for solar hrs and 500 MW for non-solar hrs against the rated capacity of 1000 MW | 0-30,0 |

Revision Summary

| Revision | Date Of Revision | Period Of Revision | Reason for Revision/Comment | Corridor Affected |
|----------|------------------|--------------------|-----------------------------|-------------------|
|----------|------------------|--------------------|-----------------------------|-------------------|

| ASSUMPTIONS IN BASECASE | | | | | |
|-------------------------|--------------------|--------------------|-----------------|--------------------|-----------------|
| Month : Sept'25 | | | | | |
| S.No. | Name of State/Area | Demand | | Generation | |
| | | Non-Solar Peak(MW) | Solar Peak (MW) | Non-Solar Peak(MW) | Solar Peak (MW) |
| I | NORTHERN REGION | | | | |

| | | | | | |
|-----|----------------------------|--------|--------|--------|--------|
| 1 | Punjab | 6786 | 6770 | 3900 | 3660 |
| 2 | Haryana | 6932 | 7300 | 1426 | 3659 |
| 3 | Rajasthan | 13840 | 17619 | 6944 | 8474 |
| 4 | Delhi | 4003 | 4328 | 365 | 314 |
| 5 | Uttar Pradesh | 18915 | 17337 | 10369 | 10075 |
| 6 | Uttarakhand | 1977 | 1728 | 821 | 366 |
| 7 | Himachal Pradesh | 1660 | 1709 | 595 | 306 |
| 8 | Jammu & Kashmir | 2278 | 2673 | 226 | 230 |
| 9 | Chandigarh | 203 | 176 | 0 | 0 |
| 10 | ISGS/IPPs | 114 | 115 | 19978 | 22204 |
| | Total NR | 56708 | 59755 | 44624 | 49288 |
| | | | | | |
| II | EASTERN REGION | | | | |
| 1 | Bihar | 5084 | 4030 | 445 | 436 |
| 2 | Jharkhand | 1645 | 1700 | 406 | 427 |
| 3 | Damodar Valley Corporation | 3510 | 3400 | 5600 | 5332 |
| 4 | Orissa | 6186 | 6000 | 3818 | 3764 |
| 5 | West Bengal | 7660 | 8000 | 6462 | 6115 |
| 6 | Sikkim | 106 | 98 | 0 | 0 |
| 7 | Bhutan | 33 | 49 | 307 | 372 |
| 8 | ISGS/IPPs | 920 | 728 | 16923 | 17242 |
| | Total ER | 25143 | 24005 | 33962 | 33688 |
| | | | | | |
| III | WESTERN REGION | | | | |
| 1 | Maharashtra | 25755 | 29506 | 16723 | 19565 |
| 2 | Gujarat | 18687 | 20689 | 8270 | 8865 |
| 3 | Madhya Pradesh | 14705 | 17125 | 7923 | 9952 |
| 4 | Chattisgarh | 4208 | 3970 | 1768 | 1801 |
| 5 | DD & DNH | 971 | 974 | 0 | 0 |
| 6 | Goa-WR | 674 | 676 | 0 | 0 |
| 7 | ISGS/IPPs | 2490 | 2493 | 47245 | 48284 |
| | Total WR | 67491 | 75433 | 81929 | 88468 |
| | | | | | |
| IV | SOUTHERN REGION | | | | |
| 1 | Andhra Pradesh | 9057 | 12431 | 5376 | 7080 |
| 2 | Telangana | 7435 | 9730 | 4578 | 7247 |
| 3 | Karnataka | 10750 | 13304 | 5081 | 7257 |
| 4 | Tamil Nadu | 16629 | 16830 | 5755 | 9952 |
| 5 | Kerala | 4253 | 3484 | 1637 | 646 |
| 6 | Pondy | 578 | 575 | 25 | 40 |
| 7 | Goa-SR | 87 | 87 | 0 | 0 |
| 8 | ISGS/IPPs | 12 | 12 | 21969 | 20081 |
| | Total SR | 48800 | 56452 | 44422 | 52305 |
| | | | | | |
| V | NORTH-EASTERN REGION | | | | |
| 1 | Arunachal Pradesh | 164 | 100 | 0 | 0 |
| 2 | Assam | 1430 | 1140 | 271 | 444 |
| 3 | Manipur | 260 | 138 | 0 | 0 |
| 4 | Meghalaya | 468 | 348 | 139 | 13 |
| 5 | Mizoram | 169 | 140 | 31 | 8 |
| 6 | Nagaland | 157 | 119 | 14 | 7 |
| 7 | Tripura | 366 | 316 | 190 | 193 |
| 8 | ISGS/IPPs | 0 | 0 | 3215 | 2609 |
| | Total NER | 3014 | 2301 | 3860 | 3274 |
| | | | | | |
| | Total All India | 201120 | 217890 | 208385 | 226545 |