## **National Load Despatch Centre**

## Import of Bihar Transfer Capability for November 2021

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st November 2021 to 30th November 2021	00-24	5000	100	4900	4592.39	308		
Limiting Constraints		132kV Bettiah-DMTCL (Motihari) over loading on N-1 tripping of the other parallel ckt						