

National Load Despatch Centre
Import of Chhattisgarh Transfer Capability for Nov 2021

Issue Date: 26th July 2021

Issue Time: 1700 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
* 1st Nov 2021 to 30th Nov 2021	00-24	2170	50	2120	2071	49		400 kV Korba (NTPC)-Korba (West)-S/C is under OPEN condition
#1st Nov 2021 to 30th Nov 2021	00-24	2430	50	2380	2071	309		400 kV Korba (NTPC)-Korba (West)-S/C is under CLOSED condition
Limiting Constraints		* N-1 contingency of 2 x 315 MVA, 400/220 kV Bhatapara ICTs # Contingency of 220 kV Raigarh-PG-Raigarh-CG-1						

National Load Despatch Centre
Import of Chhattisgarh Transfer Capability for Nov 2021

Revision No	Date of Revision	Period of Revision	Reason for Revision