

National Load Despatch Centre
Import of Chhattisgarh Transfer Capability for Sept 2021

Issue Date: 08th Sept 2021

Issue Time: 1615 hrs

Revision No. 1

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Sept 2021 to 07th Sept 2021	00-24	2050	50	2000	3185	-1185		
08th Sept 2021 to 30th Sept 2021	00-24	2590	50	2540	3185	-645		
Limiting Constraints	N-1 contingency of (a) 2X 315 MVA, 400/220kV NSPCL ICTs, (b) 2X 315 MVA, 400/220kV Bhatapara ICTs, (c) 2X 315 MVA, 400/220kV Raigarh-PG ICTs							

National Load Despatch Centre
Import of Chhattisgarh Transfer Capability for Sept 2021

Revision No	Date of Revision	Period of Revision	Reason for Revision
1	08.09.2021	08.09.21-30.09.2021	Bus re-arrangements done by CSPTCL at 220 kV Bhilai/Banari/Suhela to control ICTs loading at NSPCL/Bhatapara