## **National Load Despatch Centre**

## **Import of DNH Transfer Capability for Feb 2022**

Issue Date: 26th Oct 2021 Issue Time: 1500 hrs Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Feb 2022 to 28th Feb 2022	00-24	840	15	825	1201	-376		Allocated LTA is more than ATC
<b>Limiting Constraints</b>		N-1 contingency of 220 kV Kala-Khadoli D/C						

## National Load Despatch Centre Import of DNH Transfer Capability for Feb 2022

Revision	Date of	Period of	Reason for Revision		
No	Revision	Revision			