

National Load Despatch Centre
Import of DNHDDPDCL Transfer Capability for August 2025

Issue Date: 28th August 2024

Issue Time: 1700 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Control area	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Approved GNA (MW)	Margin for T-GNA (MW)	Changes in TTC w.r.t. Last Revision	Comments
1st August 2025 to 31st August 2025	00-24	DNHDDPDCL	1310	25	1285	1206	79		
	00-24	DNH	470	10	460	384	76		
	00-24	DD	840	15	825	822	3		
Limiting Constraints			DNH: N-1 contingency of 220 kV Kala-Khadoli D/C						
			DD: N-1 contingency of 220 kV Magarwada-Magarwada(DD)-D/c						

****This total TTC/ATC is for mentioning in SCADA and WRLDC website for DNHDDPDCL. In real time, ATC violations would be monitored separately for DD&DNH.**

Import of DNHDDPDCL Transfer Capability for August 2025

Revision No	Date of Revision	Period of Revision	Reason for Revision